

**Iowa Department of Natural Resources
Title V Operating Permit**

Name of Permitted Facility: Red Star Yeast Company, LLC
Facility Location: 950 60th Avenue SW, Cedar Rapids, IA 52404
Air Quality Operating Permit Number: 10-TV-006R2
Expiration Date: September 29, 2025
Permit Renewal Application Deadline: March 29, 2025

EIQ Number: 92-6919
Facility File Number: 57-01-226

Responsible Official

Name: Anthony Marolda
Title: VP Operations
Mailing Address: 7475 W. Main Street Milwaukee, Wisconsin 53214
Phone #: (414) 615-4051

Permit Contact Person for the Facility

Name: Scott Groth
Title: EHS Manager
Mailing Address: 950 60th Avenue SW Cedar Rapids, IA 52404
Phone #: (319) 896-2620

This permit is issued in accordance with 567 Iowa Administrative Code Chapter 22, and is issued subject to the terms and conditions contained in this permit. This facility, ADM Corn Processing (Plant No. 57-01-080), Vantage Corn Processing (Plant No. 57-01-246), and Bio Springer North America Corporation (Plant No. 57-01-226) are considered one stationary source. Four Title V Permits have been issued for the four facilities. This permit is for Red Star Yeast Company, LLC. Other permits have been issued for ADM Corn Processing (Permit No. 08-TV-004R1-M002), Vantage Corn Processing (Permit No. 08-TV-007R1-M001) and Bio Springer North America Corporation (Permit No. 12-TV-005R1).

For the Director of the Department of Natural Resources



09/30/2020

Marnie Stein, Supervisor of Air Operating Permits Section

Date

Table of Contents

I. Facility Description and Equipment List	4
II. Plant - Wide Conditions.....	6
III. Emission Point Specific Conditions	9
IV. General Conditions.....	45
G1. Duty to Comply	
G2. Permit Expiration	
G3. Certification Requirement for Title V Related Documents	
G4. Annual Compliance Certification	
G5. Semi-Annual Monitoring Report	
G6. Annual Fee	
G7. Inspection of Premises, Records, Equipment, Methods and Discharges	
G8. Duty to Provide Information	
G9. General Maintenance and Repair Duties	
G10. Record keeping Requirements for Compliance Monitoring	
G11. Evidence used in establishing that a violation has or is occurring	
G12. Prevention of Accidental Release: Risk Management Plan Notification and Compliance Certification	
G13. Hazardous Release	
G14. Excess Emissions and Excess Emissions Reporting Requirements	
G15. Permit Deviation Reporting Requirements	
G16. Notification Requirements for Sources That Become Subject to NSPS and NESHAP Regulations	
G17. Requirements for Making Changes to Emission Sources That Do Not Require Title V Permit Modification	
G18. Duty to Modify a Title V Permit	
G19. Duty to Obtain Construction Permits	
G20. Asbestos	
G21. Open Burning	
G22. Acid Rain (Title IV) Emissions Allowances	
G23. Stratospheric Ozone and Climate Protection (Title VI) Requirements	
G24. Permit Reopening	
G25. Permit Shield	
G26. Severability	
G27. Property Rights	
G28. Transferability	
G29. Disclaimer	
G30. Notification and Reporting Requirements for Stack Tests or Monitor Certification	
G31. Prevention of Air Pollution Emergency Episodes	
G32. Contacts List	
V. Appendices.....	55
Appendix A: Applicable Federal Standards	
Appendix B: CAM Plan(s) Summary	
Appendix C: Facility O&M Plan(s) Summary	
Appendix D: Opacity Monitoring Summary	
Appendix E: Stack Testing Summary	

Abbreviations

acfm	actual cubic feet per minute
ATI	authorization to install
CFR	Code of Federal Regulation
CE	control equipment
CEM	continuous emission monitor
DNR	Department of Natural Resources
°F	degrees Fahrenheit
EIQ	emissions inventory questionnaire
EP	emission point
EU	emission unit
gph	gallons per hour
gr./dscf	grains per dry standard cubic foot
gr./100 cf	grains per one hundred cubic feet
H	Horizontal discharge
IAC	Iowa Administrative Code
LCPH	Linn County Public Health
LCO	Linn County Ordinance
MVAC	motor vehicle air conditioner
NSPS	new source performance standard
NAICS	North American Industry Classification System
N/A	not applicable
ppmv	parts per million by volume
lb./hr	pounds per hour
lb./MMBtu	pounds per million British thermal units
PTO	permit to operate
scfm	standard cubic feet per minute
SIC	Standard Industrial Classification
tph	tons per hour
tpy	tons per year
USEPA	United States Environmental Protection Agency
V	Vertical (without rain cap or with unobstructing rain cap)

Pollutants

PM	particulate matter
PM ₁₀	particulate matter ten microns or less in diameter
SO ₂	sulfur dioxide
NO _x	nitrogen oxides
VOC	volatile organic compound
CO	carbon monoxide
HAP	hazardous air pollutant
SHAP	single hazardous air pollutant
THAP	total hazardous air pollutant

I. Facility Description and Equipment List

Facility Name: Red Star Yeast Company, LLC

Permit Number: 10-TV-006R2

Facility Description: Yeast Manufacturing (NAICS 311999; SIC 2099)

Equipment List

Emission Point Number	Emission Unit Number	Emission Unit Description	Construction Permit Number(s) (ATI/PTO)
1.1	EU 01.1	Trade Fermenter 1	LCPH ATI 5927 / PTO 5586 DNR PSD 03-A-1038-P3
1.2	EU 01.2	Trade Fermenter 2	LCPH ATI 5928 / PTO 5587 DNR PSD 03-A-1039-P3
1.3	EU 01.3	Trade Fermenter 3	LCPH ATI 5929 / PTO 5588 DNR PSD 03-A-1040-P3
1.4	EU 01.4	Trade Fermenter 4	LCPH ATI 5930 / PTO 5589 DNR PSD 03-A-1041-P3
1.5	EU 01.5	Trade Fermenter 5	LCPH ATI 5931 / PTO 5590 DNR PSD 03-A-1042-P3
1.6	EU 01.6	Trade Fermenter 6	LCPH ATI 5932 / PTO 5591 DNR PSD 03-A-1043-P3
1.7	EU 01.7	Trade Fermenter 7	LCPH ATI 5933 / PTO 5592 DNR PSD 03-A-1044-P3
1.8	EU 01.8	Trade Fermenter 8	LCPH ATI 5470 / PTO 6278 DNR PSD 08-A-281-P2
1.10	EU 01.10	Trade Fermenter 10	LCPH ATI 6822 / PTO 6755-R1
2.1	EU 02.1	Stock Fermenter 1	LCPH ATI 5934 / PTO 5593 DNR PSD 03-A-1048-P3
3.1	EU 03.1	Pure Culture Fermenter 1	LCPH ATI 5935 / PTO 5594 DNR PSD 03-A-1050-P3
39.10	EU 39.10	Yeast Plant Cooling Tower Cell #10	LCPH ATI 5446 / PTO 5600 DNR PSD 08-A-174P1
39.11	EU 39.11	Yeast Plant Cooling Tower Cell #11	LCPH ATI 5447 / PTO 5601 DNR PSD 080-A-175P1
39.12	EU 39.12	Yeast Plant Cooling Tower Cell #12	LCPH ATI 5448 / PTO 5602 DNR PSD 08-A-176P1
39.13	EU 39.13	Yeast Plant Cooling Tower Cell #13	LCPH ATI 5449 / PTO 6280 DNR PSD 08-A-177P1
39.14	EU 19.14	Yeast Plant Cooling Tower Cell #14	LCPH ATI 5450 / PTO 6383 DNR PSD 08-A-178P1
39.15	EU 39.15	Yeast Plant Cooling Tower Cell #15	LCPH ATI 6823 / PTO 6910
39.16	EU 39.16	Yeast Plant Cooling Tower Cell #16	LCPH ATI 6824 / PTO 6911
50	EU AS.1	Plant Haul Roads	LCPH ATI 5505 / PTO 6238 DNR PSD 08-A-180P1
43.3	EU 43.3	Vitamin Prep	LCPH ATI 6928 / PTO 6912
43.4	EU 43.4	Packaging	LCPH ATI 6929 / PTO 6913
7.1	EU 07.1	Nutritional Yeast Dryer	LCPH ATI 6608 / PTO 6445-R2
7.2	EU 07.2	Nutritional Yeast Dryer	LCPH ATI 6609 / PTO 6446-R2
7.3	EU 07.4	Nutritional Yeast Dryer	LCPH ATI 7113 / PTO 6849
	EU 07.5	Nutritional Yeast Dryer	
18.1	EU 18.1	Dry Ingredient Storage Silo	LCPH ATI 4586 / PTO 5206-R2
18.2	EU 18.2	Dry Ingredient Storage Silo	LCPH ATI 6935 / PTO 6931
19.1	EU 19.1	Dry Ingredient Storage Silo	LCPH ATI 5521 / PTO 5595-R1
19.2	EU 19.2	Dry Ingredient Storage Silo	LCPH ATI 5522 / PTO 5596-R1

Emission Point Number	Emission Unit Number	Emission Unit Description	Construction Permit Number(s) (ATI/PTO)
20.1	EU 20.1	Dry Ingredient Rail Car Unloading Baghouse	LCPH ATI 5523 / PTO 5597-R2
60.1	EU 60.1	Emergency Generator	SI 152
S1.1	EU S1.1	Ingredient Silo #1	LCPH ATI 6954 / PTO 6905
C2.1	EU C2.1	Pneumatic Conveyor #1	LCPH ATI 6955 / PTO 6906
B3.1	EU B3.1	Blender #1	LCPH ATI 6956 / PTO 6907
BD4.1	EU BD4.1	Bag Dumper	LCPH ATI 6957 / PTO 6908
PL5.1	EU PL5.1	Packaging Line #1	LCPH ATI 6958 / PTO 6909
FP7.1	EU FP7.1	Emergency Fire Pump	CI 142
BU8.1	EU BU8.1	Bulk Bag Unloader #1	LCPH ATI 7195 / PTO 6930

Insignificant Activities Equipment List

Insignificant Emission Unit ID	Insignificant Emission Unit Description
EU 39.1	Cooling Tower
EU 39.2	Cooling Tower
EU 39.3	Cooling Tower
EU 39.4	Cooling Tower
EU 39.5	Cooling Tower
EU 39.6	Cooling Tower
EU 39.7	Cooling Tower
EU 39.8	Cooling Tower
EU 39.9	Cooling Tower
NA	Natural Gas Heaters <10 MMBTU/hr
NA	Dry chemical silo
NA	Process chemical storage tanks
NA	Water treatment chemical generator vent

II. Plant-Wide Conditions

Facility Name: Red Star Yeast Company, LLC
Permit Number: 10-TV-006R2

Permit conditions are established in accord with 567 Iowa Administrative Code rule 22.108

Permit Duration

The term of this permit is: Five years
Commencing on: September 30, 2020
Ending on: September 29, 2025

Amendments, modifications and reopenings of the permit shall be obtained in accordance with 567 Iowa Administrative Code rules 22.110 - 22.114. Permits may be suspended, terminated, or revoked as specified in 567 Iowa Administrative Code Rules 22.115.

Plant-Wide Emission Limits

Unless specified otherwise in the Source Specific Conditions, the following limitations and supporting regulations apply to all emission points at this plant:

Opacity (visible emissions): 20 % opacity
Authority for Requirement: LCO Sec. 10-60(a)

Sulfur Dioxide (SO₂): 500 parts per million by volume
Authority for Requirement: 567 IAC 23.3(3)"e"; LCO Sec. 10-65(a)(2)

Particulate Matter:

No person shall cause or allow the emission of particulate matter from any source in excess of the emission standards specified in this chapter, except as provided in 567 – Chapter 24. For sources constructed, modified or reconstructed on or after July 21, 1999, the emission of particulate matter from any process shall not exceed an emission standard of 0.1 grain per dry standard cubic foot of exhaust gas, except as provided in 567 – 21.2(455B), 23.1(455B), 23.4(455B) and 567 – Chapter 24.

For sources constructed, modified or reconstructed prior to July 21, 1999, the emission of particulate matter from any process shall not exceed the amount determined from Table I, or amount specified in a permit if based on an emission standard of 0.1 grain per standard cubic foot of exhaust gas or established from standards provided in 23.1(455B) and 23.4(455B).

Authority for Requirement: 567 IAC 23.3(2)"a"

Particulate Matter: No person shall permit, cause, suffer or allow the emission of particulate matter into the atmosphere in any one hour from any emission point from any process equipment at a rate in excess of that specified in Table I for the process weight rate allocated to such emission point. The emission standards in LCO 10.9 (1)"a" shall apply and those specified in LCO 10.8 and 10.9 and Table I shall not apply to each process of the types listed in those sections, with the following exception: whenever the compliance status, history of operations, ambient air quality in the vicinity, or the type of control equipment utilized, would warrant maximum control, the Air Pollution Control Officer may enforce 0.1 grain per standard cubic foot of exhaust gas, or Table I of this section, whichever would result in the lowest allowable emission rate.

Authority for Requirement: LCO Sec. 10-62(a)

Fugitive Dust: Attainment and Unclassified Areas - A person shall take reasonable precautions to prevent particulate matter from becoming airborne in quantities sufficient to cause a nuisance as defined in Iowa Code section 657.1 when the person allows, causes or permits any materials to be handled, transported or stored or a building, its appurtenances or a construction haul road to be used, constructed, altered, repaired or demolished, with

the exception of farming operations or dust generated by ordinary travel on unpaved roads. Ordinary travel includes routine traffic and road maintenance activities such as scarifying, compacting, transporting road maintenance surfacing material, and scraping of the unpaved public road surface. All persons, with the above exceptions, shall take reasonable precautions to prevent the discharge of visible emissions of fugitive dusts beyond the lot line of the property on which the emissions originate. The public highway authority shall be responsible for taking corrective action in those cases where said authority has received complaints of or has actual knowledge of dust conditions which require abatement pursuant to this subrule. Reasonable precautions may include, but not be limited to, the following procedures.

1. Use, where practical, of water or chemicals for control of dusts in the demolition of existing buildings or structures, construction operations, the grading of roads or the clearing of land.
2. Application of suitable materials, such as but not limited to asphalt, oil, water or chemicals on unpaved roads, material stockpiles, race tracks and other surfaces which can give rise to airborne dusts.
3. Installation and use of containment or control equipment, to enclose or otherwise limit the emissions resulting from the handling and transfer of dusty materials, such as but not limited to grain, fertilizer or limestone.
4. Covering, at all times when in motion, open-bodied vehicles transporting materials likely to give rise to airborne dusts.
5. Prompt removal of earth or other material from paved streets or to which earth or other material has been transported by trucking or earth-moving equipment, erosion by water or other means.
6. Reducing the speed of vehicles traveling over on-property surfaces as necessary to minimize the generation of airborne dusts.

Authority for Requirement: 567 IAC 23.3(2)"c"
LCO Sec. 10-66

Regulatory Authority

This facility is located in Linn County, Iowa. Linn County Public Health Department, under agreement with the Iowa Department of Natural Resources (DNR), is the primary regulatory agency in Linn County. This Title V permit is issued by the Iowa Department of Natural Resources, however, required contacts and information submittals referred to in this permit as required by "the Department" should continue to be directed to the Linn County Public Health Department office. This will include such items as stack test notification, stack test results submittal, oral and written excess emission reports, and reports and records required in the Linn County construction permits. Information specifically required by the Title V permit such as the annual EIQ and fees, annual compliance certification, semi-annual monitoring report and any Title V forms submitted for updates, modifications, renewals, etc. must be submitted to the Iowa DNR.

Authority for Requirement: 567 IAC 22.108

40 CFR 60 Subpart III Requirements

This facility is subject to Standards of Performance for Stationary Compression Ignition Internal Combustion Engines.

See Appendix A, Applicable Federal Standards

Authority for Requirement: 40 CFR 60 Subpart III
567 IAC 23.1(2)"yyy"
LCO Sec. 10-62(b)(77)

40 CFR 60 Subpart JJJJ Requirements

This facility is subject to Standards of Performance for Stationary Spark Ignition Internal Combustion Engines.

See Appendix A, Applicable Federal Standards

Authority for Requirement: 40 CFR 60 Subpart JJJJ
567 IAC 23.1(2)"zzz"
LCO Sec. 10-62(b)(78)

40 CFR 63 Subpart Q Requirements

This facility is subject to National Emission Standards for Hazardous Air Pollutants for Industrial Process Cooling Towers.

See Appendix A, Applicable Federal Standards

Authority for Requirement: 40 CFR 63 Subpart Q

567 IAC 23.1(4)"q"

LCO Sec. 10-62(b)(17)

40 CFR 63 Subpart CCCC Requirements

This facility is subject to National Emission Standards for Hazardous Air Pollutants: Manufacturing of Nutritional Yeast.

See Appendix A, Applicable Federal Standards

Authority for Requirement: 40 CFR 63 Subpart CCCC

567 IAC 23.1(4)"cc"

LCO Sec. 10-62(b)(81)

40 CFR 63 Subpart ZZZZ Requirements

This facility is subject to National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.

See Appendix A, Applicable Federal Standards

Authority for Requirement: 40 CFR 63 Subpart ZZZZ

567 IAC 23.1(4)"cz"

LCO Sec. 10-62(d)(104)

III. Emission Point-Specific Conditions

Facility Name: Red Star Yeast Company, LLC
 Permit Number: 10-TV-006R2

Emission Point ID Number: 1.1, 1.2, 1.3, 1.4, 1.5, 1.6, 1.7, 1.8

Associated Equipment Table 1

EP	EU	EU Description	Raw Material	Rated Capacity	CE ID	CE Description
1.1	1.1	Trade Fermenter 1	Yeast Culture, Carbon Substrate	5,990 lbs/hr	--	Process Control
1.2	1.2	Trade Fermenter 2		5,990 lbs/hr	--	Process Control
1.3	1.3	Trade Fermenter 3		5,990 lbs/hr	--	Process Control
1.4	1.4	Trade Fermenter 4		5,990 lbs/hr	--	Process Control
1.5	1.5	Trade Fermenter 5		5,990 lbs/hr	--	Process Control
1.6	1.6	Trade Fermenter 6		5,990 lbs/hr	--	Process Control
1.7	1.7	Trade Fermenter 7		5,990 lbs/hr	--	Process Control
1.8	1.8	Trade Fermenter 8		5,990 lbs/hr	--	Process Control

Associated Equipment Table 2

EP	EU	CEM
1.1	1.1	ME01.1 – VOC
1.2	1.2	ME01.2 – VOC
1.3	1.3	ME01.3 – VOC
1.4	1.4	ME01.4 – VOC
1.5	1.5	ME01.5 – VOC
1.6	1.6	ME01.6 – VOC
1.7	1.7	ME01.7 – VOC
1.8	1.8	ME01.8 - VOC

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from these emission points shall not exceed the levels specified below.

General Emission Limits

EP	Pollutant	Emission Limit(s)	Authority for Requirement
1.1, 1.2, 1.3, 1.4, 1.5, 1.6, 1.7, 1.8	Opacity	40%	567 IAC 23.2(2)"d"
		20%	LCO Sec.10-60(a)
	PM	0.1 gr/dscf	567 IAC 23.3(2)"a" LCO Sec. 10-62(a)(1)

Emission Limits (When used as a Trade Fermenter)

EP	Pollutant	Emission Limit(s)	Authority for Requirement
1.1	Opacity	40% ^(4,5)	DNR PSD 03-A-1038-P3
1.2			LCPH ATI 5927 / PTO 5586
1.3	PM	0.1 gr/dscf	DNR PSD 03-A-1039-P3
1.4	PM/PM ₁₀	0.043 lb/hr ⁽¹⁾ ; 1.02 tpy ^(2,3)	LCPH ATI 5928 / PTO 5587

EP	Pollutant	Emission Limit(s)	Authority for Requirement
1.5	VOC	100 ppmv ⁽⁶⁾ ; 142 lb/batch ⁽⁷⁾ ; 225 tpy ^(2,8)	DNR PSD 03-A-1040-P3
1.6			LCPH ATI 5929 / PTO 5588
1.7	SHAP	47.35 tpy ^(2,9)	DNR PSD 03-A-1041-P3
1.8	THAP	47.35 tpy ^(2,10)	LCPH ATI 5930 / PTO 5589
			DNR PSD 03-A-1042-P3
			LCPH ATI 5931 / PTO 5590
			DNR PSD 03-A-1043-P3
			LCPH ATI 5932 / PTO 5591
			DNR PSD 03-A-1044-P3
			LCPH ATI 5933 / PTO 5592
	DNR PSD 08-A-281-P2		
	LCPH ATI 5470 / PTO 6278		

Emission Limits (When used as a First Generation Fermenter)

EP	Pollutant	Emission Limit(s)	Authority for Requirement
1.1	Opacity	40% ^(4,5)	DNR PSD 03-A-1038-P3
	PM	0.1 gr/dscf	LCPH ATI 5927 / PTO 5586
	PM/PM ₁₀	0.043 lb/hr ⁽¹⁾ ; 1.02 tpy ^(2,11)	DNR PSD P03-A-1039-P3
1.2	VOC	200 ppmv ⁽⁶⁾ ; 151 lb/batch ⁽⁷⁾ ; 225 tpy ^(2,8)	LCPH ATI 5928 / PTO 5587
1.3			DNR PSD 03-A-1040-P3
1.4	SHAP	47.35 tpy ^(2,9)	LCPH ATI 5929 / PTO 5588
1.5	THAP	47.35 tpy ^(2,10)	DNR PSD 03-A-1041-P3
1.6			LCPH ATI 5930 / PTO 5589
1.7			DNR PSD 03-A-1042-P3
1.8			LCPH ATI 5931 / PTO 5590
			DNR PSD 03-A-1043-P3
			LCPH ATI 5932 / PTO 5591
			DNR PSD 03-A-1044-P3
	LCPH ATI 5933 / PTO 5592		
	DNR PSD 08-A-281-P2		
	LCPH ATI 5470 / PTO 6278		

⁽¹⁾ Standard is expressed as the average of three (3) runs.

⁽²⁾ Standard is a 12-month rolling total.

⁽³⁾ Limit is for all trade fermentations in EU 01.1-01.8 combined.

⁽⁴⁾ The emission limit is a six (6) minute average.

⁽⁵⁾ An exceedance of the indicator opacity of 'No Visible Emissions' will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

⁽⁶⁾ Measured as propane averaged over the batch cycle. At least 98% of all batches in each rolling 12-month period must meet the limit that applies to the fermentation type. This limit does not apply to specialty yeast.

⁽⁷⁾ Measured as total VOCs. Limit is a 30-day rolling average. VOC emissions from specialty yeast batches are not included in the 30-day average.

⁽⁸⁾ Limit is for all pure culture, stock, first generation and trade fermentations, including specialty yeast, produced in EUs 01.1-01.8, 02.1, 03.1, and nutritional yeast dried in EUs 07.1 and 07.2.

⁽⁹⁾ Acetaldehyde or other HAPs. This limit is an aggregate limit for all pure culture, stock, first generation, and trade fermentations including specialty yeast, produced in EUs 01.1-01.8, 02.1, 03.1, and nutritional yeast dried in EUs 07.1 and 07.2.

⁽¹⁰⁾ Total HAPs are assumed to be 21% of VOC emissions. This limit is an aggregate limit for all pure culture, stock, first generation, and trade fermentations including specialty yeast, produced in EUs 01.1-01.8, 02.1, 03.1, and nutritional yeast dried in EUs 07.1 and 07.2.

⁽¹¹⁾ Limit is for all first generation fermentations in EU 01.1-01.8 combined.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Federal Standards

- A. National Emission Standards for Hazardous Air Pollutants (NESHAP):
The following subparts apply to the emission unit(s) in this permit:

EU ID	Subpart	Title	Type	Local Reference (LCO Sec.)	Federal Reference (40 CFR)
1.1, 1.2, 1.3, 1.4, 1.5, 1.6, 1.7, 1.8	A	General Conditions	--	10-62(d)(1)	§63.1 – §63.15
	CCCC	National Emission Standards for Hazardous Air Pollutants: Manufacturing of Nutritional Yeast	Trade and First Generation	10-62(d)(81)	§63.2130 – §63.2192

Authority for Requirement: DNR PSD 03-A-1038-P3; LCPH ATI 5927 / PTO 5586
 DNR PSD 03-A-1039-P3; LCPH ATI 5928 / PTO 5587
 DNR PSD 03-A-1040-P3; LCPH ATI 5929 / PTO 5588
 DNR PSD 03-A-1041-P3; LCPH ATI 5930 / PTO 5589
 DNR PSD 03-A-1042-P3; LCPH ATI 5931 / PTO 5590
 DNR PSD 03-A-1043-P3; LCPH ATI 5932 / PTO 5591
 DNR PSD 03-A-1044-P3; LCPH ATI 5933 / PTO 5592
 DNR PSD 08-A-281-P2; LCPH ATI 5470 / PTO 6278

Operating Limits

- A. The maximum number of yeast batches produced in all the trade fermentations in EUs 01.1-01.8 is limited to 2964 batches per 12-month rolling period.
- B. The maximum number of yeast batches produced in all the first generation fermentations in EUs 01.1-01.8 is limited to 390 batches per 12-month rolling period.
- C. The facility shall develop and implement a written malfunction plan. It will be as specified in 40 CFR §63.6(e)(3), except that the requirements for startup, shutdown and maintenance plans, records and reports apply only to malfunctions. A period of malfunction is expressed in whole batches and not in portions of batches.

Authority for Requirement: DNR PSD 03-A-1038-P3; LCPH ATI 5927 / PTO 5586
 DNR PSD 03-A-1039-P3; LCPH ATI 5928 / PTO 5587
 DNR PSD 03-A-1040-P3; LCPH ATI 5929 / PTO 5588
 DNR PSD 03-A-1041-P3; LCPH ATI 5930 / PTO 5589
 DNR PSD 03-A-1042-P3; LCPH ATI 5931 / PTO 5590
 DNR PSD 03-A-1043-P3; LCPH ATI 5932 / PTO 5591
 DNR PSD 03-A-1044-P3; LCPH ATI 5933 / PTO 5592
 DNR PSD 08-A-281-P2; LCPH ATI 5470 / PTO 6278

Operating Condition Monitoring & Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Linn County Air Quality Division and other federal or state air pollution regulatory agencies and their authorized representatives. Records shall be legible and maintained in an orderly manner.

- A. VOC emissions must be monitored according to 40 CFR §63.2170.
- B. The operator must maintain records according to 40 CFR §63.2182. These include copies of notifications, records related to malfunctions and records of performance tests.
- C. For each CEM, records must be kept according to 40 CFR §63.2182 (b)(1) through (9).
- D. The records required in Table 4 of NESHAP CCCC must be kept to show continuous compliance with each applicable emission limit.
- E. For each fermentation batch, records must be kept identifying a unique batch identification number, the fermentation stage and a unique CEM identification number.
- F. Continuous compliance with the emission limits in Table 1 of NESHAP CCCC must be demonstrated according to the methods in Table 4 of this subpart and 40 CFR §63.2171. The average VOC concentration in the exhaust for at least 98% of the batches in the previous 12-month period must not exceed the emission limit.
- G. An airflow monitor must be installed and calibrated to monitor the exhaust flow rate. This data along with the VOC concentration data from the CEM shall be used to calculate the VOC emissions in pounds per batch.
- H. For times CEM data is not available for a portion of a batch, total VOC emissions from a batch shall be determined by adding the pounds of VOC calculated from available CEM data to the pounds of VOC calculated using the brew alcohol calculation method.

- I. Record the number of yeast batches produced in EUs 01.1-01.8. Calculate and record monthly and 12-month rolling totals for trade batches and first generation batches in EUs 01.1-01.8.
- J. Calculate and record the total amount of VOC emissions from all trade, first generation, stock and pure culture fermentations from EUs 01.1-01.8, 02.1, and 03.1, and nutritional yeast dried from EUs 07.1 and 07.2 on a 12-month rolling total basis.
- K. Calculate and record the total amount of single and combined HAP emissions from all trade, first generation, stock and pure culture fermentations from EUs 01.1-01.8, 02.1, and 03.1, and nutritional yeast dried from EUs 07.1 and 07.2 on a 12-month rolling total basis.
- L. The owner or operator shall monitor and record 'no visible emissions' observations on a weekly basis. An exceedance of 'no visible emissions' will require the owner/operator to promptly investigate the emission unit, make corrections to operations or equipment associated with the exceedance, and record the corrective action taken.

Authority for Requirement: DNR PSD 03-A-1038-P3; LCPH ATI 5927 / PTO 5586
 DNR PSD 03-A-1039-P3; LCPH ATI 5928 / PTO 5587
 DNR PSD 03-A-1040-P3; LCPH ATI 5929 / PTO 5588
 DNR PSD 03-A-1041-P3; LCPH ATI 5930 / PTO 5589
 DNR PSD 03-A-1042-P3; LCPH ATI 5931 / PTO 5590
 DNR PSD 03-A-1043-P3; LCPH ATI 5932 / PTO 5591
 DNR PSD 03-A-1044-P3; LCPH ATI 5933 / PTO 5592
 DNR PSD 08-A-281-P2; LCPH ATI 5470 / PTO 6278

Emission Point Characteristics

These emission points shall conform to the specifications listed below.

EP	Stack Height (feet, above ground)	Discharge Style	Stack Opening (inches, dia.)	Temp (°F)	Flowrate (acfm)	Authority for Requirement
1.1	124.7	V	39	90-100	13,000 – 18,500	DNR PSD 03-A-1038-P3 LCPH ATI 5927 / PTO 5586
1.2	124.7	V	39	90-100	13,000 – 18,500	DNR PSD 03-A-1039-P3 LCPH ATI 5928 / PTO 5587
1.3	124.7	V	39	90-100	13,000 – 18,500	DNR PSD 03-A-1040-P3 LCPH ATI 5929 / PTO 5588
1.4	124.7	V	39	90-100	13,000 – 18,500	DNR PSD 03-A-1041-P3 LCPH ATI 5930 / PTO 5589
1.5	124.7	V	39	90-100	13,000 – 18,500	DNR PSD 03-A-1042-P3 LCPH ATI 5931 / PTO 5590
1.6	124.7	V	39	90-100	13,000 – 18,500	DNR PSD 03-A-1043-P3 LCPH ATI 5932 / PTO 5591
1.7	124.7	V	39	90-100	13,000 – 18,500	DNR PSD 03-A-1044-P3 LCPH ATI 5933 / PTO 5592
1.8	125.9	V	39	90-100	13,000 – 18,500	DNR PSD 08-A-281-P2 LCPH ATI 5470 / PTO 6278

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

Continuous Emission Monitoring

Continuous emission monitoring is required for VOC emissions by this permit. The CEM must be installed operated and maintained according to the applicable Performance Specification (PS) of 40 CFR part 60, appendix B. The operator must conduct a performance evaluation of each CEM according to the requirements in 40 CFR part §63.8, according to the applicable Performance Specification of 40 CFR part 60, appendix B and according to 40 CFR

§63.2163 paragraphs (b)(1) through (4). The operation, calibration and maintenance of the CEM must follow the applicable requirements of 40 CFR §63.2163.

Authority for Requirement: DNR PSD 03-A-1038-P3; LCPH ATI 5927 / PTO 5586
 DNR PSD 03-A-1039-P3; LCPH ATI 5928 / PTO 5587
 DNR PSD 03-A-1040-P3; LCPH ATI 5929 / PTO 5588
 DNR PSD 03-A-1041-P3; LCPH ATI 5930 / PTO 5589
 DNR PSD 03-A-1042-P3; LCPH ATI 5931 / PTO 5590
 DNR PSD 03-A-1043-P3; LCPH ATI 5932 / PTO 5591
 DNR PSD 03-A-1044-P3; LCPH ATI 5933 / PTO 5592
 DNR PSD 08-A-281-P2; LCPH ATI 5470 / PTO 6278

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Compliance Testing

CEMS cylinder gas audit (CGA) and relative accuracy test audit (RATA) requirements within 40 CFR Appendix B (performance specifications) and Appendix F (Quality Assurance Procedures) as specified in 40 CFR §63.2163 satisfy the compliance testing requirements. No additional testing is required.

Authority for Requirement – 567 IAC 22.108(3)

Continuous Emissions Monitoring

Pollutant:	VOC
Continuous Emissions Monitor ID:	ME01.1, ME01.2, ME01.3, ME01.4, ME01.5, ME01.6, ME01.7, ME01.8
Operational Specifications:	40 CFR 60
Ongoing System Calibration/Quality Assurance:	40 CFR 60
Reporting & Recordkeeping:	40 CFR 60
Authority for Requirement:	DNR PSD 03-A-1038-P3; LCPH ATI 5927 / PTO 5586 DNR PSD 03-A-1039-P3; LCPH ATI 5928 / PTO 5587 DNR PSD 03-A-1040-P3; LCPH ATI 5929 / PTO 5588 DNR PSD 03-A-1041-P3; LCPH ATI 5930 / PTO 5589 DNR PSD 03-A-1042-P3; LCPH ATI 5931 / PTO 5590 DNR PSD 03-A-1043-P3; LCPH ATI 5932 / PTO 5591 DNR PSD 03-A-1044-P3; LCPH ATI 5933 / PTO 5592 DNR PSD 08-A-281-P2; LCPH ATI 5470 / PTO 6278 40 CFR 63 Subpart CCCC 567 IAC 23.1(4)"cc" LCO Sec. 10-62(b)(81)

The owner of this equipment or the owner's authorized agent shall provide written notice to the Director, not less than 30 days before a required stack test or performance evaluation of a continuous emission monitor. Results of the test shall be submitted in writing to the Director in the form of a comprehensive report within 6 weeks of the completion of the testing. 567 IAC 25.1(7)

Opacity Monitoring

See Appendix D, Opacity Monitoring Summary.

Authority for Requirement: 567 IAC 22.108(14)

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 1.10

Associated Equipment Table 1

EP	EU	EU Description	Raw Material	Rated Capacity	CE ID	CE Description
1.10	1.10	Trade Fermenter 10	Yeast Culture, Carbon Substrate	5,990 lbs/hr	--	Process Control

Associated Equipment Table 2

EP	EU	CEM
1.10	1.10	ME01.10 – VOC

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

General Emission Limits

EP	Pollutant	Emission Limit(s)	Authority for Requirement	Authority for Requirement
1.10	Opacity	20% ⁽¹⁾	LCO Sec.10-60(a)	LCPH ATI 6822 / PTO 6755-R1
	PM	0.1 gr/dscf	567 IAC 23.3(2)"a" LCO Sec. 10-62(a)(1)	

Emission Limits (When used as a Trade Fermenter)

EP	Pollutant	Emission Limit(s)	Authority for Requirement
1.10	PM/PM ₁₀	0.043 lb/hr	LCPH ATI 6822 / PTO 6755-R1
	VOC	34.80 tpy ⁽²⁾ ; 100 ppm _v ⁽³⁾	
	SHAP	7.31 tpy ⁽⁴⁾	
	THAP	7.31 tpy ⁽⁵⁾	

Emission Limits (When used as a First Generation Fermenter)

EP	Pollutant	Emission Limit(s)	Authority for Requirement
1.10	PM/PM ₁₀	0.043 lb/hr	LCPH ATI 6822 / PTO 6755-R1
	VOC	34.80 tpy ⁽²⁾ ; 200 ppm _v ⁽³⁾	
	SHAP	7.31 tpy ⁽⁴⁾	
	THAP	7.31 tpy ⁽⁵⁾	

⁽¹⁾ The observation of **visible emissions** of air contaminants as defined in LCCO 10.2 will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the visible emissions. If visible emissions continue after the corrections, Linn County may require additional proof to demonstrate compliance (e.g., stack testing).

⁽²⁾ Limit is for all pure culture, stock, first generation and trade fermentations, including specialty yeast, produced in EU 1.10.

⁽³⁾ Measured as propane averaged over the batch cycle. At least 98% of all batches in each rolling 12-month period must meet the limit that applies to the fermentation type. This limit does not apply to specialty yeast.

⁽⁴⁾ Acetaldehyde or other HAPs. This limit is an aggregate limit for all pure culture, stock, first generation, and trade fermentations including specialty yeast, produced in EU 1.10.

⁽⁵⁾ Total HAPs are assumed to be 21% of VOC emissions. This limit is an aggregate limit for all pure culture, stock, first generation, and trade fermentations including specialty yeast, produced in EU 1.10.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Federal Standards

A. National Emission Standards for Hazardous Air Pollutants (NESHAP):

The following subparts apply to the emission unit(s) in this permit:

EU ID	Subpart	Title	Type	Local Reference (LCO Sec.)	Federal Reference (40 CFR)
1.10	A	General Conditions	--	10-62(d)(1)	§63.1 – §63.15
	CCCC	National Emission Standards for Hazardous Air Pollutants: Manufacturing of Nutritional Yeast	Trade and First Generation	10-62(d)(81)	§63.2130 – §63.2192

Authority for Requirement: LCPH ATI 6822 / PTO 6755-R1

Operating Requirements with Associated Monitoring and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:

- A. The maximum number of trade fermentation yeast batches produced in EU 1.10 is limited to 420 batches per 12-month rolling period. Calculate and record and 12-month rolling totals of trade batches in EU 1.10.
- B. The maximum number of first generation yeast batches produced in EU 1.10 is limited to 60 batches per 12-month rolling period. Calculate and record monthly and 12-month rolling totals of first generation batches in EU 1.10.
- C. The owner or operator shall comply with the general compliance requirements of NESHAP Subpart CCCC per 40 CFR §63.2150.
- D. The owner or operator shall comply with the testing and initial compliance requirements of NESHAP Subpart CCCC per 40 CFR §63.2160, §63.2163, and §63.2165.
- E. The owner or operator shall comply with the continuous compliance requirements of NESHAP Subpart CCCC per 40 CFR §63.2170 and §63.2171.
- F. The owner or operator shall comply with the notification, reports, and records requirements of NESHAP Subpart CCCC per 40 CFR §63.2180 through §63.2183.
- G. The owner or operator shall comply with the applicable general provisions of NESHAP Subpart A as required per 40 CFR §63.2190.
- H. An airflow monitor must be installed and calibrated to monitor the exhaust flow rate. This data, along with the VOC concentration data from the CEMS, shall be used to calculate the VOC emissions in pounds per batch.
- I. If CEMS data are not available for some portion of a batch, total VOC emissions from a batch shall be determined by adding the pounds of VOC calculated from available CEMS data to the pounds of VOC calculated using the brew alcohol calculation method.
- J. The owner or operator shall calculate and record the total amount of single and combined HAP emissions from all trade fermentations and all first generation fermentations in EU 1.10 on a 12-month rolling total basis.
- K. The owner or operator shall monitor and record 'no visible emissions' observations on a weekly basis. An exceedance of 'no visible emissions' will require the owner/operator to promptly investigate the emission unit, make corrections to operations or equipment associated with the exceedance, and record the corrective action taken.

Authority for Requirement: LCPH ATI 6822 / PTO 6755-R1

Emission Point Characteristics

This emission point shall conform to the specifications listed below.

EP	Stack Height (feet, above ground)	Discharge Style	Stack Opening (inches, dia.)	Temp (°F)	Flowrate (acfm)	Authority for Requirement
1.10	124.7	V	39	90-100	13,000 – 18,500	LCPH ATI 6822 / PTO 6755-R1

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

Continuous Emission Monitoring Systems (CEMS)

The following continuous monitoring requirements apply to this emission point (EP 1.10) and its associated emission unit (EU 1.10).

- A. *VOC*: The owner or operator shall demonstrate compliance with the volatile organic compounds (VOC) limits of this permit through the use of a continuous emission monitoring system (CEMS). The owner or operator shall install, calibrate, maintain, operate, and record the output of a CEMS for measuring the VOC of emissions discharged to the atmosphere from EU 1.10. Each CEMS must be installed, operated, and maintained according to 40 CFR §63.2163.

Authority for Requirement: LCPH ATI 6822 / PTO 6755-R1

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Compliance Testing

CEMS cylinder gas audit (CGA) and relative accuracy test audit (RATA) requirements within 40 CFR Appendix B (performance specifications) and Appendix F (Quality Assurance Procedures) as specified in 40 CFR §63.2163 satisfy the compliance testing requirements. No additional testing is required.

Authority for Requirement – 567 IAC 22.108(3)

Continuous Emissions Monitoring

Pollutant:	VOC
Continuous Emissions Monitor ID:	ME1.10
Operational Specifications:	40 CFR 60
Ongoing System Calibration/Quality Assurance:	40 CFR 60
Reporting & Recordkeeping:	40 CFR 60
Authority for Requirement:	LCPH ATI 6822 / PTO 6755 40 CFR 63 Subpart CCCC 567 IAC 23.1(4)"cc" LCO Sec. 10-62(b)(81)

The owner of this equipment or the owner's authorized agent shall provide written notice to the Director, not less than 30 days before a required stack test or performance evaluation of a continuous emission monitor. Results of the test shall be submitted in writing to the Director in the form of a comprehensive report within 6 weeks of the completion of the testing. 567 IAC 25.1(7)

Opacity Monitoring

See Appendix D, Opacity Monitoring Summary.

Authority for Requirement: 567 IAC 22.108(14)

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 2.1

Associated Equipment Table 1

EP	EU	EU Description	Raw Material	Rated Capacity	CE ID	CE Description
2.1	2.1	Stock Fermenter 1	Yeast Culture, Carbon Substrate	2,000 lbs/hr	--	Process Control

Associated Equipment Table 2

EP	EU	CEM
2.1	2.1	ME02.1 – VOC

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Emission Limits

EP	Pollutant	Emission Limit(s)	Authority for Requirement	Authority for Requirement
2.1	Opacity	40%	567 IAC 23.2(2)"d"	DNR PSD 03-A-1048-P3 LCPH ATI 5934 / PTO 5593
		20%	LCO Sec.10-60(a)	LCPH ATI 5934 / PTO 5593
	PM	0.1 gr/dscf	567 IAC 23.3(2)"a" LCO Sec. 10-62(a)(1)	DNR PSD 03-A-1048-P3 LCPH ATI 5934 / PTO 5593
	PM/PM ₁₀	0.13 lb/hr ⁽¹⁾ ; 0.50 tpy ^(2,3)		
	VOC	300 ppmv ⁽⁶⁾ ; 644 lb/batch ⁽⁷⁾ ; 225 tpy ^(2,8)		
	SHAP	47.35 tpy ^(2,9)		
THAP	47.35 tpy ^(2,10)			

¹ Standard is expressed as the average of three (3) runs.

² Standard is a 12-month rolling total.

³ Limit is for all stock fermentations in EU02.1.

⁴ The emission limit is a six (6) minute average.

⁵ An exceedance of the indicator opacity of 'No Visible Emissions' will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

⁶ Measured as propane averaged over the batch cycle. At least 98% of all batches in each rolling 12-month period must meet the limit that applies to the fermentation type. This limit does not apply to specialty yeast.

⁷ Measured as total VOCs. Limit is a 30-day rolling average. VOC emissions from specialty yeast batches are not included in the 30-day average.

⁸ Limit is for all pure culture, stock, first generation and trade fermentations, including specialty yeast, produced in EUs 01.1-01.8, 02.1, 03.1, and nutritional yeast dried in EUs 07.1 and 07.2.

⁹ Acetaldehyde or other HAPs. This limit is an aggregate limit for all pure culture, stock, first generation, and trade fermentations including specialty yeast, produced in EUs 01.1-01.8, 02.1, 03.1, and nutritional yeast dried in EUs 07.1 and 07.2.

¹⁰ Total HAPs are assumed to be 21% of VOC emissions. This limit is an aggregate limit for all pure culture, stock, first generation, and trade fermentations including specialty yeast, produced in EUs 01.1-01.8, 02.1, 03.1, and nutritional yeast dried in EUs 07.1 and 07.2.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Federal Standards

A. National Emission Standards for Hazardous Air Pollutants (NESHAP):

The following subparts apply to the emission unit(s) in this permit:

EU ID	Subpart	Title	Type	Local Reference (LCO Sec.)	Federal Reference (40 CFR)
2.1	A	General Conditions	--	10-62(d)(1)	§63.1 – §63.15
	CCCC	National Emission Standards for Hazardous Air Pollutants: Manufacturing of Nutritional Yeast	Trade and First Generation	10-62(d)(81)	§63.2130 – §63.2192

Authority for Requirement: DNR PSD 03-A-1048-P3; LCPH ATI 5934 / PTO 5593

Operating Limits:

- A. The maximum number of yeast batches produced in all stock fermentations in EU 02.1 is limited to 364 batches per 12-month rolling period.
- B. The facility shall develop and implement a written malfunction plan. It will be as specified in 40 CFR §63.6(e)(3), except that the requirements for startup, shutdown and maintenance plans, records and reports apply only to malfunctions. A period of malfunction is expressed in whole batches and not in portions of batches.

Authority for Requirement: PSD 03-A-1048-P3; LCPH ATI 5934 / PTO 5593

Operating Condition Monitoring & Recordkeeping:

All records as required by this permit shall be kept on site for a minimum of five (5) years and shall be available for inspection by the Linn County Air Quality Division and other federal or state air pollution regulatory agencies and their authorized representatives.

- A. VOC emissions must be monitored according to 40 CFR §63.2170.
- B. The operator must maintain records according to 40 CFR §63.2182. These include copies of notifications, records related to malfunctions and records of performance tests.
- C. For each CEM, records must be kept according to 40 CFR §63.2182 (b)(1) through (9).
- D. The records required in Table 4 of NESHAP CCCC must be kept to show continuous compliance with each applicable emission limit.
- E. For each fermentation batch, records must be kept identifying a unique batch identification number, the fermentation stage and a unique CEM identification number.
- F. Continuous compliance with the emission limits in Table 1 of NESHAP CCCC must be demonstrated according to the methods in Table 4 of this subpart and 40 CFR §63.2171. The average VOC concentration in the exhaust for at least 98% of the batches in the previous 12-month period must not exceed the emission limit.
- G. An airflow monitor must be installed and calibrated to monitor the exhaust flow rate. This data along with the VOC concentration data from the CEM shall be used to calculate the VOC emissions in pounds per batch.
- H. For times CEM data is not available for a portion of a batch, total VOC emissions from a batch shall be determined by adding the pounds of VOC calculated from available CEM data to the pounds of VOC calculated using the brew alcohol calculation method.
- I. Record the number of yeast batches produced in EUs 01.1-01.8 and 02.1. Calculate and record monthly and 12-month rolling totals for stock fermentation batches in EU 02.1.
- J. Calculate and record the total amount of VOC emissions from all trade, first generation, stock and pure culture fermentations from EUs 01.1-01.8, 02.1, and 03.1, and nutritional yeast dried from EUs 07.1 and 07.2 on a 12-month rolling total basis.
- K. Calculate and record the total amount of single and combined HAP emissions from all trade, first generation, stock and pure culture fermentations from EUs 01.1-01.8, 02.1, and 03.1, and nutritional yeast dried from EUs 07.1 and 07.2 on a 12-month rolling total basis.
- L. The owner or operator shall monitor and record 'no visible emissions' observations on a weekly basis. An exceedance of 'no visible emissions' will require the owner/operator to promptly investigate the emission unit, make corrections to operations or equipment associated with the exceedance, and record the corrective action taken.

Authority for Requirement: DNR PSD 03-A-1048-P3; LCPH ATI 5934 / PTO 5593

Emission Point Characteristics

This emission point shall conform to the specifications listed below.

EP	Stack Height (feet, above ground)	Discharge Style	Stack Opening (inches, dia.)	Temp (°F)	Flowrate (acfm)	Authority for Requirement
2.1	124.7	V	20	90-100	2,000 – 14,000	DNR PSD Permit 03-A-1048-P3 LCPH ATI 5934 / PTO 5593

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Compliance Testing

CEMS cylinder gas audit (CGA) and relative accuracy test audit (RATA) requirements within 40 CFR Appendix B (performance specifications) and Appendix F (Quality Assurance Procedures) as specified in 40 CFR §63.2163 satisfy the compliance testing requirements. No additional testing is required.

Authority for Requirement – 567 IAC 22.108(3)

Continuous Emissions Monitoring

Pollutant:	VOC
Continuous Emissions Monitor ID:	ME02.1
Operational Specifications:	40 CFR 60
Ongoing System Calibration/Quality Assurance:	40 CFR 60
Reporting & Recordkeeping:	40 CFR 60
Authority for Requirement:	DNR PSD Permit 03-A-1048-P3; LCPH ATI 5934 / PTO 5593 40 CFR 63 Subpart CCCC 567 IAC 23.1(4)"cc" LCO Sec. 10-62(b)(81)

The owner of this equipment or the owner's authorized agent shall provide written notice to the Director, not less than 30 days before a required stack test or performance evaluation of a continuous emission monitor. Results of the test shall be submitted in writing to the Director in the form of a comprehensive report within 6 weeks of the completion of the testing. 567 IAC 25.1(7)

Opacity Monitoring

See Appendix D, Opacity Monitoring Summary.

Authority for Requirement: 567 IAC 22.108(14)

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 3.1

Associated Equipment

EP	EU	EU Description	Raw Material	Rated Capacity	CE ID	CE Description
3.1	3.1	Pure Culture Fermenter 1	Yeast Culture, Carbon Substrate	22 lbs/hr	--	Process Control

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Emission Limits

EP	Pollutant	Emission Limit(s)	Authority for Requirement	Authority for Requirement
3.1	Opacity	40%	567 IAC 23.2(2)"d"	DNR PSD 03-A-1050-P3 LCPH ATI 5935 / PTO 5594
		20%	LCO Sec.10-60(a)	
	PM	0.1 gr/dscf	567 IAC 23.3(2)"a" LCO Sec. 10-62(a)(1)	DNR PSD 03-A-1050-P3 LCPH ATI 5935 / PTO 5594
	PM/PM ₁₀	0.013 lb/hr ⁽¹⁾ ; 0.03 tpy ^(2,3)		
	VOC	0.10 lb/hr ⁽¹⁾ ; 225 tpy ⁽⁶⁾		
	SHAP	47.35 tpy ^(2,7)		
THAP	47.35 tpy ^(2,8)			

⁽¹⁾ Standard is expressed as the average of three (3) runs.

⁽²⁾ Standard is a 12-month rolling total.

⁽³⁾ Limit is for all pure culture fermentations in EU 03.1 combined.

⁽⁴⁾ The emission limit is a six (6) minute average.

⁽⁵⁾ An exceedance of the indicator opacity of 'No Visible Emissions' will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

⁽⁶⁾ Limit is for all pure culture, stock, first generation and trade fermentations, including specialty yeast, produced in EUs 01.1-01.8, 02.1, 03.1, and nutritional yeast dried in EUs 07.1 and 07.2.

⁽⁷⁾ Acetaldehyde or other HAPs. This limit is an aggregate limit for all pure culture, stock, first generation, and trade fermentations including specialty yeast, produced in EUs 01.1-01.8, 02.1, 03.1, and nutritional yeast dried in EUs 07.1 and 07.2.

⁽⁸⁾ Total HAPs are assumed to be 21% of VOC emissions. This limit is an aggregate limit for all pure culture, stock, first generation, and trade fermentations including specialty yeast, produced in EUs 01.1-01.8, 02.1, 03.1, and nutritional yeast dried in EUs 07.1 and 07.2.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Federal Standards

A. National Emission Standards for Hazardous Air Pollutants (NESHAP):

The following subparts apply to the emission unit(s) in this permit:

EU ID	Subpart	Title	Type	Local Reference (LCO Sec.)	Federal Reference (40 CFR)
3.1	A	General Conditions	--	10-62(d)(1)	§63.1 – §63.15
	CCCC	National Emission Standards for Hazardous Air Pollutants: Manufacturing of Nutritional Yeast	Trade and First Generation	10-62(d)(81)	§63.2130 – §63.2192

Authority for Requirement: DNR PSD 03-A-1050-P3; LCPH ATI 5935 / PTO 5594

Operating Condition Monitoring & Recordkeeping:

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Linn County Air Quality Division and other federal or state air pollution regulatory agencies and their authorized representatives. Records shall be legible and maintained in an orderly manner.

- A. Calculate and record monthly and 12-month rolling totals of the number of pure culture fermentations.
- B. Calculate and record the total amount of VOC emissions from all trade, first generation, stock and pure culture fermentations from EUs 01.1-01.8, 02.1, and 03.1, and nutritional yeast dried from EUs 07.1 and 07.2 on a 12-month rolling total basis.
- C. Calculate and record the total amount of single and combined HAP emissions from all trade, first generation, stock and pure culture fermentations from EUs 01.1-01.8, 02.1, and 03.1, and nutritional yeast dried from EUs 07.1 and 07.2 on a 12-month rolling total basis.

Authority for Requirement: DNR PSD 03-A-1050-P3; LCPH ATI 5935 / PTO 5594

Emission Point Characteristics

This emission point shall conform to the specifications listed below.

EP	Stack Height (feet, above ground)	Discharge Style	Stack Opening (inches, dia.)	Temp (°F)	Flowrate (acfm)	Authority for Requirement
3.1	75	V	8	90-100	107-213	DNR PSD 03-A-1050-P3 LCPH ATI 5935 / PTO 5594

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Opacity Monitoring

See Appendix D, Opacity Monitoring Summary.

Authority for Requirement: 567 IAC 22.108(14)

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 39.10, 39.11, 39.12, 39.13, 39.14

Associated Equipment

EP	EU	EU Description	Raw Material	Rated Capacity	CE ID	CE Description
39.10	39.10	Yeast Plant Cooling Tower Cell #10	Process Cooling Water	161,400 gph	39.10	Drift Eliminator
39.11	39.11	Yeast Plant Cooling Tower Cell #11	Process Cooling Water	161,400 gph	39.11	Drift Eliminator
39.12	39.12	Yeast Plant Cooling Tower Cell #12	Process Cooling Water	161,400 gph	39.12	Drift Eliminator
39.13	39.13	Yeast Plant Cooling Tower Cell #13	Process Cooling Water	161,400 gph	39.13	Drift Eliminator
39.14	39.14	Yeast Plant Cooling Tower Cell #14	Process Cooling Water	161,400 gph	39.14	Drift Eliminator

Applicable Requirements

Emission Limits (lb. /hr, gr. /dscf, lb./MMBtu, % opacity, etc.)

The emissions from these emission points shall not exceed the levels specified below.

Emission Limits

EP	Pollutant	Emission Limit(s)	Authority for Requirement	Authority for Requirement
39.10	Opacity	40% ⁽¹⁾	567 IAC 23.2(2)"d"	DNR PSD 08-A-174P1 LCPH ATI 5446 / PTO 5600
		20%	LCO Sec.10-60(a)	DNR PSD 08-A-175P1 LCPH ATI 5447 / PTO 5601
39.11	PM	0.1 gr/dscf	567 IAC 23.3(2)"a"	DNR PSD 08-A-176P1 LCPH ATI 5448 / PTO 5602
39.12			LCO Sec. 10-62(a)(1)	DNR PSD 08-A-177P1 LCPH ATI 5449 / PTO 6280
39.13	PM/PM ₁₀	0.07 lb/hr; 0.30 tpy		DNR PSD 08-A-178P1 LCPH ATI 5450 / PTO 6283
39.14				

⁽¹⁾ An exceedance of the indicator opacity of 10% will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

Operating limits for this emission unit shall be:

A. The Total Dissolved Solids (TDS) concentration in the cooling water shall not exceed 1950 parts per million by weight (1950 mg/L) for any single sampling event.

B. Chromium based water treatment chemicals shall not be used in this emission unit.

Authority for Requirement: DNR PSD 08-A-174P1; LCPH ATI 5446 / PTO 5600
 DNR PSD 08-A-175P1; LCPH ATI 5447 / PTO 5601
 DNR PSD 08-A-176P1; LCPH ATI 5448 / PTO 5602
 DNR PSD 08-A-177P1; LCPH ATI 5449 / PTO 6280
 DNR PSD 08-A-178P1; LCPH ATI 5450 / PTO 6283

Operating Condition Monitoring and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Linn County Air Quality Division and other federal or state air pollution regulatory agencies and their authorized representatives. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall complete an analysis of the TDS of the water in the cooling tower at least once for each calendar month this emission unit is in operation.
- B. Maintain a safety data sheet of all water treatment chemicals used.
- C. Maintain records of the manufacturer's design guarantee.

Authority for Requirement: DNR PSD 08-A-174P1; LCPH ATI 5446 / PTO 5600
 DNR PSD 08-A-175P1; LCPH ATI 5447 / PTO 5601
 DNR PSD 08-A-176P1; LCPH ATI 5448 / PTO 5602
 DNR PSD 08-A-177P1; LCPH ATI 5449 / PTO 6280
 DNR PSD 08-A-178P1; LCPH ATI 5450 / PTO 6283

Emission Point Characteristics

These emission points shall conform to the specifications listed below.

EP	Stack Height (feet, above ground)	Discharge Style	Stack Opening (inches, dia.)	Temp (°F)	Flowrate (acfm)	Authority for Requirement
39.10	36.79	V	144	92	293,780	DNR PSD 08-A-174P1 LCPH ATI 5446 / PTO 5600
39.11	36.79	V	144	92	293,780	DNR PSD 08-A-175P1 LCPH ATI 5447 / PTO 5601
39.12	36.79	V	144	92	293,780	DNR PSD 08-A-176P1 LCPH ATI 5448 / PTO 5602
39.13	36.79	V	144	92	293,780	DNR PSD 08-A-177P1 LCPH ATI 5449 / PTO 6280
39.14	36.79	V	144	92	293,780	DNR PSD 08-A-178P1 LCPH ATI 5450 / PTO 6283

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Opacity Monitoring

See Appendix D, Opacity Monitoring Summary.
 Authority for Requirement: 567 IAC 22.108(14)

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 39.15, 39.16

Associated Equipment

EP	EU	EU Description	Raw Material	Rated Capacity	CE ID	CE Description
39.15	39.15	Yeast Plant Cooling Tower Cell #15	Process Cooling Water	205,714 gph	39.15	Drift Eliminator
39.16	39.16	Yeast Plant Cooling Tower Cell #16	Process Cooling Water	205,714 gph	39.16	Drift Eliminator

Applicable Requirements

Emission Limits (lb. /hr, gr. /dscf, lb./MMBtu, % opacity, etc.)

The emissions from these emission points shall not exceed the levels specified below.

Emission Limits

EP	Pollutant	Emission Limit(s)	Authority for Requirement	Authority for Requirement
39.15	Opacity	20%	LCO Sec.10-60(a)	LCPHATI 6823 / PTO 6910 LCPH ATI 6824 / PTO 6911
39.16	PM	0.1 gr/dscf	567 IAC 23.3(2)"a" LCO Sec. 10-62(a)(1)	
	PM/PM ₁₀	0.07 lb/hr; 0.30 tpy		

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

Operating limits for this emission unit shall be:

- A. The Total Dissolved Solids (TDS) concentration in the cooling water shall not exceed 1,950 parts per million by weight (1,950 mg/L) for any single sampling event.
- B. Chromium based water treatment chemicals shall not be used in this emission unit.

Authority for Requirement: LCPH ATI 6823 / PTO 6910; LCPH ATI 6824 / PTO 6911

Operating Condition Monitoring and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Linn County Air Quality Division and other federal or state air pollution regulatory agencies and their authorized representatives. Records shall be legible and maintained in an orderly manner. These records shall show the following:

- A. The owner or operator shall complete an analysis of the TDS of the water in the cooling tower at least once for each calendar month this emission unit is in operation.
- B. The owner or operator shall maintain a safety data sheet (SDS) of all water treatment chemicals used.
- C. The owner or operator shall maintain records of the manufacturer's design guarantee.

Authority for Requirement: LCPH ATI 6823 / PTO 6910; LCPH ATI 6824 / PTO 6911

Emission Point Characteristics

These emission points shall conform to the specifications listed below.

EP	Stack Height (feet, above ground)	Discharge Style	Stack Opening (inches, dia.)	Temp (°F)	Flowrate (acfm)	Authority for Requirement
39.15	34.45	V	144	92	304,400	LCPH ATI 6823 / PTO 6910
39.16	34.45	V	144	92	304,400	LCPH ATI 6824 / PTO 6911

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Opacity Monitoring

See Appendix D, Opacity Monitoring Summary.

Authority for Requirement: 567 IAC 22.108(14)

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 50

Associated Equipment

EP	EU	EU Description	Raw Material	Rated Capacity	CE ID	CE Description
50	AS.1	Plant Haul Roads	Silt	N/A	--	--

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Emission Limits

EP	Pollutant	Emission Limit(s)	Authority for Requirement	Authority for Requirement
50	Opacity	40% ⁽¹⁾	567 IAC 23.2(2)"d"	DNR PSD 08-A-180P1 LCPH ATI 5498 / PTO 6238
	PM	0.1 gr/dscf	567 IAC 23.3(2)"a" LCO Sec. 10-62(a)(1)	
		0.10 tpy		

⁽¹⁾ An exceedance of the indicator opacity of 10% will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. The haul roads shall be paved prior to facility start up.
- B. Truck traffic on the haul road shall not exceed 20 mph. The speed limit shall be posted on the haul road.
- C. Any spills on the road shall be cleaned up immediately.
- D. Truck traffic emissions on the haul road shall be controlled by sweeping or vacuuming once per day or as often as weather permits.

Authority for Requirement: DNR PSD 08-A-180P1; LCPH ATI 5498 / PTO 6238

Operating Condition Monitoring

All records as required by this permit shall be kept on site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. Record the frequency of sweeping and/or vacuuming performed on the haul roads. If the roads are not swept and/or vacuumed due to weather, a written record must be kept on site outlining the conditions.

Authority for Requirement: DNR PSD 08-A-180P1; LCPH ATI 5498 / PTO 6238

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 43.3, 43.4

Associated Equipment

EP	EU	EU Description	Raw Material	Rated Capacity	CE ID	CE Description
43.3	43.3	Vitamin Prep		--	43.3	Cartridge Filters
43.4	43.4	Packaging		2,000 lbs/hr	43.4	Cartridge Filters

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from these emission points shall not exceed the levels specified below.

Emission Limits

EP	Pollutant	Emission Limit(s)	Authority for Requirement	Authority for Requirement
43.3	Opacity	20%	LCO Sec.10-60(a)	LCPH ATI 6928 / PTO 6912
43.4	PM	0.1 gr/dscf	567 IAC 23.3(2)"a" LCO Sec. 10-62(a)(1)	LCPH ATI 6929 / PTO 6913
43.3	PM/PM ₁₀	0.06 lb/hr		LCPH ATI 6928 / PTO 6912
43.4		0.26 lb/hr		LCPH ATI 6929 / PTO 6913

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Requirements with Associated Monitoring and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:

- L. The control equipment shall be maintained according to manufacturer's specifications and good operating practices. The owner or operator shall maintain records of all maintenance completed on the control equipment.
- M. The differential pressure across the control equipment shall be maintained between 0.1" and 8.0" w.c. The owner or operator shall monitor and record the differential pressure across the control equipment on a weekly basis.
- N. The owner or operator shall monitor and record 'no visible emissions' observations on a weekly basis. An exceedance of 'no visible emissions' will require the owner/operator to promptly investigate the emission unit, make corrections to operations or equipment associated with the exceedance, and record the corrective action taken.

Authority for Requirement: LCPH ATI 6928 / PTO 6912; LCPH ATI 6929 / PTO 6913

Emission Point Characteristics

These emission points shall conform to the specifications listed below.

EP	Stack Height (feet, above ground)	Discharge Style	Stack Opening (inches, dia.)	Temp (°F)	Flowrate (acfm)	Authority for Requirement
43.3	27	V	6	100	700	LCPH ATI 6928 / PTO 6912
43.4	17	V	10	100	3,000	LCPH ATI 6929 / PTO 6913

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Opacity Monitoring

See Appendix D, Opacity Monitoring Summary.

Authority for Requirement: 567 IAC 22.108(14)

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 7.1, 7.2

Associated Equipment

EP	EU	EU Description	Raw Material	Rated Capacity	CE ID	CE Description
7.1	7.1	Nutritional Yeast Dryer 1	Trade Fermenter Yeast	675 lbs/hr	7.1	Wet Scrubber
7.2	7.2	Nutritional Yeast Dryer 2	Trade Fermenter Yeast	675 lbs/hr	7.2	Wet Scrubber

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from these emission points shall not exceed the levels specified below.

Emission Limits

EP	Pollutant	Emission Limit(s)	Authority for Requirement	Authority for Requirement
7.1	Opacity	20%	LCO Sec.10-60(a)	LCPH ATI 6608 / PTO 6445-R2 LCPH ATI 6609 / PTO 6446-R2
	PM	0.1 gr/dscf	567 IAC 23.3(2)"a" LCO Sec. 10-62(a)(1)	
7.2		PM ₁₀	0.75 lb/hr; 2.63 tpy	
	VOC	0.375 lb/hr; 1.31 tpy		
	SHAP	225 tpy		
	THAP	47.35 tpy		
	THAP	47.35 tpy		

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Control Device

A wet scrubber shall be installed to control particulate emissions. The control equipment shall be maintained properly and operated at all times the air pollution source is in operation. All appropriate probes, monitors and gauges needed to measure the parameters outlined in "operating condition monitoring and recordkeeping" shall be installed, maintained and operating during the operation of the emission unit and control device at all times.

Authority for Requirement: LCPH ATI 6608 / PTO 6445-R2; LCPH ATI 6609 / PTO 6446-R2

Operating Limits

- A. Each emission unit shall be limited to 7,500 hours per year based on a 12-month rolling total.
- B. The scrubber on these units shall be maintained according to the manufacturer's specifications and good operating practices.
- C. The recirculation water flow to the scrubbers shall be maintained at a minimum of 55 gpm.

Authority for Requirement: LCPH ATI 6608 / PTO 6445-R2; LCPH ATI 6609 / PTO 6446-R2

Operating Condition Monitoring and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:

- A. The owner or operator shall record scrubber water recirculation water flow rate on a weekly basis.
- B. The owner or operator shall install a non-resettable hour meter on the dryer.
- C. The owner or operator shall record the dryer hours of operation monthly and calculate 12-month rolling total for each month.

- D. The owner or operator shall monitor and record 'no visible emissions' observations on a weekly basis. An exceedance of 'no visible emissions' will require the owner/operator to promptly investigate the emission unit, make corrections to operations or equipment associated with the exceedance, and record the corrective action taken.
- E. The owner or operator shall record maintenance and repairs completed on the control equipment.
- F. The owner or operator shall monitor and record monthly and 12-month rolling PM and PM₁₀ emission totals to ensure compliance with the annual emission limits established in "Emission Limits" section. This requirement only applies in the event any source test (three 1-hour runs) results in an average emission rate > 0.70 lb/hr PM and/or > 0.349 lb/hr PM₁₀.
- G. The owner or operator shall calculate and record the total amount of VOC emissions from the facility on a 12-month rolling total basis.
- H. The owner or operator shall calculate and record the total amount of single and combined HAP emissions from the facility on a 12-month rolling total basis.

Authority for Requirement: LCPH ATI 6608 / PTO 6445-R2; LCPH ATI 6609 / PTO 6446-R2

Emission Point Characteristics

These emission points shall conform to the specifications listed below.

EP	Stack Height (feet, above ground)	Discharge Style	Stack Opening (inches, dia.)	Temp (°F)	Flowrate (acfm)	Authority for Requirement
7.1	59.7	V	36	140	9,330	LCPH ATI 6608 / PTO 6445-R2
7.2	59.7	V	36	140	9,330	LCPH ATI 6609 / PTO 6446-R2

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Opacity Monitoring

See Appendix D, Opacity Monitoring Summary.

Authority for Requirement: 567 IAC 22.108(14)

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes ⁽¹⁾ No

⁽¹⁾ See Appendix C, Facility O&M Plans, for the applicable requirements.

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 7.3

Associated Equipment

EP	EU	EU Description	Raw Material	Rated Capacity	CE ID	CE Description
7.3	7.4	Nutritional Yeast Dryer 4	Trade Fermenter Yeast	675 lbs/hr	7.3	Wet Scrubber
	7.5	Nutritional Yeast Dryer 5	Trade Fermenter Yeast	675 lbs/hr		

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Emission Limits

EP	Pollutant	Emission Limit(s)	Authority for Requirement	Authority for Requirement
7.3	Opacity	20%	LCO Sec.10-60(a)	LCPH ATI 7113 / PTO 6849
	PM	0.1 gr/dscf	567 IAC 23.3(2)"a" LCO Sec. 10-62(a)(1)	
		1.4 lb/hr		
	PM ₁₀	0.7 lb/hr		
	VOC	0.77 tpy		

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Requirements with Associated Monitoring and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:

- A. EU 7.4 shall be limited to operating 7,500 hours per year based on a 12-month rolling total.
 - i. The owner or operator shall install a non-resettable hour meter on EU 7.4.
 - ii. The owner or operator shall record the hours of operation monthly and calculate the 12-month rolling total for each month.
- B. EU 7.5 shall be limited to operating 7,500 hours per year based on a 12-month rolling total.
 - i. The owner or operator shall install a non-resettable hour meter on EU 7.5.
 - ii. The owner or operator shall record the hours of operation monthly and calculate the 12-month rolling total for each month.
- C. The control equipment shall be maintained according to the manufacturer's specifications and good operating practices. The owner or operator shall maintain records of all maintenance completed on the control equipment.
- D. The recirculation water flow to the scrubber (CE 7.3) shall be maintained between 130 and 200 gallons per minute (gpm). The owner or operator shall monitor and record the recirculation water flow rate (in gpm) to the scrubber on a weekly basis.
- E. The owner or operator shall monitor and record 'no visible emissions' observations on a weekly basis. An exceedance of 'no visible emissions' will require the owner/operator to promptly investigate the emission unit, make corrections to operations or equipment associated with the exceedance, and record the corrective action taken.

Authority for Requirement: LCPH ATI 7113 / PTO 6849

Emission Point Characteristics

This emission point shall conform to the specifications listed below.

EP	Stack Height (feet, above ground)	Discharge Style	Stack Opening (inches, dia.)	Temp (°F)	Flowrate (acfm)	Authority for Requirement
7.3	70.2	V	52	140	29,500	LCPH ATI 7113 / PTO 6849

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Opacity Monitoring

See Appendix D, Opacity Monitoring Summary.

Authority for Requirement: 567 IAC 22.108(14)

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes ⁽¹⁾ No

⁽¹⁾ See Appendix C, Facility O&M Plans, for the applicable requirements.

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 18.1, 18.2

Associated Equipment

EP	EU	EU Description	Raw Material	Rated Capacity	CE ID	CE Description
18.1	18.1	Dry Ingredient Storage Silo	Dry Ingredients	1,321 lbs/hr	18.1	Baghouse
18.2	18.2	Dry Ingredient Storage Silo	Dry Ingredients	50,000 lbs/hr	18.2	Cartridge Filters

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from these emission points shall not exceed the levels specified below.

Emission Limits

EP	Pollutant	Emission Limit(s)	Authority for Requirement	Authority for Requirement
18.1	Opacity	20%	LCO Sec.10-60(a)	LCPH ATI 4586 / PTO 5206-R2 LCPH ATI 6935 / PTO 6931
18.2	PM	0.1 gr/dscf	567 IAC 23.3(2)"a" LCO Sec. 10-62(a)(1)	
18.1	PM/PM ₁₀	0.17 lb/hr; 0.02 tpy		LCPH ATI 4586 / PTO 5206-R2
18.2		0.05 lb/hr; 0.01 tpy		LCPH ATI 6935 / PTO 6931

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Control Equipment (EP 18.1 only)

A baghouse shall be installed to control particulate emissions. The control equipment shall be maintained properly and operated at all times the air pollution source is in operation. All appropriate probes, monitors and gauges needed to measure the parameters outlined in "operating condition monitoring and recordkeeping" shall be installed, maintained and operating during the operation of the emission unit and control device at all times.

Authority for Requirement: LCPH ATI 4586 / PTO 5206 –R2

Operating Limits (EP 18.1 only)

A. This unit shall be limited to a total throughput of 11,575 tons per year based on a 12-month rolling total.

Authority for Requirement: LCPH ATI 4586 / PTO 5206-R2

Operating Condition Monitoring & Recordkeeping (EP 18.1 only)

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Linn County Air Quality Division and other federal or state air pollution regulatory agencies and their authorized representatives. Records shall be legible and maintained in an orderly manner. These records shall show the following:

- A. Record the amount of product loaded per year based on a 12-month rolling total
- B. The owner or operator shall monitor and record 'no visible emissions' observations on a weekly basis. An exceedance of 'no visible emissions' will require the owner/operator to promptly investigate the emission unit, make corrections to operations or equipment associated with the exceedance, and record the corrective action taken.
- C. Maintain a written record of the 'no visible emissions' observations and any action resulting from the observations.
- D. Record all maintenance and repair completed to the control device.

Authority for Requirement: LCPH ATI 4586 / PTO 5206-R2

Operating Requirements with Associated Monitoring and Recordkeeping (EP 18.2 only)

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:

- A. This unit shall be limited to a total throughput of 11,575 tons per year based on a 12-month rolling total. The owner or operator shall record the amount of product unloaded on a monthly and 12-month rolling total basis.
- B. The control equipment shall be maintained according to manufacturer's specifications and good operating practices. The owner or operator shall maintain records of all maintenance completed on the control equipment.
- C. The owner or operator shall monitor and record 'no visible emissions' observations on a weekly basis. An exceedance of 'no visible emissions' will require the owner/operator to promptly investigate the emission unit, make corrections to operations or equipment associated with the exceedance, and record the corrective action taken.

Authority for Requirement: LCPH ATI 6935 / PTO 6931

Emission Point Characteristics

These emission points shall conform to the specifications listed below.

EP	Stack Height (feet, above ground)	Discharge Style	Stack Opening (inches, dia.)	Temp (°F)	Flowrate (acfm)	Authority for Requirement
18.1	50	H	36 x 36	50	3,919	LCPH ATI 4586 / PTO 5206-R2
18.2	58.5	H	10	Ambient	850	LCPH ATI 6935 / PTO 6931

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 19.1, 19.2

Associated Equipment

EP	EU	EU Description	Raw Material	Rated Capacity	CE ID	CE Description
19.1	19.1	Dry Ingredient Storage Silo	Dry Ingredients	1,321 lbs/hr	19.1	Baghouse
19.2	19.2	Dry Ingredient Storage Silo	Dry Ingredients	1,321 lbs/hr	19.2	Baghouse

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from these emission points shall not exceed the levels specified below.

Emission Limits

EP	Pollutant	Emission Limit(s)	Authority for Requirement	Authority for Requirement
19.1	Opacity	20%	LCO Sec.10-60(a)	LCPH ATI 5521 / PTO 5595-R1 LCPH ATI 5522 / PTO 5596-R1
	19.2	PM	0.1 gr/dscf	
PM/PM ₁₀		0.05 lb/hr; 0.006 tpy		

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Control Equipment

A baghouse shall be installed to control particulate emissions. The control equipment shall be maintained properly and operated at all times the air pollution source is in operation. All appropriate probes, monitors and gauges needed to measure the parameters outlined in "operating condition monitoring and recordkeeping" shall be installed, maintained and operating during the operation of the emission unit and control device at all times.

Authority for Requirement: LCPH ATI 5521 / PTO 5595-R1; LCPH ATI 5522 / PTO 5596-R1

Operating Limits

- Silo EU19.1 and Silo EU19.2 shall be limited to a total operation of 36 days per year for both silos combined based on a 12-month rolling total.
- Silo EU19.1 and silo EU19.2 shall be limited to operating a combined total of no more than 8 hours per day between the hours of 6:00AM and 6:00PM.
- Pressure drop across the baghouse shall be maintained between 0.5 to 6.0 inches of water.
- The control equipment on this unit shall be maintained and operated according to the manufacturer's specifications and good operating practices.

Authority for Requirement: LCPH ATI 5521 / PTO 5595-R1; LCPH ATI 5522 / PTO 5596-R1

Operating Condition Monitoring & Recordkeeping:

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Linn County Air Quality Division and other federal or state air pollution regulatory agencies and their authorized representatives. Records shall be legible and maintained in an orderly manner. These records shall show the following:

- Record the days operated per year based on a 12-month rolling total.
- Record on a daily basis the time(s) of the silo's operation.
- The owner or operator shall monitor and record 'no visible emissions' observations on a weekly basis. An exceedance of 'no visible emissions' will require the owner/operator to promptly investigate the emission unit, make corrections to operations or equipment associated with the exceedance, and record the corrective action taken.
- Maintain a written record of the 'no visible emissions' observations and any action resulting from the observations.

- E. Record pressure drop during the loading period on a weekly basis.
 - F. Record all maintenance and repair completed to the control device
- Authority for Requirement: LCPH ATI 5521 / PTO 5595-R1; LCPH ATI 5522 / PTO 5596-R1

Emission Point Characteristics

These emission points shall conform to the specifications listed below.

EP	Stack Height (feet, above ground)	Discharge Style	Stack Opening (inches, dia.)	Temp (°F)	Flowrate (acfm)	Authority for Requirement
19.1	50	H	36 x 36	50	1,200	LCPH ATI 5521 / PTO 5995
19.2	50	H	36 x 36	50	1,200	LCPH ATI 5522 / PTO 5996

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 20.1

Associated Equipment

EP	EU	EU Description	Raw Material	Rated Capacity	CE ID	CE Description
20.1	20.1	Dry Ingredient Rail Car Unloading	Dry Ingredients	45,000 lbs/hr	20.1	Baghouse

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Emission Limits

EP	Pollutant	Emission Limit(s)	Authority for Requirement	Authority for Requirement
20.1	Opacity	20%	LCO Sec.10-60(a)	LCPH ATI 5523 / PTO 5597-R1
	PM	0.1 gr/dscf	567 IAC 23.3(2)"a" LCO Sec. 10-62(a)(1)	
	PM/PM ₁₀	0.07 lb/hr; 0.015 tpy		

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

A baghouse shall be installed to control particulate emissions. The control equipment shall be maintained properly and operated at all times the air pollution source is in operation. All appropriate probes, monitors and gauges needed to measure the parameters outlined in "operating condition monitoring and recordkeeping" shall be installed, maintained and operating during the operation of the emission unit and control device at all times.

Authority for Requirement: LCPH ATI 5523 / PTO 5597-R1

Operating Limits

- This dry ingredient rail car unloading (EU20.1) shall be limited to 36 days per year based on a 12-month rolling total.
- This dry ingredient rail car unloading (EU20.1) shall be limited to operating for no more than 8 hours per day between the hours of 6:00AM and 6:00PM.
- Pressure drop across the baghouse shall be maintained between 0.5 to 6.0 inches of water.
- The control equipment on this unit shall be maintained and operated according to the manufacturer's specifications and good operating practices.

Authority for Requirement: LCPH ATI 5523 / PTO 5597-R1

Operating Condition Monitoring & Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Linn County Air Quality Division and other federal or state air pollution regulatory agencies and their authorized representatives. Records shall be legible and maintained in an orderly manner. These records shall show the following:

- Record the days operated per year based on a 12-month rolling total.
- Record on a daily basis the time(s) of rail unloading operation (EU20.1).
- The owner or operator shall monitor and record 'no visible emissions' observations on a weekly basis. An exceedance of 'no visible emissions' will require the owner/operator to promptly investigate the emission unit, make corrections to operations or equipment associated with the exceedance, and record the corrective action taken.
- Maintain a written record of the 'no visible emissions' observations and any action resulting from the observations.
- Record pressure drop during the loading period on a weekly basis.
- Record all maintenance and repair completed to the control device.

Authority for Requirement: LCPH ATI 5523 / PTO 5597-R1

Emission Point Characteristics

This emission point shall conform to the specifications listed below.

EP	Stack Height (feet, above ground)	Discharge Style	Stack Opening (inches, dia.)	Temp (°F)	Flowrate (acfm)	Authority for Requirement
20.1	11.9	H	8	Ambient	1,650	LCPH ATI 5523 / PTO 5597-R1

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: S1.1, C2.1, B3.1, BD4.1, PL5.1, BU8.1

Associated Equipment

EP	EU	EU Description	Raw Material	Rated Capacity	CE ID	CE Description
S1.1	S1.1	Dry Ingredient Silo – Blending Plant	Dry Ingredients	15 ton/hr	S1.1	Baghouse
C2.1	C2.1	Pneumatic Conveyor #1 – Blending Plant	Dry Ingredients	7.8 ton/hr	C2.1	Baghouse
B3.1	B3.1	Blender #1 – Blending Plant	Dry Ingredients	1 ton/hr	B3.1	Baghouse
BD4.1	BD4.1	Bag Dumper #1 – Blending Plant	Dry Ingredients	1 ton/hr	BD4.1	Baghouse
PL5.1	PL5.1	Packaging Line #1 – Blending Plant	Dry Ingredients	1 ton/hr	PL5.1	Baghouse
BU8.1	BU8.1	Bulk Bag Unloader – Blending Plant	Dry Ingredients	0.4 ton/hr	BU8.1	Baghouse

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from these emission points shall not exceed the levels specified below.

Emission Limits

EP	Pollutant	Emission Limit(s)	Authority for Requirement	Authority for Requirement
S1.1 C2.1	Opacity	20%	LCO Sec.10-60(a)	LCPH ATI 6954 / PTO 6905 LCPH ATI 6955 / PTO 6906
B3.1 BD4.1	PM	0.1 gr/dscf	567 IAC 23.3(2)"a" LCO Sec. 10-62(a)(1)	LCPH ATI 6956 / PTO 6907 LCPH ATI 6957 / PTO 6908
PL5.1 BU8.1	PM/PM ₁₀	0.01 gr/dscf		LCPH ATI 6958 / PTO 6909 LCPH ATI 7195 / PTO 6930

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:

- A. The control equipment shall be maintained according to manufacturer's specifications and good operating practices. The owner or operator shall maintain records of all maintenance completed on the control equipment.
- B. The owner or operator shall monitor and record 'no visible emissions' observations on a weekly basis. An exceedance of 'no visible emissions' will require the owner/operator to promptly investigate the emission unit, make corrections to operations or equipment associated with the exceedance, and record the corrective action taken.

Authority for Requirement: LCPH ATI 6954 / PTO 6905; LCPH ATI 6955 / PTO 6906;
LCPH ATI 6956 / PTO 6907; LCPH ATI 6957 / PTO 6908;
LCPH ATI 6958 / PTO 6909; LCPH ATI 7195 / PTO 6930

Emission Point Characteristics

These emission points shall conform to the specifications listed below.

EP	Stack Height (feet, above ground)	Discharge Style	Stack Opening (inches, dia.)	Temp (°F)	Flowrate (acfm)	Authority for Requirement
S1.1	50	H	6	Ambient	620-1,000	LCPH ATI 6954 / PTO 6905
C2.1	55	H	6	Ambient	1,400	LCPH ATI 6955 / PTO 6906
B3.1	70	H	4	70	350	LCPH ATI 6956 / PTO 6907
BD4.1	25	V	4	70	400	LCPH ATI 6957 / PTO 6908
PL5.1	36	H	10	70	3,000	LCPH ATI 6958 / PTO 6909
BU8.1	13.5	H	4.5	70	400	LCPH ATI 7195 / PTO 6930

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Opacity Monitoring

See Appendix D, Opacity Monitoring Summary.

Authority for Requirement: 567 IAC 22.108(14)

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes ⁽¹⁾ No

⁽¹⁾ See Appendix C, Facility O&M Plans, for the applicable requirements. (EPs C2.1 and PL5.1 only)

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 60.1

Associated Equipment

EP	EU	EU Description	Fuel	Rated Capacity	CE ID	CE Description
60.1	60.1	Emergency Generator	Natural Gas	100 BHP 1,020 cf/hr	--	--

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

EP	Pollutant	Emission Limit(s)	Authority for Requirement	Authority for Requirement
60.1	NO _x	10 g/HP-hr ¹	40 CFR §60.4233(e)	SI 152
	CO	387 g/HP-hr		
	SO ₂	500 ppm _v	LCO Sec. 10-65(a)(2)	
	Opacity	20%	LCO Sec. 10-60(a)	

¹ The emission standard is in terms of NO_x + HC.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Federal Standards

A. New Source Performance Standards (NSPS):

The following subparts apply to the emission unit(s) in this permit:

EU ID	Subpart	Title	Type	Local Reference (LCO Sec.)	Federal Reference (40 CFR)
60.1	A	General Conditions	--	10-62(b)	§60.1 – §60.19
	JJJJ	Standards of Performance for Stationary Spark Ignition Internal Combustion Engines	New Emergency Engine	10-62(b)(78)	§60.4230 - §60.4248

Authority for Requirement: 567 IAC 23.1(2)"zzz"; Registration Permit SI 152

B. National Emission Standards for Hazardous Air Pollutants (NESHAP):

The following subparts apply to the emission unit(s) in this permit:

EU ID	Subpart	Title	Type	Local Reference (LCO Sec.)	Federal Reference (40 CFR)
60.1	ZZZZ	National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines	New Emergency Engine 25<HP<130	10-62(d)(104)	§63.6580 - §63.6675

Authority for Requirement: 567 IAC 23.1(4)"cz"; Registration Permit SI 152

Below are the specific requirements outlined in the Stationary Spark Ignition Internal Combustion Engines (Less than 400 Brake Horsepower) Registration Permit for EP60.1. For a full explanation of all requirements and to view NSPS Subpart JJJJ in its entirety, please refer to the web link in Appendix A – Applicable Federal Standards.

Summary of Compliance Requirements for Owners and Operators

A. Engines subject to Subpart JJJJ are required to meet emission standards. The standards are listed above. The engine must be operated and maintained to meet the applicable emission standards over the life of the engine.
Authority for Requirement: Registration Permit SI 152

Engine Certification Requirements

A. Other groups of engines may be certified by the manufacturer to comply with the emission standards.
Authority for Requirement: Registration Permit SI 152

Requirements for certified SI engines

- A. Owners and operators of SI engines that are required to be certified and who operate and maintain the engine according to the manufacturer’s written instructions must keep records of required maintenance.
- B. Owners and operators must keep a record from the manufacturer that the engine meets the emission standards.
- C. Owners and operators of SI engines that are not required to be certified may purchase an engine that is certified by the manufacturer to comply with the emission standards. The engine must be maintained according to the manufacturer’s written instructions and records of required maintenance must be kept.
- D. Engines that are required to be certified that are not operated and maintained according to manufacturer’s written instructions are considered to be non-certified engines. Owners and operators of such a non-certified SI engine must keep a maintenance plan and records of conducted maintenance and must maintain and operate the engine in a manner consistent with good air pollution control practice to minimize emissions. An initial performance test is required if the engine is rated at 100 HP or greater.

Authority for Requirement: Registration Permit SI 152

Emergency Engine Requirements for Owners and Operators

- A. Owners and operators of an emergency SI engine that is less than 130 bhp and does not meet the applicable standards for a non-emergency engine must install a non-resettable hour meter upon start-up.
- B. The SI engine may be operated for the purpose of maintenance checks and readiness testing for a maximum of 100 hours per year. There is no time limit on use for emergency situations.
- C. The engine may be operated for up to 50 hours per year for non-emergency purposes. This operating time cannot be used to generate income for the facility (e.g., supplying power to the grid) and should be included in the total of 100 hours allowed for maintenance checks and readiness testing.
- D. Owners and operators of an emergency engine must keep records of all operation of the engine. The owner must record the date and time of operation of the engine and the reason the engine was in operation.
- E. Owners and operators of natural gas SI engines may use propane as an alternative fuel for up to 100 hours per year during emergency operations.

Authority for Requirement: Registration Permit SI 152

Monitoring Requirements

The owner/operator of this equipment shall comply with the periodic monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: FP7.1

Associated Equipment

EP	EU	EU Description	Fuel	Rated Capacity	CE ID	CE Description
FP7.1	FP7.1	Emergency Fire Pump – Blending Plant	Diesel	183 BHP 9.6 gallons/hour	--	--

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

EP	Pollutant	Emission Limit(s)	Authority for Requirement	Authority for Requirement
FP7.1	NMHC + NO _x	4.0 grams/kW-hr (3.0 grams/HP-hr)	40 CFR §60.4205(c)	CI 142
	CO	3.5 grams/kW-hr (2.6 grams/HP-hr)		
	PM	0.20 grams/kW-hr (0.15 grams/HP-hr)		
	SO ₂	1.5 lb/MMBtu	LCO Sec. 10-65(a)(1)(b)	
	Opacity	20%	LCO Sec. 10-60(a)	

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Federal Standards

A. New Source Performance Standards (NSPS):

The following subparts apply to the emission unit(s) in this permit:

EU ID	Subpart	Title	Type	Local Reference (LCO Sec.)	Federal Reference (40 CFR)
FP7.1	A	General Conditions	--	10-62(b)	§60.1 – §60.19
	III	Standards of Performance for Stationary Compression Ignition Internal Combustion Engines	New Fire Pump	10-62(b)(77)	§60.4200 - §60.4219

Authority for Requirement: 567 IAC 23.1(2)"yyy"; Registration Permit CI 142

B. National Emission Standards for Hazardous Air Pollutants (NESHAP):

The following subparts apply to the emission unit(s) in this permit:

EU ID	Subpart	Title	Type	Local Reference (LCO Sec.)	Federal Reference (40 CFR)
FP7.1	ZZZZ	National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines	New Fire Pump	10-62(d)(104)	§63.6580 - §63.6675

Authority for Requirement: 567 IAC 23.1(4)"cz"; Registration Permit CI 142

Below are the specific requirements outlined in the Stationary Compression Ignition Internal Combustion Engines (Less than 400 Brake Horsepower) Registration Permit for EPFP7.1. For a full explanation of all requirements and to view NSPS Subpart III in its entirety, please refer to the web link in Appendix A – Applicable Federal Standards.

Emission Standards for Owners and Operators

- A. Beginning with the model years in table 3 of subpart IIII, stationary CI internal combustion engine manufacturers must certify their fire pump stationary CI ICE to the emission standards in table 4 to subpart IIII, for all pollutants, for the same model year and NFPA nameplate power.

Authority for Requirement: Registration Permit CI 142

Fuel Requirements for Owners and Operators

- A. Beginning October 1, 2010, engines must use a fuel that meets the following: 1) a maximum sulfur content of 15 ppm and 2) either a minimum cetane index of 40 or a maximum aromatic content of 35 percent by volume.

Authority for Requirement: Registration Permit CI 142

Emergency Engine Requirements for Owners and Operators

- A. Owners and operators of an emergency CI engine must install a non-resettable hour meter prior to start-up of the engine.
- B. The engine may be operated for the purpose of maintenance checks and readiness testing a maximum of 100 hours/year. There is no time limit on use for emergency situations.
- C. Operation other than for emergency operation and maintenance checks and readiness testing as permitted is prohibited
- D. Owners and operators of an emergency engine must keep records of all operation of the engine. The owner must record the time of operation of the engine and the reason the engine was in operation.

Authority for Requirement: Registration Permit CI 142

Summary of Compliance Requirements for Owners and Operators

- A. Owners and operators of stationary CI ICE must operate and maintain stationary CI ICE that achieve the emission standards as required in §60.4205 over the entire life of the engine.
- B. Owners and operators of CI fire pump engines that are manufactured on or after the model years specified in Table 3 to subpart IIII must comply with the emission standards above by purchasing an engine certified to the applicable emission standards for the same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power. The engine must be installed and configured according to the manufacturer's specifications except as permitted in paragraph (g) of §60.4211.

Authority for Requirement: Registration Permit CI 142

Monitoring Requirements

The owner/operator of this equipment shall comply with the periodic monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

IV. General Conditions

This permit is issued under the authority of the Iowa Code subsection 455B.133(8) and in accordance with 567 Iowa Administrative Code chapter 22 and Linn County Code of Ordinance (LCO) Chapter 10 – Environment, Article III, Sec. 10-57.

G1. Duty to Comply

1. The permittee must comply with all conditions of the Title V permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action; for a permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. *567 IAC 22.108(9)"a"*
2. Any compliance schedule shall be supplemental to, and shall not sanction noncompliance with, the applicable requirements on which it is based. *567 IAC 22.105 (2)"h"(3)*
3. Where an applicable requirement of the Act is more stringent than an applicable requirement of regulations promulgated under Title IV of the Act, both provisions shall be enforceable by the administrator and are incorporated into this permit. *567 IAC 22.108 (1)"b"*
4. Unless specified as either "state enforceable only" or "local program enforceable only", all terms and conditions in the permit, including provisions to limit a source's potential to emit, are enforceable by the administrator and citizens under the Act. *567 IAC 22.108 (14)*
5. It shall not be a defense for a permittee, in an enforcement action, that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. *567 IAC 22.108 (9)"b"*
6. For applicable requirements with which the permittee is in compliance, the permittee shall continue to comply with such requirements. For applicable requirements that will become effective during the permit term, the permittee shall meet such requirements on a timely basis. *567 IAC 22.108(15)"c"*

G2. Permit Expiration

1. Except as provided in rule 567—22.104(455B), permit expiration terminates a source's right to operate unless a timely and complete application for renewal has been submitted in accordance with rule 567—22.105(455B). *567 IAC 22.116(2)*
2. To be considered timely, the owner, operator, or designated representative (where applicable) of each source required to obtain a Title V permit shall submit on forms or electronic format specified by the Department to the Air Quality Bureau, Iowa Department of Natural Resources, Air Quality Bureau, Wallace State Office Building, 502 E 9th St., Des Moines, IA 50319-0034, two copies (three if your facility is located in Linn or Polk county) of a complete permit application, at least 6 months but not more than 18 months prior to the date of permit expiration. An additional copy must also be sent to U.S. EPA Region VII, Attention: Chief of Air Permitting & Standards Branch, 11201 Renner Blvd., Lenexa, KS 66219. Additional copies to local programs or EPA are not required for application materials submitted through the electronic format specified by the Department. The application must include all emission points, emission units, air pollution control equipment, and monitoring devices at the facility. All emissions generating activities, including fugitive emissions, must be included. The definition of a complete application is as indicated in 567 IAC 22.105(2). *567 IAC 22.105*

G3. Certification Requirement for Title V Related Documents

Any application, report, compliance certification or other document submitted pursuant to this permit shall contain certification by a responsible official of truth, accuracy, and completeness. All certifications shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. *567 IAC 22.107 (4)*

G4. Annual Compliance Certification

By March 31 of each year, the permittee shall submit compliance certifications for the previous calendar year. The certifications shall include descriptions of means to monitor the compliance status of all emissions sources including emissions limitations, standards, and work practices in accordance with applicable requirements. The certification for a source shall include the identification of each term or condition of the permit that is the basis of the certification; the compliance status; whether compliance was continuous or intermittent; the method(s) used for determining the compliance status of the source, currently and over the reporting period consistent with all applicable department rules. For sources determined not to be in compliance at the time of compliance certification, a compliance schedule shall be submitted which provides for periodic progress reports, dates for achieving activities, milestones, and an explanation of why any dates were missed and preventive or corrective measures. The compliance certification shall be submitted to the administrator, director, and Linn County Public Health Air Quality Division. *567 IAC 22.108 (15)"e"*

G5. Semi-Annual Monitoring Report

By March 31 and September 30 of each year, the permittee shall submit a report of any monitoring required under this permit for the 6 month periods of July 1 to December 31 and January 1 to June 30, respectively. All instances of deviations from permit requirements must be clearly identified in these reports, and the report must be signed by a responsible official, consistent with 567 IAC 22.107(4). The semi-annual monitoring report shall be submitted to the director and Linn County Public Health Air Quality Division. *567 IAC 22.108 (5)*

G6. Annual Fee

1. The permittee is required under subrule 567 IAC 22.106 to pay an annual fee based on the total tons of actual emissions of each regulated air pollutant. Beginning July 1, 1996, Title V operating permit fees will be paid on July 1 of each year. The fee shall be based on emissions for the previous calendar year.
2. The fee amount shall be calculated based on the first 4,000 tons of each regulated air pollutant emitted each year. The fee to be charged per ton of pollutant will be available from the department by June 1 of each year. The Responsible Official will be advised of any change in the annual fee per ton of pollutant.
3. The emissions inventory shall be submitted annually by March 31 with forms specified by the department documenting actual emissions for the previous calendar year.
4. The fee shall be submitted annually by July 1 with forms specified by the department.
5. If there are any changes to the emission calculation form, the department shall make revised forms available to the public by January 1. If revised forms are not available by January 1, forms from the previous year may be used and the year of emissions documented changed. The department shall calculate the total statewide Title V emissions for the prior calendar year and make this information available to the public no later than April 30 of each year.
6. Phase I acid rain affected units under section 404 of the Act shall not be required to pay a fee for emissions which occur during the years 1993 through 1999 inclusive.
7. The fee for a portable emissions unit or stationary source which operates both in Iowa and out of state shall be calculated only for emissions from the source while operating in Iowa.
8. Failure to pay the appropriate Title V fee represents cause for revocation of the Title V permit as indicated in 567 IAC 22.115(1)"d".

G7. Inspection of Premises, Records, Equipment, Methods and Discharges

Upon presentation of proper credentials and any other documents as may be required by law, the permittee shall allow the director or the director's authorized representative to:

1. Enter upon the permittee's premises where a Title V source is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
3. Inspect, at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
4. Sample or monitor, at reasonable times, substances or parameters for the purpose of ensuring compliance with the permit or other applicable requirements. *567 IAC 22.108 (15)"b" and LCO Sec. 10-75*

G8. Duty to Provide Information

The permittee shall furnish to the director, within a reasonable time, any information that the director may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee also shall furnish to the director copies of records required to be kept by the permit, or for information claimed to be confidential, the permittee shall furnish such records directly to the administrator of EPA along with a claim of confidentiality. *567 IAC 22.108 (9)"e" and LCO Sec. 10-71 and 10-72*

G9. General Maintenance and Repair Duties

The owner or operator of any air emission source or control equipment shall:

1. Maintain and operate the equipment or control equipment at all times in a manner consistent with good practice for minimizing emissions.
2. Remedy any cause of excess emissions in an expeditious manner.
3. Minimize the amount and duration of any excess emission to the maximum extent possible during periods of such emissions. These measures may include but not be limited to the use of clean fuels, production cutbacks, or the use of alternate process units or, in the case of utilities, purchase of electrical power until repairs are completed.
4. Schedule, at a minimum, routine maintenance of equipment or control equipment during periods of process shutdowns to the maximum extent possible. *567 IAC 24.2(1) and LCO Sec. 10-67(b)*

G10. Recordkeeping Requirements for Compliance Monitoring

1. In addition to any source specific recordkeeping requirements contained in this permit, the permittee shall maintain the following compliance monitoring records, where applicable:
 - a. The date, place and time of sampling or measurements
 - b. The date the analyses were performed.
 - c. The company or entity that performed the analyses.
 - d. The analytical techniques or methods used.
 - e. The results of such analyses; and
 - f. The operating conditions as existing at the time of sampling or measurement.
 - g. The records of quality assurance for continuous compliance monitoring systems (including but not limited to quality control activities, audits and calibration drifts.)
2. The permittee shall retain records of all required compliance monitoring data and support information for a period of at least 5 years from the date of compliance monitoring sample, measurement report or application. Support information includes all calibration and maintenance records and all original strip chart recordings for continuous compliance monitoring, and copies of all reports required by the permit.
3. For any source which in its application identified reasonably anticipated alternative operating scenarios, the permittee shall:
 - a. Comply with all terms and conditions of this permit specific to each alternative scenario.
 - b. Maintain a log at the permitted facility of the scenario under which it is operating.
 - c. Consider the permit shield, if provided in this permit, to extend to all terms and conditions under each operating scenario. *567 IAC 22.108(4), 567 IAC 22.108(12)*

G11. Evidence used in establishing that a violation has or is occurring.

Notwithstanding any other provisions of these rules, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions herein.

1. Information from the use of the following methods is presumptively credible evidence of whether a violation has occurred at a source:
 - a. A monitoring method approved for the source and incorporated in an operating permit pursuant to 567 Chapter 22;
 - b. Compliance test methods specified in 567 Chapter 25; or
 - c. Testing or monitoring methods approved for the source in a construction permit issued pursuant to 567 Chapter 22.
2. The following testing, monitoring or information gathering methods are presumptively credible testing, monitoring, or information gathering methods:
 - a. Any monitoring or testing methods provided in these rules; or
 - b. Other testing, monitoring, or information gathering methods that produce information comparable to that produced by any method in subrule 21.5(1) or this subrule. *567 IAC 21.5(1)-567 IAC 21.5(2) and LCO Sec. 10-69(1)*

G12. Prevention of Accidental Release: Risk Management Plan Notification and Compliance Certification

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Act, the permittee shall notify the department of this requirement. The plan shall be filed with all appropriate authorities by the deadline specified by EPA. A certification that this risk management plan is being properly implemented shall be included in the annual compliance certification of this permit. *567 IAC 22.108(6)*

G13. Hazardous Release

The permittee must report any situation involving the actual, imminent, or probable release of a hazardous substance into the atmosphere which, because of the quantity, strength and toxicity of the substance, creates an immediate or potential danger to the public health, safety or to the environment. A verbal report shall be made to the department at (515) 725-8694 and to the local police department or the office of the sheriff of the affected county as soon as possible but not later than six hours after the discovery or onset of the condition. This verbal report must be followed up with a written report as indicated in 567 IAC 131.2(2). *567 IAC Chapter 131-State Only*

G14. Excess Emissions and Excess Emissions Reporting Requirements

1. Excess Emissions. Excess emission during a period of startup, shutdown, or cleaning of control equipment is not a violation of the emission standard if the startup, shutdown or cleaning is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions. Cleaning of control equipment which does not require the shutdown of the process equipment shall be limited to one six-minute period per one-hour period. An incident of excess emission (other than an incident during startup, shutdown or cleaning of control equipment) is a violation. If the owner or operator of a source maintains that the incident of excess emission was due to a malfunction, the owner or operator must show that the conditions which caused the incident of excess emission were

not preventable by reasonable maintenance and control measures. Determination of any subsequent enforcement action will be made following review of this report. If excess emissions are occurring, either the control equipment causing the excess emission shall be repaired in an expeditious manner or the process generating the emissions shall be shutdown within a reasonable period of time. An expeditious manner is the time necessary to determine the cause of the excess emissions and to correct it within a reasonable period of time. A reasonable period of time is eight hours plus the period of time required to shut down the process without damaging the process equipment or control equipment. A variance from this subrule may be available as provided for in Iowa Code section 455B.143. In the case of an electric utility, a reasonable period of time is eight hours plus the period of time until comparable generating capacity is available to meet consumer demand with the affected unit out of service, unless, the director shall, upon investigation, reasonably determine that continued operation constitutes an unjustifiable environmental hazard and issue an order that such operation is not in the public interest and require a process shutdown to commence immediately.

2. Excess Emissions Reporting

a. **Initial Reporting of Excess Emissions.** An incident of excess emission (other than an incident of excess emission during a period of startup, shutdown, or cleaning) shall be reported to the appropriate field office of the department within eight hours of, or at the start of the first working day following the onset of the incident. The reporting exemption for an incident of excess emission during startup, shutdown or cleaning does not relieve the owner or operator of a source with continuous monitoring equipment of the obligation of submitting reports required in 567-subrule 25.1(6). An initial report of excess emission is not required for a source with operational continuous monitoring equipment (as specified in 567-subrule 25.1(1)) if the incident of excess emission continues for less than 30 minutes and does not exceed the applicable emission standard by more than 10 percent or the applicable visible emission standard by more than 10 percent opacity. The initial report may be made by electronic mail (E-mail), in person, or by telephone and shall include as a minimum the following:

- i. The identity of the equipment or source operation from which the excess emission originated and the associated stack or emission point.
- ii. The estimated quantity of the excess emission.
- iii. The time and expected duration of the excess emission.
- iv. The cause of the excess emission.
- v. The steps being taken to remedy the excess emission.
- vi. The steps being taken to limit the excess emission in the interim period.

b. **Written Reporting of Excess Emissions.** A written report of an incident of excess emission shall be submitted as a follow-up to all required initial reports to the department within seven days of the onset of the upset condition, and shall include as a minimum the following:

- i. The identity of the equipment or source operation point from which the excess emission originated and the associated stack or emission point.
- ii. The estimated quantity of the excess emission.
- iii. The time and duration of the excess emission.
- iv. The cause of the excess emission.
- v. The steps that were taken to remedy and to prevent the recurrence of the incident of excess emission.
- vi. The steps that were taken to limit the excess emission.
- vii. If the owner claims that the excess emission was due to malfunction, documentation to support this claim. *567 IAC 24.1(1)-567 IAC 24.1(4) and LCO Sec. 10-67*

3. **Emergency Defense for Excess Emissions.** For the purposes of this permit, an "emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which situation requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission limitation under the permit due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include non-compliance, to the extent caused by improperly designed equipment, lack of preventive maintenance, careless or improper operation or operator error. An emergency constitutes an affirmative defense to an action brought for non-compliance with technology based limitations if it can be demonstrated through properly signed contemporaneous operating logs or other relevant evidence that:

- a. An emergency occurred and that the permittee can identify the cause(s) of the emergency;
- b. The facility at the time was being properly operated;
- c. During the period of the emergency, the permittee took all reasonable steps to minimize levels of emissions that exceeded the emissions standards or other requirements of the permit; and

d. The permittee submitted notice of the emergency to the director by certified mail within two working days of the time when the emissions limitations were exceeded due to the emergency. This notice fulfills the requirement of paragraph 22.108(5)"b." – See G15. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

In any enforcement proceeding, the permittee seeking to establish the occurrence of an emergency has the burden of proof. This provision is in addition to any emergency or upset provision contained in any applicable requirement. *567 IAC 22.108(16)*

G15. Permit Deviation Reporting Requirements

A deviation is any failure to meet a term, condition or applicable requirement in the permit. Reporting requirements for deviations that result in a hazardous release or excess emissions have been indicated above (see G13 and G14). Unless more frequent deviation reporting is specified in the permit, any other deviation shall be documented in the semi-annual monitoring report and the annual compliance certification (see G4 and G5). *567 IAC 22.108(5)"b"*

G16. Notification Requirements for Sources That Become Subject to NSPS and NESHAP Regulations

During the term of this permit, the permittee must notify the department of any source that becomes subject to a standard or other requirement under 567-subrule 23.1(2) (standards of performance of new stationary sources) or section 111 of the Act; or 567-subrule 23.1(3) (emissions standards for hazardous air pollutants), 567-subrule 23.1(4) (emission standards for hazardous air pollutants for source categories) or section 112 of the Act. This notification shall be submitted in writing to the department pursuant to the notification requirements in 40 CFR Section 60.7, 40 CFR Section 61.07, and/or 40 CFR Section 63.9. *567 IAC 23.1(2), 567 IAC 23.1(3), 567 IAC 23.1(4)* This notification must be made to Linn County Air Quality Division, in lieu of the Department, upon adoption of the NSPS or NESHAP into Chapter 10.

G17. Requirements for Making Changes to Emission Sources That Do Not Require Title V Permit Modification

1. Off Permit Changes to a Source. Pursuant to section 502(b)(10) of the CAAA, the permittee may make changes to this installation/facility without revising this permit if:

- a. The changes are not major modifications under any provision of any program required by section 110 of the Act, modifications under section 111 of the act, modifications under section 112 of the act, or major modifications as defined in 567 IAC Chapter 22.
- b. The changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions);
- c. The changes are not modifications under any provisions of Title I of the Act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or as total emissions);
- d. The changes are not subject to any requirement under Title IV of the Act (revisions affecting Title IV permitting are addressed in rules 567—22.140(455B) through 567 - 22.144(455B));
- e. The changes comply with all applicable requirements.
- f. For each such change, the permitted source provides to the department and the administrator by certified mail, at least 30 days in advance of the proposed change, a written notification, including the following, which must be attached to the permit by the source, the department and the administrator:
 - i. A brief description of the change within the permitted facility,
 - ii. The date on which the change will occur,
 - iii. Any change in emission as a result of that change,
 - iv. The pollutants emitted subject to the emissions trade
 - v. If the emissions trading provisions of the state implementation plan are invoked, then Title V permit requirements with which the source shall comply; a description of how the emissions increases and decreases will comply with the terms and conditions of the Title V permit.
 - vi. A description of the trading of emissions increases and decreases for the purpose of complying with a federally enforceable emissions cap as specified in and in compliance with the Title V permit; and
 - vii. Any permit term or condition no longer applicable as a result of the change.

567 IAC 22.110(1)

2. Such changes do not include changes that would violate applicable requirements or contravene federally enforceable permit terms and conditions that are monitoring (including test methods), record keeping, reporting, or compliance certification requirements. *567 IAC 22.110(2)*

3. Notwithstanding any other part of this rule, the director may, upon review of a notice, require a stationary source to apply for a Title V permit if the change does not meet the requirements of subrule 22.110(1). *567 IAC 22.110(3)*

4. The permit shield provided in subrule 22.108(18) shall not apply to any change made pursuant to this rule. Compliance with the permit requirements that the source will meet using the emissions trade shall be determined according to requirements of the state implementation plan authorizing the emissions trade. *567 IAC 22.110(4)*
5. No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes, for changes that are provided for in this permit. *567 IAC 22.108(11)*

G18. Duty to Modify a Title V Permit

1. Administrative Amendment.

- a. An administrative permit amendment is a permit revision that does any of the following:
 - i. Correct typographical errors
 - ii. Identify a change in the name, address, or telephone number of any person identified in the permit, or provides a similar minor administrative change at the source;
 - iii. Require more frequent monitoring or reporting by the permittee; or
 - iv. Allow for a change in ownership or operational control of a source where the director determines that no other change in the permit is necessary, provided that a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new permittee has been submitted to the director.
- b. The permittee may implement the changes addressed in the request for an administrative amendment immediately upon submittal of the request. The request shall be submitted to the director.
- c. Administrative amendments to portions of permits containing provisions pursuant to Title IV of the Act shall be governed by regulations promulgated by the administrator under Title IV of the Act.

2. Minor Title V Permit Modification.

- a. Minor Title V permit modification procedures may be used only for those permit modifications that satisfy all of the following:
 - i. Do not violate any applicable requirement;
 - ii. Do not involve significant changes to existing monitoring, reporting or recordkeeping requirements in the Title V permit;
 - iii. Do not require or change a case by case determination of an emission limitation or other standard, or an increment analysis;
 - iv. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed in order to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include any federally enforceable emissions caps which the source would assume to avoid classification as a modification under any provision under Title I of the Act; and an alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Act;
 - v. Are not modifications under any provision of Title I of the Act; and
 - vi. Are not required to be processed as significant modification under rule 567 - 22.113(455B).
- b. An application for minor permit revision shall be on the minor Title V modification application form and shall include at least the following:
 - i. A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
 - ii. The permittee's suggested draft permit;
 - iii. Certification by a responsible official, pursuant to *567 IAC 22.107(4)*, that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used; and
 - iv. Completed forms to enable the department to notify the administrator and the affected states as required by *567 IAC 22.107(7)*.
- c. The permittee may make the change proposed in its minor permit modification application immediately after it files the application. After the permittee makes this change and until the director takes any of the actions specified in *567 IAC 22.112(4)* "a" to "c", the permittee must comply with both the applicable requirements governing the change and the proposed permit terms and conditions. During this time, the permittee need not comply with the existing permit terms and conditions it seeks to modify. However, if the permittee fails to comply with its proposed permit terms and conditions during this time period, the existing permit terms and conditions it seeks to modify may be enforced against the facility.

3. Significant Title V Permit Modification.

Significant Title V modification procedures shall be used for applications requesting Title V permit modifications that do not qualify as minor Title V modifications or as administrative amendments. These include but are not

limited to all significant changes in monitoring permit terms, every relaxation of reporting or recordkeeping permit terms, and any change in the method of measuring compliance with existing requirements. Significant Title V modifications shall meet all requirements of 567 IAC Chapter 22, including those for applications, public participation, review by affected states, and review by the administrator, as those requirements that apply to Title V issuance and renewal.

The permittee shall submit an application for a significant permit modification not later than three months after commencing operation of the changed source unless the existing Title V permit would prohibit such construction or change in operation, in which event the operation of the changed source may not commence until the department revises the permit. *567 IAC 22.111-567 IAC 22.113*

G19. Duty to Obtain Construction Permits

Unless exempted in 567 IAC 22.1(2) or to meet the parameters established in 567 IAC 22.1(1)"c", the permittee shall not construct, install, reconstruct or alter any equipment, control equipment or anaerobic lagoon without first obtaining a construction permit, or conditional permit, or permit pursuant to rule 567 IAC 22.8, or permits required pursuant to rules 567 IAC 22.4, 567 IAC 22.5, 567 IAC 31.3, and 567 IAC 33.3 as required in 567 IAC 22.1(1). A permit shall be obtained prior to the initiation of construction, installation or alteration of any portion of the stationary source or anaerobic lagoon. *567 IAC 22.1(1) and LCO Sec. 10-58*

G20. Asbestos

The permittee shall comply with 567 IAC 23.1(3)"a", and 567 IAC 23.2(3)"g" when activities involve asbestos mills, surfacing of roadways, manufacturing operations, fabricating, insulating, waste disposal, spraying applications, demolition and renovation operations (*567 IAC 23.1(3)"a"*); training fires and controlled burning of a demolished building (*567 IAC 23.2*).

G21. Open Burning

The permittee is prohibited from conducting open burning, except as provided in LCO Sec. 10-63.

G22. Acid Rain (Title IV) Emissions Allowances

The permittee shall not exceed any allowances that it holds under Title IV of the Act or the regulations promulgated there under. Annual emissions of sulfur dioxide in excess of the number of allowances to emit sulfur dioxide held by the owners and operators of the unit or the designated representative of the owners and operators is prohibited. Exceedences of applicable emission rates are prohibited. "Held" in this context refers to both those allowances assigned to the owners and operators by USEPA, and those allowances supplementally acquired by the owners and operators. The use of any allowance prior to the year for which it was allocated is prohibited. Contravention of any other provision of the permit is prohibited. *567 IAC 22.108(7)*

G23. Stratospheric Ozone and Climate Protection (Title VI) Requirements

1. The permittee shall comply with the standards for labeling of products using ozone-depleting substances pursuant to 40 CFR Part 82, Subpart E:

- a. All containers in which a class I or class II substance is stored or transported, all products containing a class I substance, and all products directly manufactured with a class I substance must bear the required warning statement if it is being introduced into interstate commerce pursuant to § 82.106.
- b. The placement of the required warning statement must comply with the requirements pursuant to § 82.108.
- c. The form of the label bearing the required warning statement must comply with the requirements pursuant to § 82.110.
- d. No person may modify, remove, or interfere with the required warning statement except as described in § 82.112.

2. The permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 CFR Part 82, Subpart F, except as provided for MVACs in Subpart B:

- a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to § 82.156.
- b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to § 82.158.
- c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to § 82.161.
- d. Persons disposing of small appliances, MVACs, and MVAC-like appliances must comply with reporting and recordkeeping requirements pursuant to § 82.166. ("MVAC-like appliance" as defined at § 82.152)
- e. Persons owning commercial or industrial process refrigeration equipment must comply with the leak repair requirements pursuant to § 82.156.
- f. Owners/operators of appliances normally containing 50 or more pounds of refrigerant must keep records of refrigerant purchased and added to such appliances pursuant to § 82.166.

3. If the permittee manufactures, transforms, imports, or exports a class I or class II substance, the permittee is subject to all the requirements as specified in 40 CFR part 82, Subpart A, Production and Consumption Controls.
4. If the permittee performs a service on motor (fleet) vehicles when this service involves ozone-depleting substance refrigerant (or regulated substitute substance) in the motor vehicle air conditioner (MVAC), the permittee is subject to all the applicable requirements as specified in 40 CFR part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners. The term "motor vehicle" as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed. The term "MVAC" as used in Subpart B does not include the air-tight sealed refrigeration system used as refrigerated cargo, or system used on passenger buses using HCFC-22 refrigerant,
5. The permittee shall be allowed to switch from any ozone-depleting or greenhouse gas generating substances to any alternative that is listed in the Significant New Alternatives Program (SNAP) promulgated pursuant to 40 CFR part 82, Subpart G, Significant New Alternatives Policy Program. *40 CFR part 82*

G24. Permit Reopenings

1. This permit may be modified, revoked, reopened, and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition. *567 IAC 22.108(9)"c"*
2. Additional applicable requirements under the Act become applicable to a major part 70 source with a remaining permit term of 3 or more years. Revisions shall be made as expeditiously as practicable, but not later than 18 months after the promulgation of such standards and regulations.
 - a. Reopening and revision on this ground is not required if the permit has a remaining term of less than three years;
 - b. Reopening and revision on this ground is not required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions have been extended pursuant to 40 CFR 70.4(b)(10)(i) or (ii) as amended to May 15, 2001.
 - c. Reopening and revision on this ground is not required if the additional applicable requirements are implemented in a general permit that is applicable to the source and the source receives approval for coverage under that general permit. *567 IAC 22.108(17)"a"*, *567 IAC 22.108(17)"b"*
3. A permit shall be reopened and revised under any of the following circumstances:
 - a. The department receives notice that the administrator has granted a petition for disapproval of a permit pursuant to 40 CFR 70.8(d) as amended to July 21, 1992, provided that the reopening may be stayed pending judicial review of that determination;
 - b. The department or the administrator determines that the Title V permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the Title V permit;
 - c. Additional applicable requirements under the Act become applicable to a Title V source, provided that the reopening on this ground is not required if the permit has a remaining term of less than three years, the effective date of the requirement is later than the date on which the permit is due to expire, or the additional applicable requirements are implemented in a general permit that is applicable to the source and the source receives approval for coverage under that general permit. Such a reopening shall be complete not later than 18 months after promulgation of the applicable requirement.
 - d. Additional requirements, including excess emissions requirements, become applicable to a Title IV affected source under the acid rain program. Upon approval by the administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.
 - e. The department or the administrator determines that the permit must be revised or revoked to ensure compliance by the source with the applicable requirements. *567 IAC 22.114(1)*
4. Proceedings to reopen and reissue a Title V permit shall follow the procedures applicable to initial permit issuance and shall effect only those parts of the permit for which cause to reopen exists. *567 IAC 22.114(2)*
5. A notice of intent shall be provided to the Title V source at least 30 days in advance of the date the permit is to be reopened, except that the director may provide a shorter time period in the case of an emergency. *567 IAC 22.114(3)*

G25. Permit Shield

1. The director may expressly include in a Title V permit a provision stating that compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that:
 - a. Such applicable requirements are included and are specifically identified in the permit; or
 - b. The director, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the source, and the permit includes the determination or a concise summary thereof.

2. A Title V permit that does not expressly state that a permit shield exists shall be presumed not to provide such a shield.
3. A permit shield shall not alter or affect the following:
 - a. The provisions of Section 303 of the Act (emergency orders), including the authority of the administrator under that section;
 - b. The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance;
 - c. The applicable requirements of the acid rain program, consistent with Section 408(a) of the Act;
 - d. The ability of the department or the administrator to obtain information from the facility pursuant to Section 114 of the Act. *567 IAC 22.108 (18)*

G26. Severability

The provisions of this permit are severable and if any provision or application of any provision is found to be invalid by this department or a court of law, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected by such finding. *567 IAC 22.108 (8) and LCO Sec. 1-7*

G27. Property Rights

The permit does not convey any property rights of any sort, or any exclusive privilege. *567 IAC 22.108 (9)"d"*

G28. Transferability

This permit is not transferable from one source to another. If title to the facility or any part of it is transferred, an administrative amendment to the permit must be sought consistent with the requirements of *567 IAC 22.111(1). 567 IAC 22.111 (1)"d"*

G29. Disclaimer

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions. *567 IAC 22.3(3)"c"*

G30. Notification and Reporting Requirements for Stack Tests or Monitor Certification

The permittee shall notify the department's stack test contact in writing not less than 30 days before a required test or performance evaluation of a continuous emission monitor is performed to determine compliance with applicable requirements of 567 – Chapter 23 or a permit condition. Such notice shall include the time, the place, the name of the person who will conduct the test and other information as required by the department. If the owner or operator does not provide timely notice to the department, the department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with applicable rules or permit conditions. Upon written request, the department may allow a notification period of less than 30 days. At the department's request, a pretest meeting shall be held not later than 15 days prior to conducting the compliance demonstration. A testing protocol shall be submitted to the department no later than 15 days before the owner or operator conducts the compliance demonstration. A representative of the department shall be permitted to witness the tests. Results of the tests shall be submitted in writing to the department's stack test contact in the form of a comprehensive report within six weeks of the completion of the testing. Compliance tests conducted pursuant to this permit shall be conducted with the source operating in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which the source shall be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the equipment manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the department that the source has been physically altered so that capacity cannot be exceeded, or the department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the department to determine whether such source is in compliance.

Stack test notifications, reports and correspondence shall be sent to:

Stack Test Review Coordinator
Iowa DNR, Air Quality Bureau
Wallace State Office Building
502 E 9th St.
Des Moines, IA 50319-0034
(515) 725-9526

Within Linn County, stack test notifications, reports and correspondence shall also be directed to the supervisor of the county air pollution program.

567 IAC 25.1(7)"a", 567 IAC 25.1(9) and LCO Sec. 10-70

G31. Prevention of Air Pollution Emergency Episodes

The permittee shall comply with the provisions of 567 IAC Chapter 26 in the prevention of excessive build-up of air contaminants during air pollution episodes, thereby preventing the occurrence of an emergency due to the effects of these contaminants on the health of persons. *567 IAC 26.1(1)*

G32. Contacts List

The current address and phone number for reports and notifications to the EPA administrator is:

Iowa Compliance Officer
Air Branch
Enforcement and Compliance Assurance Division
U.S. EPA Region 7
Air Permits and Compliance Branch
11201 Renner Blvd.
Lenexa, KS 66219
(913) 551-7020

The current address and phone number for reports and notifications to the department or the Director is:

Chief, Air Quality Bureau
Iowa Department of Natural Resources
Wallace State Office Building
502 E 9th St.
Des Moines, IA 50319-0034
(515) 725-8200

Reports or notifications to the Linn County local program shall be directed to the supervisor at the Linn County local program. The current address and phone number is:

Linn County Public Health
Air Quality Division
1020 6th Street SE
Cedar Rapids, IA 52401
(319) 892-6000

V. APPENDIX A – Applicable Federal Standards

[40 CFR 60 Subpart A](#) – *General Provisions*

[40 CFR 60 Subpart IIII](#) – *Standards of Performance for Stationary Compression Ignition Internal Combustion Engines*

[40 CFR 60 Subpart JJJJ](#) – *Standards of Performance for Stationary Spark Ignition Internal Combustion Engines*

A listing of all the promulgated NSPS rules, EPA Region 7 staff contact information (for questions pertaining to the rule), compliance assistance links and a link to each NSPS can be found at the link below:

<https://www.epa.gov/caa-permitting/air-technology-standards-region-7>

[40 CFR 63 Subpart A](#) – *General Provisions*

[40 CFR 63 Subpart Q](#) – *National Emission Standards for Hazardous Air Pollutants for Industrial Process Cooling Towers*

[40 CFR 63 Subpart CCCC](#) - *National Emission Standards for Hazardous Air Pollutants: Manufacturing of Nutritional Yeast*

[40 CFR 63 Subpart ZZZZ](#) - *National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines*

A listing of all the promulgated MACT rules, EPA Region 7 staff contact information (for questions pertaining to the rule), compliance assistance links and a link to each NSPS can be found at the link below:

<https://www.epa.gov/caa-permitting/air-technology-standards-region-7>

V. APPENDIX B – CAM Plans Summary

There are no emission units subject to a CAM plan in this renewal permit.

V. APPENDIX C – Facility O&M Plans Summary

The following emission units are subject to a facility O&M plan:

EP	EU ID	EU Description
7.1	07.1	Nutritional Yeast Dryer
7.2	07.2	Nutritional Yeast Dryer
7.3	07.4	Nutritional Yeast Dryer ¹
	07.5	Nutritional Yeast Dryer ¹
C2.1	C2.1	Pneumatic Conveyor #1 ¹
PL5.1	PL5.1	Packaging Line #1 ¹

¹ Facility operation and maintenance plans are to be developed by the facility within six (6) months of the issuance date of this permit for EU(s) 07.4, 07.5, C2.1 and PL5.1.

Facility operation and maintenance plans must be sufficient to yield reliable data from the relevant time period that are representative of the source's compliance with the applicable requirements.

The data pertaining to the plan shall be maintained on site for at least 5 years. The plan and associated recordkeeping provides documentation of this facility's implementation of its obligation to operate according to good air pollution control practice.

Good air pollution control practice is achieved by adoption of quality control standards in the operation and maintenance procedures for air pollution control that are comparable to industry quality control standards for the production processes associated with these emission points.

Authority for Requirement: 567 IAC 22.108(3)

V. APPENDIX D – Opacity Monitoring Summary

Opacity Monitoring

The facility shall check the opacity weekly during a period when the emission unit(s) associated with the emission point listed in Opacity Monitoring Tables 1 or 2 is operating at or near full capacity and record the reading. Maintain a written record of the observation and any action resulting from the observation for a minimum of five years. Opacity shall be observed to ensure that no visible emissions occur during the material handling operation of the unit. If visible emissions are observed corrective action will be taken as soon as possible, but no later than eight hours from the observation of visible emissions. If corrective action does not return the observation to no visible emissions, then a Method 9 observation will be required.

If an opacity >20 % is observed from an emission point listed in Opacity Monitoring Table 1, this would be a violation and corrective action will be taken as soon as possible, but no later than eight hours from the observation of visible emissions. If weather conditions prevent the observer from conducting an opacity observation, the observer shall note such conditions on the data observation sheet. At least three attempts shall be made to retake opacity readings at approximately 2-hour intervals throughout the day. If all observation attempts for a week have been unsuccessful due to weather, an observation shall be made the next operating day where weather permits.

Opacity Monitoring Table 1.

Emission Point														
1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.10	2.1	3.1	39.15	39.16	43.3	43.4
7.1	7.2	7.3	S1.1	C2.1	B3.1	BD4.1	PL5.1	BU8.1						

If an opacity >10 % is observed from an emission point listed in Opacity Monitoring Table 2, this would be a violation and corrective action will be taken as soon as possible, but no later than eight hours from the observation of visible emissions. If weather conditions prevent the observer from conducting an opacity observation, the observer shall note such conditions on the data observation sheet. At least three attempts shall be made to retake opacity readings at approximately 2-hour intervals throughout the day. If all observation attempts for a week have been unsuccessful due to weather, an observation shall be made the next operating day where weather permits.

Opacity Monitoring Table 2.

39.10	39.11	39.12	39.13	39.14
-------	-------	-------	-------	-------

Authority for Requirement: 567 IAC 22.108(14)

V. APPENDIX E – Stack Testing Summary

EP	EU Description	Pollutant	Compliance Methodology	Completion Deadline	Test Method

No source testing is required.

Authority for Requirement: 567 IAC 22.108(3)