



### Voltage and Amperage Rectifier Readings

(for impressed current systems)

Month/Year Cathodic Protection System Installed: \_\_\_\_\_ / \_\_\_\_\_

UST FACILITY			
Name:			Registration No:
Address:			LUST No:
City:	ZIP:	Phone:	

	Amperes	Voltage	Date
Initial Rectifier Settings			
Rectifier Adjustment			
Rectifier Adjustment			

Report any change in voltage or amperage immediately to your supervisor and corrosion protection expert. Any change could indicate a problem with the cathodic protection system. **All repairs or adjustments must be made by a corrosion expert as soon as possible.**

#### Every 60 Day Meter Readings (monthly recommended)

Date	Amperes	Voltage	Name