

**Iowa Department of Natural Resources
Title V Operating Permit**

Name of Permitted Facility: WDC Acquisition LLC
Facility Location: 1746 Commerce Road, Creston, IA 50801
Air Quality Operating Permit Number: 99-TV-018R4-M001
Expiration Date: 10/19/2027
Permit Renewal Application Deadline: 4/19/2027

EIQ Number: 92-5380
Facility File Number: 88-01-002

Responsible Official

Name: Ralph Clendenin
Title: Chief Operating Officer
Mailing Address: 1746 Commerce Road, Creston, IA 50801
Phone #: (641) 782-0210

Permit Contact Person for the Facility

Name: Matt Thelen
Title: Environmental Engineer
Mailing Address: 1746 Commerce Road, Creston, IA 50801
Phone #: (641) 782-0283

This permit is issued in accordance with 567 Iowa Administrative Code Chapter 22, and is issued subject to the terms and conditions contained in this permit.

For the Director of the Department of Natural Resources

Marnie Stein

03/21/2024

Marnie Stein, Supervisor of Air Operating Permits Section

Date

Table of Contents

I. Facility Description and Equipment List	4
II. Plant - Wide Conditions.....	7
III. Emission Point Specific Conditions	13
IV. General Conditions.....	61
G1. Duty to Comply	
G2. Permit Expiration	
G3. Certification Requirement for Title V Related Documents	
G4. Annual Compliance Certification	
G5. Semi-Annual Monitoring Report	
G6. Annual Fee	
G7. Inspection of Premises, Records, Equipment, Methods and Discharges	
G8. Duty to Provide Information	
G9. General Maintenance and Repair Duties	
G10. Recordkeeping Requirements for Compliance Monitoring	
G11. Evidence used in establishing that a violation has or is occurring.	
G12. Prevention of Accidental Release: Risk Management Plan Notification and Compliance Certification	
G13. Hazardous Release	
G14. Excess Emissions and Excess Emissions Reporting Requirements	
G15. Permit Deviation Reporting Requirements	
G16. Notification Requirements for Sources That Become Subject to NSPS and NESHAP Regulations	
G17. Requirements for Making Changes to Emission Sources That Do Not Require Title V Permit Modification	
G18. Duty to Modify a Title V Permit	
G19. Duty to Obtain Construction Permits	
G20. Asbestos	
G21. Open Burning	
G22. Acid Rain (Title IV) Emissions Allowances	
G23. Stratospheric Ozone and Climate Protection (Title VI) Requirements	
G24. Permit Reopenings	
G25. Permit Shield	
G26. Severability	
G27. Property Rights	
G28. Transferability	
G29. Disclaimer	
G30. Notification and Reporting Requirements for Stack Tests or Monitor Certification	
G31. Prevention of Air Pollution Emergency Episodes	
G32. Contacts List	
V. Appendix A: Operation & Maintenance Plans and CAM Plan	75
VI. Appendix B: NESHAP.....	76

Abbreviations

acfm.....	actual cubic feet per minute
CFR.....	Code of Federal Regulation
CE	control equipment
CEM.....	continuous emission monitor
°F.....	degrees Fahrenheit
EIQ.....	emissions inventory questionnaire
EP	emission point
EU	emission unit
gr./dscf	grains per dry standard cubic foot
IAC.....	Iowa Administrative Code
IDNR.....	Iowa Department of Natural Resources
MVAC.....	motor vehicle air conditioner
NAICS.....	North American Industry Classification System
NSPS	new source performance standard
ppmv	parts per million by volume
lb./hr	pounds per hour
lb./MMBtu	pounds per million British thermal units
SCC.....	Source Classification Codes
scfm.....	standard cubic feet per minute
SIC	Standard Industrial Classification
TPY	tons per year
USEPA.....	United States Environmental Protection Agency

Pollutants

PM.....	particulate matter
PM ₁₀	particulate matter ten microns or less in diameter
SO ₂	sulfur dioxide
NO _x	nitrogen oxides
VOC	volatile organic compound
CO.....	carbon monoxide
HAP.....	hazardous air pollutant

I. Facility Description and Equipment List

Facility Name: WDC Acquisition LLC

Permit Number: 99-TV-018R4-M001

Facility Description: Aluminum Foundries (SIC 3365)

Equipment List

Emission Point Number	Emission Unit Number	Emission Unit Description	IDNR Construction Permit Number
1	1-1	OMCO Mixer	85-A-055-S9
	6-1	450 Mixer	
	15-1	Palmer Mixer	
	16-1	250 Mixer	
	28-1	Wheelabrator Shot Blast Cabinet	
1A	15-1	Palmer Mixer	07-A-735-S5
2	2-1	South Bench Core Station	99-A-576-S7
	2-2	SANBLO Core Station	
	82-1	Gaylord Core Blower	
	91-1	CB-10 Blower	
	92-1	CB-5 Blower	
3	71-1	Silo A	99-A-144-S4
	72-1	Silo B	
5	18-1	Chill Spray Booth	99-A-784-S6
10	29-1	EDC Mixer	88-A-040-S5
	68-1	EDC Silo G	
	81-1	Inhibitor Tumbler	
11	34-1	Laempe Core Blower	99-A-145-S7
	35-1	Laempe Core Blower	
12	36-1	West Pattern Room Wood Working	99-A-577
13	37-1	Outer Pattern Room Wood Working	99-A-578
14	39-1	Wheelabrator Blast Cabinet	85-A-054-S4
18	45-2	Wheelabrator Blast Cabinet	01-A-771-S3
	55-1	Pangborn Mini Cabinet	
19A 19B	57-1a	Acid Dip Tank 1	07-A-738-S3 07-A-739-S3
	57-1b	Acid Dip Tank 2	
	57-1c	Acid Dip Tank 3	
	57-1d	Acid Dip Tank 4	
	57-1f	Acid Dip Tank 6	
	57-1g	Acid Dip Tank 7	
	57-1h	Acid Dip Tank 8	
57-1i	Acid Dip Tank 9		
23	74-1	Silo E	99-A-146-S3
	75-1	Silo F	
23A	74-1	Silo E	04-A-039-S2

Emission Point Number	Emission Unit Number	Emission Unit Description	IDNR Construction Permit Number		
59	59-1	Welding Stations	99-A-147		
94	94-1	Silo C	21-A-130		
	95-1	Silo D			
97	97-1	Silo J	21-A-132-S1		
	98-1	Silo K			
96	96-1	Simpson Sand Reclaim	21-A-131-S1		
99	99-1	3D Core Printer	23-A-451		
EF-1	84-1 85-1	Metal Pouring Mold Cooling	07-A-741-S3		
EF-2			07-A-742-S3		
EF-3			07-A-743-S3		
EF-4			07-A-744-S3		
EF-5			07-A-745-S3		
EF-6			07-A-746-S3		
EF-7			07-A-747-S3		
EF-8			07-A-748-S3		
EF-9			12-A-040-S2		
EF-10			07-A-749-S3		
EF-11			07-A-750-S3		
EF-12			12-A-041-S2		
EF-35			12-A-042-S2		
EF-36			12-A-043-S2		
EF-13-1			86-1	Aluminum Melting (12 Crucible Furnaces)	23-A-051-S1
EF-14-1					23-A-052-S1
EF-15-1	23-A-053-S1				
EF-18	24-1	Magnesium/Aluminum Melting (8 Tilter Furnaces) (12 Pot Furnaces)	07-A-751-S5		
EF-19			07-A-752-S5		
EF-20			07-A-753-S5		
EF-21			07-A-754-S5		
EF-32			07-A-755-S5		
EF-24	EF-24	Heat Treat 1	07-A-756		
	EF-26	Heat Treat 2			
EF-26	EF-27	Heat Treat 3	07-A-757		
EF-27			07-A-758		

Emission Point Number	Emission Unit Number	Emission Unit Description	IDNR Construction Permit Number
BLDG F (Vent Internally) BLDG F (Vent Internally)	4-1	East Cell Mixer	07-A-759-S5
	38-1	Old Knockout	
	47-1	West Cell Mixer	
	50-1	Cleaning and Grinding Room	
	88-1	Tinker Omega Mixer	
	93-1	300 Mixer	

Insignificant Activities Equipment List

Insignificant Emission Unit Number	Insignificant Emission Unit Description
30-1*	Aluminum Melt Pressure Pourer
49-1*	Core Drying Oven
102-1*	Core Smoke Check
103-1*	Mudding Compound
104-1*	Core Coating
105-1*	Core Wash
106-1*	Mold Wash
107-1*	Electric Bakeout Oven
108-1*	Electric Bakeout Oven
109-1*	Zyglo Penetrant Dip
80-1*	Zyglo Powder Booth
EU NG	All Insignificant Natural Gas Units Combined (Individual units range from <1MMBtu to <10MMBtu/unit)

* Emission Units qualify for Small Unit Exemption under 567 IAC 22.1(2)"w". Records shall be kept in accordance with 567 IAC 22.1(2)"w"(3).

II. Plant-Wide Conditions

Facility Name: WDC Acquisition LLC

Permit Number: 99-TV-018R4-M001

Permit conditions are established in accord with 567 Iowa Administrative Code rule 22.108

Permit Duration

The term of this permit is: 5 years

Commencing on: 10/20/2022

Ending on: 10/19/2027

Amendments, modifications and reopenings of the permit shall be obtained in accordance with 567 Iowa Administrative Code rules 22.110 - 22.114. Permits may be suspended, terminated, or revoked as specified in 567 Iowa Administrative Code Rules 22.115.

Emission Limits

Unless specified otherwise in the Source Specific Conditions, the following limitations and supporting regulations apply to all emission points at this plant:

Opacity (visible emissions): 40% opacity

Authority for Requirement: 567 IAC 23.3(2)"d"

Sulfur Dioxide (SO₂): 500 parts per million by volume

Authority for Requirement: 567 IAC 23.3(3)"e"

Particulate Matter:

No person shall cause or allow the emission of particulate matter from any source in excess of the emission standards specified in this chapter, except as provided in 567 – Chapter 24. For sources constructed, modified or reconstructed on or after July 21, 1999, the emission of particulate matter from any process shall not exceed an emission standard of 0.1 grain per dry standard cubic foot of exhaust gas, except as provided in 567 – 21.2(455B), 23.1(455B), 23.4(455B) and 567 – Chapter 24.

For sources constructed, modified or reconstructed prior to July 21, 1999, the emission of particulate matter from any process shall not exceed the amount determined from Table I, or amount specified in a permit if based on an emission standard of 0.1 grain per standard cubic foot of exhaust gas or established from standards provided in 23.1(455B) and 23.4(455B).

Authority for Requirement: 567 IAC 23.3(2)"a"

Fugitive Dust: Attainment and Unclassified Areas - A person shall take reasonable precautions to prevent particulate matter from becoming airborne in quantities sufficient to cause a nuisance as defined in Iowa Code section 657.1 when the person allows, causes or permits any materials to be handled, transported or stored or a building, its appurtenances or a construction haul road to be used, constructed, altered, repaired or demolished, with the exception of farming operations or

dust generated by ordinary travel on unpaved roads. Ordinary travel includes routine traffic and road maintenance activities such as scarifying, compacting, transporting road maintenance surfacing material, and scraping of the unpaved public road surface. (the preceding sentence is State Only) All persons, with the above exceptions, shall take reasonable precautions to prevent the discharge of visible emissions of fugitive dusts beyond the lot line of the property on which the emissions originate. The public highway authority shall be responsible for taking corrective action in those cases where said authority has received complaints of or has actual knowledge of dust conditions which require abatement pursuant to this subrule. Reasonable precautions may include, but not be limited to, the following procedures.

1. Use, where practical, of water or chemicals for control of dusts in the demolition of existing buildings or structures, construction operations, the grading of roads or the clearing of land.
2. Application of suitable materials, such as but not limited to asphalt, oil, water or chemicals on unpaved roads, material stockpiles, race tracks and other surfaces which can give rise to airborne dusts.
3. Installation and use of containment or control equipment, to enclose or otherwise limit the emissions resulting from the handling and transfer of dusty materials, such as but not limited to grain, fertilizer or limestone.
4. Covering, at all times when in motion, open-bodied vehicles transporting materials likely to give rise to airborne dusts.
5. Prompt removal of earth or other material from paved streets or to which earth or other material has been transported by trucking or earth-moving equipment, erosion by water or other means.
6. Reducing the speed of vehicles traveling over on-property surfaces as necessary to minimize the generation of airborne dusts.

Authority for Requirement: 567 IAC 23.3(2)"c"

Pollutant: VOC

Emission Limit: 230.0 tpy⁽¹⁾

Authority for Requirement: DNR Construction Permit 99-A-576-S7, 99-A-784-S6, 88-A-040-S5, 99-A-145-S7, 85-A-055-S9, 07-A-735-S5, 07-A-738-S3, 07-A-739-S3, 07-A-741-S3, 07-A-742-S3, 07-A-743-S3, 07-A-744-S3, 07-A-745-S3, 07-A-746-S3, 07-A-747-S3, 07-A-748-S3, 07-A-749-S3, 07-A-750-S3, 12-A-040-S2, 12-A-041-S2, 12-A-042-S2, 12-A-043-S2, 07-A-759-S5, 23-A-451, 07-A-755-S5, 07-A-754-S5, 07-A-753-S5, 07-A-752-S5, 07-A-751-S5, 23-A-053-S1, 23-A-052-S1, 23-A-051-S1

⁽¹⁾This limit is a combined limit for all sources at the facility, excluding welding and natural gas combustion sources.

Pollutant: Single HAP

Emission Limit: 9.0 tpy⁽²⁾

Authority for Requirement: DNR Construction Permit listed above

Pollutant: Total HAP

Emission Limit: 22.0 tpy⁽²⁾

Authority for Requirement: DNR Construction Permit listed above

⁽²⁾Facility-wide emission limit of 9.0 tons and 22.0 for individual and cumulative HAP, respectively, per rolling 12-month period. This limit is a combined limit for all sources at the facility, excluding welding and natural gas combustion sources.

FACILITY-WIDE EMISSIONS LIMIT REQUIREMENTS

- A. The permittee (or owner or operator) shall maintain the following daily records:
 - (1) The identification of each VOC-containing or HAP-containing material used in all sources at this facility, excluding welding and natural gas combustion sources.
 - (2) The VOC and HAP content of each VOC-containing or HAP-containing material used in all sources at this facility, excluding welding and natural gas combustion sources.
 - (3) The amount of each VOC-containing or HAP-containing material used in all sources at this facility, excluding welding and natural gas combustion sources. For the purposes of calculating emissions, the material may be considered completely used on the day the materials are delivered to the facility or to the production line.
- B. The permittee (or owner or operator) shall maintain the following records for each VOC-containing or HAP-containing material used in all sources at this facility, excluding welding and natural gas combustion sources.
 - (1) Calculate and record the HAP emitted in weight percent for each Part I, Part II, and Part III Binder, or similar material, used in the Mold and Core making Operations. The amount of HAP should be determined by the MSDS or vendor technical data sheet. The HAP emissions from formaldehyde, furan, polyether polyol, and phenol can be assumed to be 95% reacted with the remaining 5% emitted. HAP emissions from diisocyanates can be assumed to be 99% reacted with the remaining 1% emitted. For these compounds, the permittee shall use the maximum content specified by the manufacturer on the MSDS or product specification sheet. For all other compounds, the permittee shall assume that 100% of the HAP is emitted.
 - (2) Calculate and record the VOC emitted in weight percent for each Part I, Part II, and Part III Binder or similar material used in the Mold and Core making Operations. The amount of VOC emitted shall be calculated by using the equation given below. If the equation does not apply the permittee shall assume that 100% of the VOC in the material is emitted:

$$E_{VOC} = VOC_{TOTAL} - (VOC_{PHENOL} + VOC_{FORMALDEHYDE} + VOC_{POLYETHER\ POLYOL} + VOC_{FURAN} + VOC_{ISOCYANATES})$$

Where,

E_{VOC} = Amount of VOC and HAP emitted in weight percent from the Part I, Part II, or Part III Binder, or similar material

VOC_{TOTAL} = Total VOC content of the Part I, Part II, or Part III Binder, or similar material, in weight percent using the maximum content specified by the manufacturer on the MSDS or product specification sheet

VOC_{PHENOL} = Percent by weight of Phenol and/or Phenolic Resin x 0.95

(When calculating VOC_{PHENOL} , the permittee shall use the minimum content on any range specified on the MSDS or product specification sheet)

Based on U.S. EPA’s National Emission Standards for Hazardous Air Pollutants (NESHAP) for Iron and Steel Foundries – Background Information for Proposed Standards (EPA 453/R-02-013), December 2002

$VOC_{FORMALDEHYDE}$ = Maximum percent by weight of Formaldehyde x 0.95

(When calculating $VOC_{\text{FORMALDEHYDE}}$, the permittee shall use the minimum content on any range specified on the MSDS or product specification sheet)

Based on U.S. EPA's National Emission Standards for Hazardous Air Pollutants (NESHAP) for Iron and Steel Foundries – Background Information for Proposed Standards (EPA 453/R-02-013), December 2002 $VOC_{\text{POLYETHER POLYOL}} = \text{Percent by weight of Polyether Polyol} \times 0.95$

(When calculating $VOC_{\text{POLYETHER POLYOL}}$, the permittee shall use the minimum content on any range specified on the MSDS or product specification sheet)

Based on binder manufacturer's data

$VOC_{\text{FURAN}} = \text{Maximum percent by weight of Furan Resin} \times 0.95$

(When calculating VOC_{FURAN} , the permittee shall use the minimum content on any range specified on the MSDS or product specification sheet)

Based on U.S. EPA's National Emission Standards for Hazardous Air Pollutants (NESHAP) for Iron and Steel Foundries – Background Information for Proposed Standards (EPA 453/R-02-013), December 2002

$VOC_{\text{ISOCYANATES}} = \text{Maximum percent by weight of Isocyanates} \times 0.99$

(When calculating $VOC_{\text{ISOCYANATES}}$, the permittee shall use the minimum content on any range specified on the MSDS or product specification sheet)

Based on U.S. EPA's National Emission Standards for Hazardous Air Pollutants (NESHAP) for Iron and Steel Foundries – Background Information for Proposed Standards (EPA 453/R-02-013), December 2002

- (3) The facility may not take credit for any other reductions of VOC or HAP emissions from Mold and Core making Operations at the facility without further evaluation by the department.
 - (4) Record the VOC and HAP content in weight percent for all other VOC-containing and HAP-containing materials used at this facility, excluding welding and natural gas combustion sources. The facility shall assume that 100% of the VOC and HAP in these materials are emitted.
- C. The facility may apply a control efficiency of 98% for Amine emissions that are controlled by the scrubbers CE-11. The facility shall assume all of the Amine is emitted when it is emitted through EP-2.
- D. The facility shall calculate the VOC and HAP emissions that occur during the pouring, cooling, and shakeout operations. The facility shall calculate the emissions using the most recent and relevant emissions factors available.
- E. The owner or operator shall maintain the following monthly records:
- (1) The identification of each VOC-containing or HAP-containing material used in all sources at this facility, excluding welding and natural gas combustion sources.
 - (2) The amount of each VOC-containing or HAP-containing material used in all sources at this facility, excluding welding and natural gas combustion sources. For the purposes of calculating emissions, all VOC or HAP may be considered emitted on the day the materials are delivered to the facility or to the production line.

SINGLE HAP EMISSIONS

- F. The total amount for each Single HAP (SHAP) emitted from all sources at this facility (88-01-002); excluding welding and natural gas combustion sources, shall not exceed 9.0 tons

in any 12-month rolling period. All HAP-containing materials used in these sources at the facility shall be included in the emissions calculations.

- 1) The owner or operator shall record the total amount, in tons, of each individual HAP emitted from all sources at this facility; excluding welding and natural gas combustion sources, on a monthly basis. All chlorine used in the magnesium melt process shall be assumed to be emitted.
 - 2) The owner or operator shall calculate and record the 12-month rolling total amount, in tons, of each individual HAP emitted from all sources at this facility; excluding welding and natural gas combustion sources, on a monthly basis.
- G. If the 12-month rolling total amount of any single HAP emitted from all sources at this facility (88-01-002); excluding welding and natural gas combustion sources, exceeds 7.2 tons, the permittee shall immediately begin keeping the following daily records:
- 1) The amount of emissions of each individual HAP from all sources at this facility, excluding welding and natural gas combustion sources, in tons.
 - 2) The 365-day rolling total of the amount of emissions of each individual HAP from all sources at this facility, excluding welding and natural gas combustion sources, in tons.
 - 3) Daily calculations for individual HAP emissions shall continue until the 365-day rolling total of the amount of individual HAP emissions from all sources at this facility, excluding welding and natural gas combustion sources, drops below 7.2 tons for the remainder of the current calendar month plus one additional calendar month. At that time, rolling daily calculation of individual HAP emissions will cease per Section F, above. If the emissions once again exceed 7.2 tons, daily recordkeeping will be required per Section G, above.

TOTAL HAP EMISSIONS

- H. The total amount all cumulative HAP (THAP) emitted from all sources at this facility (88-01-002); excluding welding and natural gas combustion sources, shall not exceed 22.0 tons in any 12-month rolling period. All HAP-containing materials used in these sources at the facility shall be included in the emissions calculations.
- 1) The owner or operator shall record the total amount, in tons, of total HAP emitted from all sources at this facility; excluding welding and natural gas combustion sources, on a monthly basis.
 - 2) The owner or operator shall calculate and record the 12-month rolling total amount, in tons, of total HAP emitted from all sources at this facility; excluding welding and natural gas combustion sources, on a monthly basis.
- I. If the 12-month rolling total amount of total HAP emitted from all sources at this facility (88-01-002); excluding welding and natural gas combustion sources, exceeds 17.6 tons, the permittee shall immediately begin keeping the following daily records:
- 1) The amount of all cumulative HAP emissions from all sources at this facility, excluding welding and natural gas combustion sources, in tons.
 - 2) The 365-day rolling total amount of cumulative HAP emissions from all sources at this facility, excluding welding and natural gas combustion sources, in tons.
 - 3) Daily calculations for total HAP emissions shall continue until the 365-day rolling total of the amount of total HAP emissions from all sources at this facility, excluding welding and natural gas combustion sources drops below 17.6 tons for the remainder of the current calendar month plus one additional calendar month. At that time,

rolling daily calculation of total HAP emissions will cease per Section I, above. If the emissions once again exceed 7.2 tons, daily recordkeeping will be required per Section I, above.

- J. The permittee may take credit for any waste HAP shipped off-site. The permittee shall record the amount of the waste shipped off-site each day, and analyze the HAP (Single and/or Total) content of the waste once every calendar quarter. The sample analyzed shall be taken as a representative sample (as defined in 40 CFR §260.10) of the waste sent off-site for that quarter and shall be used as representative until the subsequent quarter's analysis is received. The credit (calculated from the most current analysis and the amount shipped off-site) may be subtracted from the HAP (Single and/or Total) rolling totals as of the date the waste is shipped off-site.
- K. The permittee shall maintain the Material Safety Data Sheets (MSDS) for each VOC-containing or HAP-containing material used at the facility.

Authority for Requirement: DNR Construction Permit 99-A-576-S7, 99-A-784-S6, 88-A-040-S5, 99-A-145-S7, 85-A-055-S9, 07-A-735-S5, 07-A-738-S3, 07-A-739-S3, 07-A-741-S3, 07-A-742-S3, 07-A-743-S3, 07-A-744-S3, 07-A-745-S3, 07-A-746-S3, 07-A-747-S3, 07-A-748-S3, 07-A-749-S3, 07-A-750-S3, 12-A-040-S2, 12-A-041-S2, 12-A-042-S2, 12-A-043-S2, 07-A-759-S5, 23-A-451, 07-A-755-S5, 07-A-754-S5, 07-A-753-S5, 07-A-752-S5, 07-A-751-S5, 23-A-053-S1, 23-A-052-S1, 23-A-051-S1

NESHAP

This facility is subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) Subpart ZZZZZZ – Area Source Standards for Aluminum, Copper, and Other Nonferrous Foundries (40 CFR §63.11544 through 40 CFR §63.11558) as this facility meets the definition of an area source aluminum foundry.

Per 40 CFR Part 63.11550(a)(1) through (3) the facility must cover or enclose melting furnaces during the melting process, purchase scrap that has been depleted of hazardous metals to the extent possible, and prepare and operate according to a written management practices plan. The facility must also keep the records specified in paragraphs 40 CFR Part 63.11553(c), (d), and (e).

Authority for Requirement: 40 CFR 63 Subpart ZZZZZZ
567 IAC 23.1(4)"ez"

III. Emission Point-Specific Conditions

Facility Name: WDC Acquisition LLC
 Permit Number: **99-TV-018R4-M001**

Emission Point ID Number: 1 & 1a

Associated Equipment

Emission Point	Emission Unit	Emission Unit Description	Control Equipment	Raw Material	Rated Capacity	Construction Permit
EP-1	1-1	OMCO Mixer	CE-1-1: Baghouse	New Sand	0.166 tons/hr	85-A-055-S9
	6-1	450 Mixer		Sand/Binder	30.4 tons/hr	
	15-1	Palmer Mixer		Sand/Binder	20.8 tons/hr	
	16-1	250 Mixer		Sand/Binder	16.9 tons/hr	
	28-1	Wheelabrator Shot Blast Cabinet		Grit Blast	0.002 ton/hr	
EP-1a	15-1	Palmer Mixer	CE-1A: Baghouse	Sand/Binder	20.8 ton/hr	07-A-735-S5

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from each emission point shall not exceed the levels specified below.

EP-1 and EP-1a:

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permit 85-A-055-S9 and 07-A-735-S5
 567 IAC 23.3(2)"d"

⁽¹⁾ An exceedance of the indicator opacity of 10% will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.05 gr/dscf

Authority for Requirement: DNR Construction Permit 85-A-055-S9 and 07-A-735-S5
 567 IAC 23.4(6)

See Plant-Wide Conditions for VOC and HAP Emission Limits.

EP-01 only:

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.79 lb/hr

Authority for Requirement: DNR Construction Permit 85-A-055-S9

Pollutant: PM₁₀

Emission Limit(s): 0.79 lb/hr

Authority for Requirement: DNR Construction Permit 85-A-055-S9

EP-01a only:

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.26 lb/hr

Authority for Requirement: DNR Construction Permit 07-A-735-S5

Pollutant: PM₁₀

Emission Limit(s): 0.26 lb/hr

Authority for Requirement: DNR Construction Permit 07-A-735-S5

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner.

The operating requirements and associated recordkeeping for this permit shall be:

1. The owner or operator shall be limited to a combined input maximum capacity of 23 tons/hour of sand for OMCO Mixer (EU1-1), 450 Mixer (EU6-1), Palmer Mixer (EU15-1), and 250 Mixer (EU16-1). The owner or operator shall daily:
 - A. Record the amount of sand, in tons, used by each mixer;
 - B. Record the number of hours each mixer operated; and,
 - C. Calculate and record the maximum capacity in tons/hour for each mixer and sum the capacities to ensure the maximum capacity is not exceeded.
2. The facility shall maintain a differential pressure drop across the baghouse (CE-1-1) between 2.0 and 6.0 inches of water column (WC).
 - A. The owner or operator shall properly install, operate, and maintain equipment to continuously monitor the pressure drop of the baghouse (CE-1-1). The monitoring devices and any recorders shall be installed, calibrated, operated and maintained in accordance with the manufacturer's recommendations, instructions and operating manual or per a written facility-specific operation and maintenance plan.
 - I. The owner or operator shall collect and record the differential pressure across the baghouse, at a minimum, once per day when the emission unit the baghouse controls is in operation.
 - II. If the differential pressure across the baghouse falls outside the permitted range allowed (2.0" – 6.0" WC), then the facility shall record the time, date and actions taken to correct the situation and when the differential pressure across the baghouse is back with the permitted range allowed.

3. The facility shall conduct visible emissions observation (opacity) on bin vent (CE1-1a) once per calendar day.
 - A. The owner or operator shall collect and record the visible emissions observations.
 - B. If visible emissions are observed, the owner or operator shall investigate bin vent (CE1-1a) and make corrections to bin vent (CE1-1a). The owner or operator shall maintain a record of all corrective actions taken on each baghouse.
 - C. This requirement shall not apply on the days bin vent (CE1-1a) is not in operation.
 4. The owner or operator shall inspect and maintain the baghouse (CE-1-1) and bin vent (CE-1-1a) according to the facility's (Plant No. 88-01-002) operation and maintenance plan or manufacturer's specifications.
 - A. The owner or operator shall keep a log of all maintenance and inspection activities performed on the control equipment. At a minimum, this log shall include:
 - I. The date any inspection and/or maintenance was performed on the control equipment;
 - II. Any issues identified during the inspection; and,
 - III. Any issues addressed during the maintenance activities.
 5. See Plant-Wide Conditions listed for additional applicable requirements.
- Authority for Requirement: DNR Construction Permit 85-A-055-S9 and 07-A-735-S5

Emission Point Characteristics

The emission points shall conform to the specifications listed below.

Emission Point	EP-1	EP-1a
Stack Height, (ft, from the ground)	30	33
Stack Opening, (inches)	16 x 20	8
Exhaust Flow Rate (scfm)	8000	1500
Exhaust Temperature (°F)	70	70
Discharge Style	Vertical Unobstructed	Downward
Construction Permit	85-A-055-S9	07-A-735-S5

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

EP-1a qualifies for CAM. However, the conditions listed in the Operating Requirements of the construction permit meet the requirements of CAM.

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 2Associated Equipment

Emission Unit	Emission Unit Description	Raw Material	Rated Capacity	Construction Permit
2-1	South Bench Core Stations	Sand/Binders	0.145 tons/hr sand	99-A-576-S7
2-2	SANBLO Core Station	Sand/Binders	0.0141 ton/hr sand	
82-1	Gaylord Core Blower	Sand/Binders	4.2 tons/hr	
91-1	CB-10 Blower	Sand/Binders	0.17 tons/hr	
92-1	CB-5 Blower	Sand/Binders	0.17 tons/hr	

Applicable Requirements**Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permit 99-A-576-S7
567 IAC 23.3(2)"d"

⁽¹⁾An exceedance of the indicator opacity of 10% will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.05 gr/dscf, 0.82 lb/hr

Authority for Requirement: DNR Construction Permit 99-A-576-S7
567 IAC 23.4(6)

Pollutant: PM₁₀

Emission Limit(s): 0.82 lb/hr

Authority for Requirement: DNR Construction Permit 99-A-576-S7

See Plant-Wide Conditions for VOC and HAP Emission Limits.

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner.

- 1. Refer to Plant-Wide Conditions for additional applicable requirements.
Authority for Requirement: DNR Construction Permit 99-A-576-S7

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 35
Stack Opening, (inches, dia.): 28 x 24
Exhaust Flow Rate (scfm): 8,150
Exhaust Temperature (°F): 70
Discharge Style: Vertical Unobstructed
Authority for Requirement: DNR Construction Permit 99-A-576-S7

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

- Agency Approved Operation & Maintenance Plan Required?** Yes No
- Facility Maintained Operation & Maintenance Plan Required?** Yes No
- Compliance Assurance Monitoring (CAM) Plan Required?** Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 3

Associated Equipment

Emission Unit	Emission Unit Description	Control Equipment	Raw Material	Rated Capacity	Construction Permit
71-1	Sand Silo A	CE-4-1: Bag Filters	New Sand	129 tons & 3.6 tons/hr	99-A-144-S4
72-1	Sand Silo B		New Sand	120 tons & 10.0 tons/hr	

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permit 99-A-144-S4
567 IAC 23.3(2)"d"

⁽¹⁾ An exceedance of the indicator opacity of 10% will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/scf, 0.13 lb/hr

Authority for Requirement: DNR Construction Permit 99-A-144-S4
567 IAC 23.3(2)"a"

Pollutant: PM₁₀

Emission Limit(s): 0.13 lb/hr

Authority for Requirement: DNR Construction Permit 99-A-144-S4

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner.

The operating requirements and associated recordkeeping for this permit shall be:

1. The facility shall weekly observe the emission point during material handling operations (i.e., the unit is in operation) to ensure no visible emissions are present. If visible emissions are observed, the facility shall initiate corrective action as soon as possible (i.e., operations are safely shutdown).

2. The owner or operator shall inspect and maintain the dust collector (CE-4-1) according to the facility's (Plant No. 88-01-002) operation and maintenance plan or manufacturer's specifications.
 - A. The owner or operator shall keep a log of all maintenance and inspection activities performed on the control equipment. At a minimum, this log shall include:
 - I. The date any inspection and/or maintenance was performed on the control equipment;
 - II. Any issues identified during the inspection; and,
 - III. Any issues addressed during the maintenance activities

Authority for Requirement: DNR Construction Permit 99-A-144-S4

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 16

Stack Opening, (inches.): 8 x 6

Exhaust Flow Rate (scfm): 500

Exhaust Temperature (°F): 70

Discharge Style: Horizontal

Authority for Requirement: DNR Construction Permit 99-A-144-S4

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 5Associated Equipment

Emission Unit	Emission Unit Description	Control Equipment	Raw Material	Rated Capacity	Construction Permit
18-1	Chill Spray Booth	CE5-1: Fabric Filter	Solvent	245 lb/hr	99-A-784-S6

Applicable Requirements**Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permit 99-A-784-S6
567 IAC 23.3(2)"d"

⁽¹⁾ An exceedance of the indicator opacity of No Visible Emissions will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.01 gr/scf, 0.30 lb/hr

Authority for Requirement: DNR Construction Permit 99-A-784-S6
567 IAC 23.4(13)

Pollutant: PM₁₀

Emission Limit(s): 0.30 lb/hr

Authority for Requirement: DNR Construction Permit 99-A-784-S6

See Plant-Wide Conditions for VOC and HAP Emission Limits.

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner.

1. Refer to Plant-Wide Conditions for applicable requirements.

Authority for Requirement: DNR Construction Permit 99-A-784-S6

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

- Stack Height, (ft, from the ground): 33
- Stack Opening, (inches): 11 x 16
- Exhaust Flow Rate (scfm): 3500
- Exhaust Temperature (°F): 70
- Discharge Style: Unobstructed vertical
- Authority for Requirement: DNR Construction Permit 99-A-784-S6

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Limit on Hours of Operation

This emission unit shall be limited to 2,000 hours of operation per 12-month rolling period. If this emission unit operates more than 2,000 hours per 12-month rolling period it will be required to stack test for PM and PM₁₀ with 90 day of exceeding the hour restriction.

This emission unit is required to record the hours of operation monthly and calculate a 12-month rolling total each month.

This condition was requested by the applicant.
Authority for Requirement: 567 IAC 22.108(14)

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No
See Appendix A.

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 10Associated Equipment

Emission Unit	Emission Unit Description	Control Equipment	Raw Material	Rated Capacity	Construction Permit
29-1	EDC Mixer	CE-2-1: Baghouse	Sand	7.4 tons/hr	88-A-040-S5
68-1	EDC Silo G		Sand	2 tons/hr	
81-1	Inhibitor Tumbler		Sand	0.3 tons/hr	

Applicable Requirements**Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permit 88-A-040-S5
567 IAC 23.3(2)"d"

⁽¹⁾ An exceedance of the indicator opacity of 10% will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.05 gr/dscf, 1.01 lb/hr

Authority for Requirement: DNR Construction Permit 88-A-040-S5
567 IAC 23.4(6)

Pollutant: PM₁₀

Emission Limit(s): 1.01 lb/hr

Authority for Requirement: DNR Construction Permit 88-A-040-S5

See Plant-Wide Conditions for VOC and HAP Emission Limits.

Operational Limits & Reporting/Record keeping Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below. Records shall be kept on site for at least five years and shall be available for inspection by the Department.

- A. The owner or operator shall operate and maintain the Baghouse (CE-2-1) according to the manufacturer's specifications. The owner or operator shall maintain a log of all inspection and maintenance activities. This log shall include, but is necessarily not

limited to:

- (1) The date and time any inspection and/or maintenance was performed on the Baghouse (CE-2-1);
- (2) Any issues identified during the inspection and the date each issue was resolved;
- (3) Any issues addressed during the maintenance activities and the date each issue was resolved; and
- (4) Identification of the staff member performing the maintenance or inspection.

Authority for Requirement: DNR Construction Permit 88-A-040-S5

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 13.5

Stack Opening, (inches): 18

Exhaust Flow Rate (scfm): 2,400

Exhaust Temperature (°F): 210

Discharge Style: Unobstructed vertical

Authority for Requirement: DNR Construction Permit 88-A-040-S5

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 11Associated Equipment

Emission Unit	Emission Unit Description	Control Equipment	Raw Material	Rated Capacity	Construction Permit
34-1	Laempe Core Blower	Packed Bed Gas Scrubber CE 11-1	Sand/Binder	1,350 lb/hr	99-A-145-S7
35-1	Laempe Core Blower		Sand/Binder	1,350 lb/hr	

Applicable Requirements**Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permit 99-A-145-S7
567 IAC 23.3(2)"d"

⁽¹⁾ An exceedance of the indicator opacity of No Visible Emissions will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.05 gr/scf, 0.22 lb/hr

Authority for Requirement: DNR Construction Permit 99-A-145-S7
567 IAC 23.4(6)

Pollutant: PM₁₀

Emission Limit(s): 0.22 lb/hr

Authority for Requirement: DNR Construction Permit 99-A-145-S7

See Plant-Wide Conditions for VOC and HAP Emission Limits.

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner.

The operating requirements and associated recordkeeping for this permit shall be:

1. The owner or operator shall install, operate, and maintain the scrubber (CE 11) according to manufacturer's specifications and maintenance schedule.
 - A. The permittee shall maintain a record of all inspections and maintenance and any action

resulting from the inspection and maintenance of the control equipment and the monitoring devices.

2. The owner or operator shall install, operate, and maintain a monitor (post- scrubber) to detect amine emissions according to the manufacturer’s specifications and maintenance schedule.
3. The permittee shall properly operate and maintain equipment to monitor the scrubbant pH. The monitoring devices and any recorders shall be installed, calibrated, operated and maintained in accordance with the manufacturer’s recommendations, instructions and operating manuals.
4. The scrubbant pH shall be maintained in the pH range specified by the manufacturer.
 - A. The permittee shall record the pH of the scrubbant, in standard units, once per day. This requirement shall not apply on the days that the scrubber or the equipment that the scrubber controls is not in operation.
5. Refer to Plant-Wide Conditions for additional applicable requirements.

Authority for Requirement: DNR Construction Permit 99-A-145-S7

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): Vents Inside Building

Stack Opening, (inches, dia.): Vents Inside Building

Exhaust Flow Rate (acfm): Vents Inside Building

Exhaust Temperature (°F): Vents Inside Building

Discharge Style: Vents Inside Building

Authority for Requirement: DNR Construction Permit 99-A-145-S7

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Numbers: 12 & 13

Associated Equipment

Emission Point	Emission Unit	Emission Unit Description	Control Equipment	Raw Material	Rated Capacity	Construction Permit
12	36-1	West Pattern Room Wood Working	CE14-1: Cyclone	Wood	200 lb/hr	99-A-577
13	37-1	Outer Pattern Room Wood Working	CE15-1: Baghouse	Wood	200 lb/hr	99-A-578

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from each emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permits 99-A-577 & 99-A-578
567 IAC 23.3(2)"d"

⁽¹⁾ An exceedance of the indicator opacity of (25%) will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing)

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/dscf

Authority for Requirement: DNR Construction Permits 99-A-577 & 99-A-578
567 IAC 23.3(2)"a"

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Control equipment parameters:

1. Maintain cyclone, 14-1 according to manufacturer's specifications and maintenance schedule.
2. Maintain baghouse, 15-1 and filter media according to manufacturer's specifications and maintenance schedule.

Reporting & Record keeping:

Records shall be kept on site for at least five years and shall be available for inspection by the Department.

1. Record on a monthly basis, all maintenance of cyclone, 14-1.
2. Record on a monthly basis, all maintenance of filter media and of baghouse, 15-1.

Authority for Requirement: DNR Construction Permits 99-A-577 & 99-A-578

Emission Point Characteristics

These emission points shall conform to the specifications listed below.

Emission Point	Stack Height, (ft, from the ground)	Stack Opening, (inches, dia.)	Exhaust Flow Rate (acfm)	Exhaust Temperature (°F)	Discharge Style	Authority for Requirement
12	20	8	2250	70	Vertical, obstructed	99-A-577
13	20	8	1200	70	Vertical, obstructed	99-A-578

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 14

Associated Equipment

Emission Unit	Emission Unit Description	Control Equipment	Raw Material	Rated Capacity	Construction Permit
39-1	Wheelabrator Blast Cabinet	CE8-1: Baghouse	Sand/Steelshot	10 tons/hr	85-A-054-S4

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permit 85-A-054-S4
567 IAC 23.3(2)"d"

⁽¹⁾ An exceedance of the indicator opacity of “no visible emissions” will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing)

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.05 gr/scf, 0.34 lb/hr

Authority for Requirement: DNR Construction Permit 85-A-054-S4
567 IAC 23.4(6)

Pollutant: PM₁₀

Emission Limit(s): 0.34 lb/hr

Authority for Requirement: DNR Construction Permit 85-A-054-S4

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner.

The operating requirements and associated recordkeeping for this permit shall be:

1. The owner or operator shall conduct daily visible emissions to ensure no visible emissions are emitted from Baghouse (CE8-1).
 - A. The owner or operator shall maintain a record of the daily visible emission observations from Baghouse (CE8-1) and any actions resulting from visible emission observations.

2. The owner or operator shall operate, inspect and maintain all the equipment associated with the process and the Baghouse (CE8-1) in accordance with manufacturer's specifications and maintenance schedule.

A. The owner or operator shall maintain a record of all inspections, maintenance activities, and any actions resulting from the inspection or maintenance of the Baghouse (CE8-1).

Authority for Requirement: DNR Construction Permit 85-A-054-S4

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 35

Stack Opening, (inches): 21 x 16

Exhaust Flow Rate (scfm): 7,500

Exhaust Temperature (°F): 110

Discharge Style: Vertical Unobstructed

Authority for Requirement: DNR Construction Permit 85-A-054-S4

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

See Appendix A.

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 18

Associated Equipment

Emission Unit	Emission Unit Description	Control Equipment	Raw Material	Rated Capacity	Construction Permit
45-2	Wheelabrator Blast Cabinet	CE3-1: Baghouse	Sand	0.875 tons/hr	01-A-771-S3
55-1	Pangborn Mini Cabinet		Sand/Castings	0.0002 tons/hr	

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permit 01-A-771-S3
567 IAC 23.3(2)"d"

⁽¹⁾ An exceedance of the indicator opacity of “no visible emissions” will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing)

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.05 gr/scf, 0.70 lb/hr

Authority for Requirement: DNR Construction Permit 01-A-771-S3
567 IAC 23.4(6)

Pollutant: PM₁₀

Emission Limit(s): 0.70 lb/hr

Authority for Requirement: DNR Construction Permit 01-A-771-S3

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner.

The operating requirements and associated recordkeeping for these permits shall be:

- 1. The owner or operator shall inspect and maintain the baghouse (CE-3-1) according to the facility’s (Plant No. 88-01-002) operation and maintenance plan or manufacturer’s specifications.
 - A. The owner or operator shall keep a log of all maintenance and inspection activities performed on the control equipment. At a minimum, this log shall include:
 - I. The date any inspection and/or maintenance was performed on the control equipment;
 - II. Any issues identified during the inspection; and,
 - III. Any issues addressed during the maintenance activities

Authority for Requirement: DNR Construction Permit 01-A-771-S3

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 30

Stack Opening, (inches): 30

Exhaust Flow Rate (scfm): 18,500

Exhaust Temperature (°F): 70

Discharge Style: Vertical Unobstructed

Authority for Requirement: DNR Construction Permit 01-A-771-S3

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

See Appendix A.

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: See Table: Acid Dip Tanks

Table: Acid Dip Tanks

Emission Point	Emission Unit	Emission Unit Description	Raw Material	Maximum Capacity (gal.)	Construction Permit Number
19A* 19B*	57-1a	Tank 1	5% Nitric Acid	859	07-A-738-S3 07-A-739-S3
	57-1b	Tank 2	Water	859	
	57-1c	Tank 3	20% Hydrofluoric Acid	859	
	57-1d	Tank 4	Water	859	
	57-1f	Tank 6	Water	859	
	57-1g	Tank 7	5% Nitric Acid & 5% Acetic Acid	859	
	57-1h	Tank 8	Water	982	
	57-1i	Tank 9	20% Hydrofluoric Acid	982	

* Note: The above 8 tanks emit to both stacks (19A & 19B).

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from each emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permits 07-A-738-S3 & 07-A-739-S3
567 IAC 23.3(2)"d"

⁽¹⁾ An exceedance of the indicator opacity of No Visible Emissions will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/scf, 0.20 lb/hr

Authority for Requirement: DNR Construction Permits 07-A-738-S3 & 07-A-739-S3
567 IAC 23.3(2)"a"

Pollutant: PM₁₀

Emission Limit(s): 0.20 lb/hr

Authority for Requirement: DNR Construction Permits 07-A-738-S3 & 07-A-739-S3

See Plant-Wide Conditions for VOC and HAP Emission Limits.

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner.

The operating requirements and associated recordkeeping for this permit shall be:

- 1. Refer to Plant-Wide Conditions for applicable requirements.

Authority for Requirement: DNR Construction Permits 07-A-738-S3 & 07-A-739-S3

Emission Point Characteristics

These emission points shall conform to the specifications listed below.

Emission Point	Stack Height, (ft, from the ground)	Stack Opening, (inches, dia.)	Exhaust Flow Rate (acfm)	Exhaust Temperature (°F)	Discharge Style	Authority for Requirement
19A	41	24	7500	70	Vertical, obstructed	07-A-738-S3
19B	41	24	7500	70	Vertical, obstructed	07-A-739-S3

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 23Associated Equipment

Emission Unit	Emission Unit Description	Control Equipment	Raw Material	Rated Capacity	Construction Permit
74-1	Silo E*	CE18-1: Baghouse	Sand	174 tons & 10 tons/hour (sand)	99-A-146-S3
75-1	Silo F		Sand	65 tons & 10 tons/hour (sand)	

*Silo E also exhausts through Emission Point 23A

Applicable Requirements**Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permit 99-A-146-S3
567 IAC 23.3(2)"d"

⁽¹⁾ An exceedance of the indicator opacity of 10% will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing)

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/dscf, 0.21 lb/hr

Authority for Requirement: DNR Construction Permit 99-A-146-S3
567 IAC 23.3(2)"a"

Pollutant: PM₁₀

Emission Limit(s): 0.21 lb/hr

Authority for Requirement: DNR Construction Permit 99-A-146-S3

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner.

1. The facility shall weekly observe the emission point during material handling operations (i.e., the unit is in operation) to ensure no visible emissions are present. If visible emissions are observed, the facility shall initiate corrective action as soon as possible (i.e., operations are safely shutdown).
2. The owner or operator shall inspect and maintain the baghouse (CE-18-1) according to the

facility's (Plant No. 88-01-002) operation and maintenance plan or manufacturer's specifications.

A. The owner or operator shall keep a log of all maintenance and inspection activities performed on the control equipment. At a minimum, this log shall include:

- I. The date any inspection and/or maintenance was performed on the control equipment;
- II. Any issues identified during the inspection; and,
- III. Any issues addressed during the maintenance activities

Authority for Requirement: DNR Construction Permit 99-A-146-S3

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 23.5

Stack Opening, (inches, dia.): 6

Exhaust Flow Rate (scfm): 500

Exhaust Temperature (°F): Ambient

Discharge Style: Horizontal

Authority for Requirement: DNR Construction Permit 99-A-146-S3

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 23AAssociated Equipment

Emission Unit	Emission Unit Description	Control Equipment	Raw Material	Rated Capacity	Construction Permit
74-1	Silo E*	CE18A: Dust Collector	Sand	174 tons & 10.0 tons/hour (sand)	04-A-039-S2

*Silo E also exhausts through Emission Point 23

Applicable Requirements**Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permit 04-A-039-S2
567 IAC 23.3(2)"d"

⁽¹⁾ Visible emissions will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/scf, 0.21 lb/hr

Authority for Requirement: DNR Construction Permit 04-A-039-S2
567 IAC 23.3(2)"a"

Pollutant: PM₁₀

Emission Limit(s): 0.21 lb/hr

Authority for Requirement: DNR Construction Permit 04-A-039-S2

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner.

1. The facility shall weekly observe the emission point during material handling operations (i.e., the unit is in operation) to ensure no visible emissions are present. If visible emissions are observed, the facility shall initiate corrective action as soon as possible (i.e., operations are safely shutdown).
2. The owner or operator shall inspect and maintain the baghouse (CE-18A) according to the facility's (Plant No. 88-01-002) operation and maintenance plan or manufacturer's

specifications.

A. The owner or operator shall keep a log of all maintenance and inspection activities performed on the control equipment. At a minimum, this log shall include:

- I. The date any inspection and/or maintenance was performed on the control equipment;
- II. Any issues identified during the inspection; and,
- III. Any issues addressed during the maintenance activities

Authority for Requirement: DNR Construction Permit 04-A-039-S2

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 58

Stack Opening, (inches, dia.): 6

Exhaust Flow Rate (scfm): 500

Exhaust Temperature (°F): Ambient

Discharge Style: Horizontal

Authority for Requirement: DNR Construction Permit 04-A-039-S2

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 59

Associated Equipment

Emission Unit	Emission Unit Description	Control Equipment	Raw Material	Rated Capacity	Construction Permit
59-1	Welding Stations	NA	Magnesium/Aluminum Alloys	200 lbs/hr	99-A-147

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permit 99-A-147
567 IAC 23.3(2)"d"

⁽¹⁾ An exceedance of the indicator opacity of 25% will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing)

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/dscf

Authority for Requirement: DNR Construction Permit 99-A-147
567 IAC 23.3(2)"a"

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 35

Stack Opening, (inches, dia.): 14

Exhaust Flow Rate (scfm): 1500

Exhaust Temperature (°F): Ambient

Authority for Requirement: DNR Construction Permit 99-A-147

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 94 & 97

Associated Equipment

Emission Point	Emission Unit	Emission Unit Description	Control Equipment	Raw Material	Rated Capacity	Construction Permit
EP94	94-1	Sand Silo C	CE-94-1: Bin Vent Filters	Sand	48 tons & 15 tons/hour	21-A-130
	95-1	Sand Silo D		Sand	48 tons & 15 tons/hour	
EP97	97-1	Sand Silo J	CE-97-1: Cartridge Filters	Sand	18 tons & 10 tons/hour	21-A-132-S1
	98-1	Sand Silo K		Sand	18 tons & 10 tons/hour	

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from each emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permits 21-A-130 & 21-A-132-S1
567 IAC 23.3(2)"d"

⁽¹⁾ An exceedance of the indicator opacity of 10% will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/scf, 0.26 lb/hr

Authority for Requirement: DNR Construction Permits 21-A-130 & 21-A-132-S1
567 IAC 23.3(2)"a"

Pollutant: PM₁₀

Emission Limit(s): 0.26 lb/hr

Authority for Requirement: DNR Construction Permits 21-A-130 & 21-A-132-S1

Pollutant: PM_{2.5}

Emission Limit(s): 0.26 lb/hr

Authority for Requirement: DNR Construction Permits 21-A-130 & 21-A-132-S1

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner.

The operating requirements and associated recordkeeping for this permit shall be:

- 1. The owner or operator shall inspect and maintain the dust collectors (CE-94-1 & CE-97-1) according to the facility’s (Plant No. 88-01-002) operation and maintenance plan or manufacturer’s specifications.
 - A. The owner or operator shall keep a log of all maintenance and inspection activities performed on the control equipment. At a minimum, this log shall include:
 - I. The date any inspection and/or maintenance was performed on the control equipment;
 - II. Any issues identified during the inspection; and,
 - III. Any issues addressed during the maintenance activities
 - IV. Identification of the staff member performing the maintenance or inspection*

*Requirement of DNR construction permit 21-A-132-S1 only

Authority for Requirement: DNR Construction Permits 21-A-130 & 21-A-132-S1

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

EP	Stack Height	Stack Opening	Exhaust Flow Rate (scfm)	Exhaust Temperature (°F)	Discharge Style	Authority for Requirement
EP94	Vents Inside	Vents Inside	1,500	70	Vents Inside	21-A-130
EP97	Vents Inside	Vents Inside	112	Building Ambient	Vents Inside	21-A-132-S1

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No
See Appendix A

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 96

Associated Equipment

Emission Unit	Emission Unit Description	Control Equipment	Raw Material	Rated Capacity	Construction Permit
96	Simpson Sand Reclaim	CE-96-1: Baghouse	Sand	10 tons/hr	21-A-131-S1

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permit 21-A-131-S1
567 IAC 23.3(2)"d"

⁽¹⁾ An exceedance of the indicator opacity of 10% will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.05 gr/dscf

Authority for Requirement: DNR Construction Permit 21-A-131-S1
567 IAC 23.4(6)

Pollutant: PM₁₀

Emission Limit(s): 1.3 lb/hr

Authority for Requirement: DNR Construction Permit 21-A-131-S1

Pollutant: PM_{2.5}

Emission Limit(s): 1.3 lb/hr

Authority for Requirement: DNR Construction Permit 21-A-131-S1

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner.

The operating requirements and associated recordkeeping for this permit shall be:

1. The facility shall maintain a differential pressure drop across the baghouse (CE-96-1) between 2.0 and 6.0 inches of water column (WC).

- A. The owner or operator shall properly install, operate, and maintain equipment to continuously monitor the pressure drop of the baghouse (CE-96-1). The monitoring devices and any recorders shall be installed, calibrated, operated and maintained in accordance with the manufacturer's recommendations, instructions and operating manual or per a written facility-specific operation and maintenance plan.
 - I. The owner or operator shall collect and record the differential pressure across the baghouse, at a minimum, once per day when the emission unit the baghouse controls is in operation.
 - II. If the differential pressure across the baghouse falls outside the permitted range allowed (2.0" – 6.0" WC), then the facility shall record the time, date and actions taken to correct the situation and when the differential pressure across the baghouse is back with the permitted range allowed.
 - 2. The owner or operator shall inspect and maintain the baghouse (CE-96-1) according to the facility's (Plant No. 88-01-002) operation and maintenance plan or manufacturer's specifications.
 - A. The owner or operator shall keep a log of all maintenance and inspection activities performed on the control equipment. At a minimum, this log shall include:
 - I. The date any inspection and/or maintenance was performed on the control equipment;
 - II. Any issues identified during the inspection; and,
 - III. Any issues addressed during the maintenance activities
- Authority for Requirement: DNR Construction Permit 21-A-131-S1

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): Vents Inside

Stack Opening, (inches, dia.): Vents Inside

Exhaust Flow Rate (scfm): 7,600

Exhaust Temperature (°F): 70

Discharge Style: Vents Inside

Authority for Requirement: DNR Construction Permit 21-A-131-S1

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No
See Appendix A.

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: 99

Associated Equipment

Emission Unit	Emission Unit Description	Raw Material	Rated Capacity	Construction Permit
99-1	3D Core Printer	Sand	0.20 tons/hr	23-A-451

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permit 23-A-451
567 IAC 23.3(2)"d"

⁽¹⁾ An exceedance of the indicator opacity of 25% will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.05 gr/dscf , 0.90 lb/hr

Authority for Requirement: DNR Construction Permit 23-A-451
567 IAC 23.4(6)

See Plant-Wide Conditions for VOC and HAP Emission Limits.

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner.

1. Refer to Plant-Wide Conditions for applicable requirements.
Authority for Requirement: DNR Construction Permit 23-A-451

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

- Stack Height, (ft, from the ground): 12
- Stack Opening, (inches, dia.): 12
- Exhaust Flow Rate (scfm): 1,000
- Exhaust Temperature (°F): Ambient
- Discharge Style: Horizontal
- Authority for Requirement: DNR Construction Permit 23-A-451

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

- Agency Approved Operation & Maintenance Plan Required?** Yes No
- Facility Maintained Operation & Maintenance Plan Required?** Yes No
- Compliance Assurance Monitoring (CAM) Plan Required?** Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Numbers: See Table: Metal Pouring and Mold Cooling-Associated Equipment

Table: Metal Pouring and Mold Cooling-Associated Equipment

Emission Point	Emission Unit	Emission Unit Description	Control Equipment	Raw Material	Rated Capacity	Construction Permit
EF-1	84-1 85-1	Metal Pouring Mold Cooling	NA	Magnesium and Aluminum	1.25 tons/hr	07-A-741-S3
EF-2						07-A-742-S3
EF-3						07-A-743-S3
EF-4						07-A-744-S3
EF-5						07-A-745-S3
EF-6						07-A-746-S3
EF-7						07-A-747-S3
EF-8						07-A-748-S3
EF-9						12-A-040-S2
EF-10						07-A-749-S3
EF-11						07-A-750-S3
EF-12						12-A-041-S2
EF-35						12-A-042-S2
EF-36						12-A-043-S2

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from each emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permits listed in Table: Metal Pouring and Mold Cooling-Associated Equipment
567 IAC 23.3(2)"d"

⁽¹⁾ An exceedance of the indicator opacity of No Visible Emissions will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/dscf, 0.15 lb/hr

Authority for Requirement: DNR Construction Permits listed in Table: Metal Pouring and Mold Cooling-Associated Equipment
567 IAC 23.3(2)"a"

Pollutant: PM₁₀

Emission Limit(s): 0.15 lb/hr

Authority for Requirement: DNR Construction Permits listed in Table: Metal Pouring and Mold Cooling-Associated Equipment

See Plant-Wide Conditions for VOC and HAP Emission Limits.

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner.

The operating requirements and associated recordkeeping for this permit shall be:

1. Refer to Plant-Wide Conditions for applicable requirements.

Authority for Requirement: DNR Construction Permits listed in Table: Metal Pouring and Mold Cooling-Associated Equipment

NESHAP

These units are subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) Subpart ZZZZZZ – Area Source Standards for Aluminum, Copper, and Other Nonferrous Foundries (40 CFR §63.11544 through 40 CFR §63. 11558).

Per 40 CFR Part 63.11550(a)(1) through (3) the facility must cover or enclose melting furnaces during the melting process, purchase scrap that has been depleted of hazardous metals to the extent possible, and prepare and operate according to a written management practices plan. The facility must also keep the records specified in paragraphs 40 CFR Part 63.11553(c), (d), and (e).

Authority for Requirement: 40 CFR 63 Subpart ZZZZZZ
567 IAC 23.1(4)"ez"

Emission Point Characteristics

Each emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 38

Stack Opening, (inches, dia.): 40

Exhaust Flow Rate (scfm): 17,000

Exhaust Temperature (°F): 70

Discharge Style: Vertical, unobstructed

Authority for Requirement: DNR Construction Permits listed in Table: Metal Pouring and Mold Cooling-Associated Equipment

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Numbers: EF-13-1, EF-14-1, EF-15-1

Emission Point	Emission Unit	Emission Unit Description	Raw Material	Rated Capacity	Construction Permit
EF-13-1	86-1	Aluminum Melting (12 Crucible Furnaces)	Aluminum Alloy	1.25 tons/hr	23-A-051-S1
EF-14-1					23-A-052-S1
EF-15-1					23-A-053-S1

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from each emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permit 23-A-051-S1, 23-A-052-S1, 23-A-053-S1
567 IAC 23.3(2)"d"

⁽¹⁾An exceedance of the indicator opacity of 'No Visible Emissions' will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.99 lb/hr, 0.1 gr/scf

Authority for Requirement: DNR Construction Permit 23-A-051-S1, 23-A-052-S1, 23-A-053-S1
567 IAC 23.3(2)"a"

Pollutant: PM₁₀

Emission Limit(s): 0.99 lb/hr

Authority for Requirement: DNR Construction Permit 23-A-051-S1, 23-A-052-S1, 23-A-053-S1

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner.

- B. The Magnesium/Aluminum Melting Furnaces (EU-24-1) and Aluminum Melting Furnaces (EU-86-1) are limited to a maximum combined throughput of 1.25 ton/hr. On a daily basis, the owner or operator shall:
 - (1) Track the amount of magnesium and aluminum melted, in tons, in EU-24-1 and EU-86-1;
 - (2) Track the number of hours that EU-24-1 and EU-86-1 operated; And,
 - (3) Calculate and record the combined throughput, in ton/hr, of EU-24-1 and EU-86-1.

- C. The furnaces located in the Aluminum Melt Room may only melt clean charge (as defined in 40 CFR 63.1503), customer returns, or internal scrap.
 - (1) The owner or operator shall record the type of charge used in the furnaces in the Aluminum Melt Room.
- D. The owner or operator shall meet all of the applicable requirements listed in 40 CFR §63.11550(a), including the requirement to cover or enclose each melting furnace that is equipped with a cover or enclosure during the melting operation to the extent practicable and the requirement to prepare and operate pursuant to a written management practices plan.
- E. The owner or operator shall meet all of the applicable monitoring requirements specified in 40 CFR §63.11552.
- F. The owner or operator shall meet all of the applicable notification, reporting, and recordkeeping requirements specified in 40 CFR §63.11553.
- G. See Plant-Wide Conditions for additional requirements.

Authority for Requirement: DNR Construction Permit 23-A-051-S1, 23-A-052-S1, 23-A-053-S1

NESHAP Applicability

This unit is subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) Subpart ZZZZZZ – Area Source Standards for Aluminum, Copper, and Other Nonferrous Foundries (40 CFR §63.11544 through 40 CFR §63. 11558).

Authority for Requirement: DNR Construction Permit 23-A-051-S1, 23-A-052-S1, 23-A-053-S1
 40 CFR 63 Subpart ZZZZZZ
 567 IAC 23.1(4)"ez"

Emission Point Characteristics

Each emission point shall conform to the specifications listed below.

- Stack Height, (ft., from the ground): 38
- Stack Opening, (inches, dia.): 40
- Exhaust Flow Rate (scfm): 17,000
- Exhaust Temperature (°F): 70
- Discharge Style: Vertical unobstructed

Authority for Requirement: DNR Construction Permit 23-A-051-S1, 23-A-052-S1, 23-A-053-S1

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Numbers: EF-18, 19, 20, 21 and EF-32

Associated Equipment

Emission Point	Emission Unit	Emission Unit Description	Raw Material	Rated Capacity*	Construction Permit
EF-18	24-1	Magnesium/Aluminum Melting (8 Tilter Furnaces) (12 Pot Furnaces)	Magnesium Aluminum	1.25 tons/hr 35.0 MMBtu/hr	07-A-751-S5
EF-19					07-A-752-S5
EF-20					07-A-753-S5
EF-21					07-A-754-S5
EF-32					07-A-755-S5

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from each emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permits listed in Associated Equipment
567 IAC 23.3(2)"d"

⁽¹⁾ An exceedance of the indicator opacity of 'No Visible Emissions' will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/dscf, 1.16 lb/hr

Authority for Requirement: DNR Construction Permits listed in Associated Equipment
567 IAC 23.3(2)"a"

Pollutant: PM₁₀

Emission Limit(s): 1.16 lb/hr

Authority for Requirement: DNR Construction Permits listed in Associated Equipment

Pollutant: Sulfur Dioxide (SO₂)

Emission Limit(s): 500ppm

Authority for Requirement: DNR Construction Permits listed in Associated Equipment
567 IAC 23.3(3)"e"

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner.

- A. The Magnesium/Aluminum Melting Furnaces (EU-24-1) and Aluminum Melting Furnaces (EU-86-1) are limited to a maximum combined throughput of 1.25 ton/hr. On a daily basis, the owner or operator shall:
 - (1) Track the amount of magnesium and aluminum melted, in tons, in EU-24-1 and EU-86-1;
 - (2) Track the number of hours that EU-24-1 and EU-86-1 operated; And,
 - (3) Calculate and record the combined throughput, in ton/hr, of EU-24-1 and EU-86-1.
- B. The magnesium/aluminum tilter and pot furnaces shall be fired with propane or natural gas fuel only.
 - (1) The owner or operator shall record the type of fuel used in the magnesium/aluminum tilter and pot furnaces.
- C. The furnaces located in the Magnesium Melt Room may only melt clean charge materials including: molten magnesium or aluminum; T-bar; sow; ingot; billet; pig; alloying elements; magnesium or aluminum scrap that is known by the owner or operator to be entirely free of paints, coatings and lubricants; and runaround scrap. Clean charge material may contain markings made at this foundry for identification purposes in paint, ink or grease pen.
 - (2) The owner or operator shall record the type of charge used in the furnaces in the Magnesium Melt Room.
- D. The owner or operator shall meet all of the applicable requirements listed in 40 CFR §63.11550(a), including the requirement to cover or enclose each melting furnace that is equipped with a cover or enclosure during the melting operation to the extent practicable and the requirement to prepare and operate pursuant to a written management practices plan.
- E. The owner or operator shall meet all of the applicable monitoring requirements specified in 40 CFR §63.11552.
- F. The owner or operator shall meet all of the applicable notification, reporting, and recordkeeping requirements specified in 40 CFR §63.11553.

Authority for Requirement: DNR Construction Permits listed in Associated Equipment

NESHAP

This unit is subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) Subpart ZZZZZZ – Area Source Standards for Aluminum, Copper, and Other Nonferrous Foundries (40 CFR §63.11544 through 40 CFR §63.11558).

Per 40 CFR Part 63.11550(a)(1) through (3) the facility must cover or enclose melting furnaces during the melting process, purchase scrap that has been depleted of hazardous metals to the extent possible, and prepare and operate according to a written management practices plan. The facility must also keep the records specified in paragraphs 40 CFR Part 63.11553(c), (d), and (e).

Authority for Requirement: 40 CFR 63 Subpart ZZZZZZ
567 IAC 23.1(4)"ez"

Emission Point Characteristics

Each emission point shall conform to the specifications listed below.

Stack Height, (ft., from the ground): 38

Stack Opening, (inches, dia.): 62

Exhaust Flow Rate (scfm): 30,000

Exhaust Temperature (°F): 100

Discharge Style: Vertical unobstructed

Authority for Requirement: DNR Construction Permit 07-A-751-S5, 07-A-752-S5, 07-A-753-S5, 07-A-754-S5, 07-A-755-S5

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Numbers: EF-24, EF-26, EF-27

Associated Equipment

Emission Point	Emission Unit	Emission Unit Description	Control Equipment	Raw Material	Rated Capacity	Construction Permit
EF-24	EF-24	Heat Treat 1	NA	Quenchant	6.92 lb/hr	07-A-756
	EF-26	Heat Treat 2	NA	Quenchant	6.92 lb/hr	
EF-26	EF-27	Heat Treat 3	NA	Quenchant	6.92 lb/hr	07-A-757
EF-27			NA			07-A-758

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from each emission point shall not exceed the levels specified below.

Emission Point	Opacity	Particulate Matter	PM ₁₀	Volatile Organic Compounds (VOC)	Authority for Requirement
EF-24	40% ⁽¹⁾	0.1 gr/dscf, 0.70 lb/hr	0.70 lb/hr	6.11 tons/yr	07-A-756, 23.3(2)"d", 23.3(2)"a"
EF-26	40% ⁽¹⁾	0.1 gr/dscf, 0.35 lb/hr	0.35 lb/hr		07-A-757, 23.3(2)"d", 23.3(2)"a"
EF-27	40% ⁽¹⁾	0.1 gr/dscf, 0.35 lb/hr	0.35 lb/hr		07-A-758, 23.3(2)"d", 23.3(2)"a"

⁽¹⁾ An exceedance of the indicator opacity of no visible emissions will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing)

Operating Requirements with Associated Monitoring and Recordkeeping

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits:

1. The combined amount of oil quenchant used in Heat Treat Furnace 1 and Quench (EF-24), Heat Treat Furnace 2 and Quench (EF-26) and Heat Treat Furnace 3 (EF-27) combined shall not exceed 22,230 pounds in any rolling 12-month period.
2. The VOC content of the oil quenching used in Heat Treat Furnace 1 and Quench (EF-24), Heat Treat Furnace 2 and Quench (EF-26) and Heat Treat Furnace 3 (EF-27) combined shall not exceed 55 percent by weight.

Reporting & Record keeping:

Records shall be kept on site for at least five years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner. These records shall show the following:

1. Record monthly the amount of oil quenchant used in Heat Treat Furnace 1 and Quench (EF-24), Heat Treat Furnace 2 and Quench (EF-26) and Heat Treat Furnace 3 (EF-27) combined in pounds. Calculate and record rolling 12-month totals.
2. Retain Material Safety Data Sheets (MSDS) for all quench materials used in Heat Treat Furnace 1 and Quench (EF-24), Heat Treat Furnace 2 and Quench (EF-26) and Heat Treat Furnace 3 (EF-27)

Authority for Requirement: DNR Construction Permits listed in Associated Equipment

Emission Point Characteristics

Each emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 32

Stack Opening, (inches, dia.): 40

Exhaust Flow Rate (scfm): 37,000

Exhaust Temperature (°F): 70

Discharge Style: Vertical unobstructed

Authority for Requirement: DNR Construction Permits listed in Associated Equipment

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: BLDG F (Vent Internally)

Associated Equipment

Emission Unit	Emission Unit Description	Control Equipment	Raw Material	Rated Capacity	Construction Permit
4-1	East Cell Mixer	CE20-1: Baghouse	Sand /Binder	4.2 tons/hr	07-A-759-S5
47-1	West Cell Mixer		Sand/Binder	4.2 tons/hr	
93-1	300 Mixer		Sand/Binder	9.4 tons/hr	
38-1	Old Knock Out	NA	Sand/Castings	1 ton/hr	
50-1	Cleaning and Grinding Room	NA	Castings Scrape Off	0.57 tons/hr	
88-1	Tinker Omega Mixer	NA	Sand/Binder	0.06 ton/hr	

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%⁽¹⁾

Authority for Requirement: DNR Construction Permit 07-A-759-S5
567 IAC 23.3(2)"d"

⁽¹⁾ An exceedance of the indicator opacity of No Visible Emissions will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.05 gr/scf, 12.33 lb/hr

Authority for Requirement: DNR Construction Permit 07-A-759-S5
567 IAC 23.4(6)

Pollutant: PM₁₀

Emission Limit(s): 5.1 lb/hr

Authority for Requirement: DNR Construction Permit 07-A-759-S5

See Plant-Wide Conditions for VOC and HAP Emission Limits.

Operating Requirements with Associated Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner.

The operating requirements and associated recordkeeping for this permit shall be:

General Requirements

1. The facility shall maintain a differential pressure drop across the baghouse (CE-20-1) between 2.0 and 6.0 inches of water column (WC).
 - A. The owner or operator shall properly install, operate, and maintain equipment to continuously monitor the pressure drop of the baghouse (CE-20-1). The monitoring devices and any recorders shall be installed, calibrated, operated and maintained in accordance with the manufacturer's recommendations, instructions and operating manual or per a written facility-specific operation and maintenance plan.
 - I. The owner or operator shall collect and record the differential pressure across the baghouse, at a minimum, once per day when the emission unit the baghouse controls is in operation.
 - II. If the differential pressure across the baghouse falls outside the permitted range allowed (2.0" – 6.0" WC), then the facility shall record the time, date and actions taken to correct the situation and when the differential pressure across the baghouse is back with the permitted range allowed.
2. The owner or operator shall inspect and maintain the baghouse (CE-20-1) according to the facility's (Plant No. 88-01-002) operation and maintenance plan or manufacturer's specifications.
 - A. The owner or operator shall keep a log of all maintenance and inspection activities performed on the control equipment. At a minimum, this log shall include:
 - I. The date any inspection and/or maintenance was performed on the control equipment;
 - II. Any issues identified during the inspection; and,
 - III. Any issues addressed during the maintenance activities.
3. The permittee shall maintain the Safety Data Sheets (SDS) for each VOC-containing or HAP-containing material used at the facility.
2. Refer to Plant-Wide Conditions for additional applicable requirements.

Authority for Requirement: DNR Construction Permit 07-A-759-S5

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

- Stack Height, (ft, from the ground): Vents Inside Building
- Stack Opening, (inches, dia.): Vents Inside Building
- Exhaust Flow Rate (acfm): Vents Inside Building
- Exhaust Temperature (°F): Vents Inside Building
- Discharge Style: Vents Inside Building
- Authority for Requirement: DNR Construction Permit 07-A-759-S5

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No
See Appendix A.

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

IV. General Conditions

This permit is issued under the authority of the Iowa Code subsection 455B.133(8) and in accordance with 567 Iowa Administrative Code chapter 22.

G1. Duty to Comply

1. The permittee must comply with all conditions of the Title V permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action; for a permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. *567 IAC 22.108(9)"a"*
2. Any compliance schedule shall be supplemental to, and shall not sanction noncompliance with, the applicable requirements on which it is based. *567 IAC 22.105 (2)"h"(3)*
3. Where an applicable requirement of the Act is more stringent than an applicable requirement of regulations promulgated under Title IV of the Act, both provisions shall be enforceable by the administrator and are incorporated into this permit. *567 IAC 22.108 (1)"b"*
4. Unless specified as either "state enforceable only" or "local program enforceable only", all terms and conditions in the permit, including provisions to limit a source's potential to emit, are enforceable by the administrator and citizens under the Act. *567 IAC 22.108 (14)*
5. It shall not be a defense for a permittee, in an enforcement action, that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. *567 IAC 22.108 (9)"b"*
6. For applicable requirements with which the permittee is in compliance, the permittee shall continue to comply with such requirements. For applicable requirements that will become effective during the permit term, the permittee shall meet such requirements on a timely basis. *567 IAC 22.108(15)"c"*

G2. Permit Expiration

1. Except as provided in rule 567—22.104(455B), permit expiration terminates a source's right to operate unless a timely and complete application for renewal has been submitted in accordance with rule 567—22.105(455B). *567 IAC 22.116(2)*
2. To be considered timely, the owner, operator, or designated representative (where applicable) of each source required to obtain a Title V permit shall submit on forms or electronic format specified by the Department to the Air Quality Bureau, Iowa Department of Natural Resources, Air Quality Bureau, Wallace State Office Building, 502 E 9th St., Des Moines, IA 50319-0034, two copies (three if your facility is located in Linn or Polk county) of a complete permit application, at least 6 months but not more than 18 months prior to the date of permit expiration. An additional copy must also be sent to U.S. EPA Region VII, Attention: Chief of Air Permitting & Standards Branch, 11201 Renner Blvd., Lenexa, KS 66219. Additional copies to local programs or EPA are not required for application materials submitted through the electronic format specified by the Department. The application must include all emission points, emission units, air pollution control equipment, and monitoring devices at the facility. All emissions generating activities, including fugitive emissions, must be included. The definition of a complete application is as indicated in 567 IAC 22.105(2). *567 IAC 22.105*

G3. Certification Requirement for Title V Related Documents

Any application, report, compliance certification or other document submitted pursuant to this permit shall contain certification by a responsible official of truth, accuracy, and completeness. All certifications shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. *567 IAC 22.107 (4)*

G4. Annual Compliance Certification

By March 31 of each year, the permittee shall submit compliance certifications for the previous calendar year. The certifications shall include descriptions of means to monitor the compliance status of all emissions sources including emissions limitations, standards, and work practices in accordance with applicable requirements. The certification for a source shall include the identification of each term or condition of the permit that is the basis of the certification; the compliance status; whether compliance was continuous or intermittent; the method(s) used for determining the compliance status of the source, currently and over the reporting period consistent with all applicable department rules. For sources determined not to be in compliance at the time of compliance certification, a compliance schedule shall be submitted which provides for periodic progress reports, dates for achieving activities, milestones, and an explanation of why any dates were missed and preventive or corrective measures. The compliance certification shall be submitted to the administrator, director, and the appropriate DNR Field office. *567 IAC 22.108 (15)"e"*

G5. Semi-Annual Monitoring Report

By March 31 and September 30 of each year, the permittee shall submit a report of any monitoring required under this permit for the 6 month periods of July 1 to December 31 and January 1 to June 30, respectively. All instances of deviations from permit requirements must be clearly identified in these reports, and the report must be signed by a responsible official, consistent with 567 IAC 22.107(4). The semi-annual monitoring report shall be submitted to the director and the appropriate DNR Field office. *567 IAC 22.108 (5)*

G6. Annual Fee

1. The permittee is required under subrule 567 IAC 22.106 to pay an annual fee based on the total tons of actual emissions of each regulated air pollutant. Beginning July 1, 1996, Title V operating permit fees will be paid on July 1 of each year. The fee shall be based on emissions for the previous calendar year.
2. The fee amount shall be calculated based on the first 4,000 tons of each regulated air pollutant emitted each year. The fee to be charged per ton of pollutant will be available from the department by June 1 of each year. The Responsible Official will be advised of any change in the annual fee per ton of pollutant.
3. The emissions inventory shall be submitted annually by March 31 with forms specified by the department documenting actual emissions for the previous calendar year.
4. The fee shall be submitted annually by July 1 with forms specified by the department.
5. If there are any changes to the emission calculation form, the department shall make revised forms available to the public by January 1. If revised forms are not available by January 1, forms from the previous year may be used and the year of emissions documented changed. The department shall calculate the total statewide Title V emissions for the prior calendar year and make this information available to the public no later than April 30 of each year.
6. Phase I acid rain affected units under section 404 of the Act shall not be required to pay a fee for emissions which occur during the years 1993 through 1999 inclusive.
7. The fee for a portable emissions unit or stationary source which operates both in Iowa and out of state shall be calculated only for emissions from the source while operating in Iowa.
8. Failure to pay the appropriate Title V fee represents cause for revocation of the Title V permit as indicated in 567 IAC 22.115(1)"d".

G7. Inspection of Premises, Records, Equipment, Methods and Discharges

Upon presentation of proper credentials and any other documents as may be required by law, the permittee shall allow the director or the director's authorized representative to:

1. Enter upon the permittee's premises where a Title V source is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
3. Inspect, at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
4. Sample or monitor, at reasonable times, substances or parameters for the purpose of ensuring compliance with the permit or other applicable requirements. *567 IAC 22.108 (15)"b"*

G8. Duty to Provide Information

The permittee shall furnish to the director, within a reasonable time, any information that the director may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee also shall furnish to the director copies of records required to be kept by the permit, or for information claimed to be confidential, the permittee shall furnish such records directly to the administrator of EPA along with a claim of confidentiality. *567 IAC 22.108 (9)"e"*

G9. General Maintenance and Repair Duties

The owner or operator of any air emission source or control equipment shall:

1. Maintain and operate the equipment or control equipment at all times in a manner consistent with good practice for minimizing emissions.
2. Remedy any cause of excess emissions in an expeditious manner.
3. Minimize the amount and duration of any excess emission to the maximum extent possible during periods of such emissions. These measures may include but not be limited to the use of clean fuels, production cutbacks, or the use of alternate process units or, in the case of utilities, purchase of electrical power until repairs are completed.
4. Schedule, at a minimum, routine maintenance of equipment or control equipment during periods of process shutdowns to the maximum extent possible. *567 IAC 24.2(1)*

G10. Recordkeeping Requirements for Compliance Monitoring

1. In addition to any source specific recordkeeping requirements contained in this permit, the permittee shall maintain the following compliance monitoring records, where applicable:
 - a. The date, place and time of sampling or measurements
 - b. The date the analyses were performed.
 - c. The company or entity that performed the analyses.
 - d. The analytical techniques or methods used.
 - e. The results of such analyses; and
 - f. The operating conditions as existing at the time of sampling or measurement.
 - g. The records of quality assurance for continuous compliance monitoring systems (including but not limited to quality control activities, audits and calibration drifts.)
2. The permittee shall retain records of all required compliance monitoring data and support information for a period of at least 5 years from the date of compliance monitoring sample, measurement report or application. Support information includes all calibration and maintenance records and all original strip chart recordings for continuous compliance monitoring, and copies of all reports required by the permit.
3. For any source which in its application identified reasonably anticipated alternative operating scenarios, the permittee shall:
 - a. Comply with all terms and conditions of this permit specific to each alternative scenario.
 - b. Maintain a log at the permitted facility of the scenario under which it is operating.

- c. Consider the permit shield, if provided in this permit, to extend to all terms and conditions under each operating scenario. *567 IAC 22.108(4), 567 IAC 22.108(12)*

G11. Evidence used in establishing that a violation has or is occurring.

Notwithstanding any other provisions of these rules, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions herein.

1. Information from the use of the following methods is presumptively credible evidence of whether a violation has occurred at a source:
 - a. A monitoring method approved for the source and incorporated in an operating permit pursuant to 567 Chapter 22;
 - b. Compliance test methods specified in 567 Chapter 25; or
 - c. Testing or monitoring methods approved for the source in a construction permit issued pursuant to 567 Chapter 22.
2. The following testing, monitoring or information gathering methods are presumptively credible testing, monitoring, or information gathering methods:
 - a. Any monitoring or testing methods provided in these rules; or
 - b. Other testing, monitoring, or information gathering methods that produce information comparable to that produced by any method in subrule 21.5(1) or this subrule. *567 IAC 21.5(1)-567 IAC 21.5(2)*

G12. Prevention of Accidental Release: Risk Management Plan Notification and Compliance Certification

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Act, the permittee shall notify the department of this requirement. The plan shall be filed with all appropriate authorities by the deadline specified by EPA. A certification that this risk management plan is being properly implemented shall be included in the annual compliance certification of this permit. *567 IAC 22.108(6)*

G13. Hazardous Release

The permittee must report any situation involving the actual, imminent, or probable release of a hazardous substance into the atmosphere which, because of the quantity, strength and toxicity of the substance, creates an immediate or potential danger to the public health, safety or to the environment. A verbal report shall be made to the department at (515) 725-8694 and to the local police department or the office of the sheriff of the affected county as soon as possible but not later than six hours after the discovery or onset of the condition. This verbal report must be followed up with a written report as indicated in 567 IAC 131.2(2). *567 IAC Chapter 131-State Only*

G14. Excess Emissions and Excess Emissions Reporting Requirements

1. Excess Emissions. Excess emission during a period of startup, shutdown, or cleaning of control equipment is not a violation of the emission standard if the startup, shutdown or cleaning is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions. Cleaning of control equipment which does not require the shutdown of the process equipment shall be limited to one six-minute period per one-hour period. An incident of excess emission (other than an incident during startup, shutdown or cleaning of control equipment) is a violation. If the owner or operator of a source maintains that the incident of excess emission was due to a malfunction, the owner or operator must show that the conditions which caused the incident of excess emission were not preventable by reasonable maintenance and control measures. Determination of any subsequent enforcement action will be made following review of this report. If excess emissions are occurring, either the control equipment causing the excess emission shall be repaired in an expeditious manner or the process generating the emissions shall be shutdown within a reasonable period of time. An expeditious manner is the time necessary to

determine the cause of the excess emissions and to correct it within a reasonable period of time. A reasonable period of time is eight hours plus the period of time required to shut down the process without damaging the process equipment or control equipment. A variance from this subrule may be available as provided for in Iowa Code section 455B.143. In the case of an electric utility, a reasonable period of time is eight hours plus the period of time until comparable generating capacity is available to meet consumer demand with the affected unit out of service, unless, the director shall, upon investigation, reasonably determine that continued operation constitutes an unjustifiable environmental hazard and issue an order that such operation is not in the public interest and require a process shutdown to commence immediately.

2. Excess Emissions Reporting

a. Initial Reporting of Excess Emissions. An incident of excess emission (other than an incident of excess emission during a period of startup, shutdown, or cleaning) shall be reported to the appropriate field office of the department within eight hours of, or at the start of the first working day following the onset of the incident. The reporting exemption for an incident of excess emission during startup, shutdown or cleaning does not relieve the owner or operator of a source with continuous monitoring equipment of the obligation of submitting reports required in 567-subrule 25.1(6). An initial report of excess emission is not required for a source with operational continuous monitoring equipment (as specified in 567-subrule 25.1(1)) if the incident of excess emission continues for less than 30 minutes and does not exceed the applicable emission standard by more than 10 percent or the applicable visible emission standard by more than 10 percent opacity. The initial report may be made by electronic mail (E-mail), in person, or by telephone and shall include as a minimum the following:

- i. The identity of the equipment or source operation from which the excess emission originated and the associated stack or emission point.
- ii. The estimated quantity of the excess emission.
- iii. The time and expected duration of the excess emission.
- iv. The cause of the excess emission.
- v. The steps being taken to remedy the excess emission.
- vi. The steps being taken to limit the excess emission in the interim period.

b. Written Reporting of Excess Emissions. A written report of an incident of excess emission shall be submitted as a follow-up to all required initial reports to the department within seven days of the onset of the upset condition, and shall include as a minimum the following:

- i. The identity of the equipment or source operation point from which the excess emission originated and the associated stack or emission point.
- ii. The estimated quantity of the excess emission.
- iii. The time and duration of the excess emission.
- iv. The cause of the excess emission.
- v. The steps that were taken to remedy and to prevent the recurrence of the incident of excess emission.
- vi. The steps that were taken to limit the excess emission.
- vii. If the owner claims that the excess emission was due to malfunction, documentation to support this claim. 567 IAC 24.1(1)-567 IAC 24.1(4)

3. Emergency Defense for Excess Emissions. For the purposes of this permit, an “emergency” means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which situation requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission

limitation under the permit due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include non-compliance, to the extent caused by improperly designed equipment, lack of preventive maintenance, careless or improper operation or operator error. An emergency constitutes an affirmative defense to an action brought for non-compliance with technology based limitations if it can be demonstrated through properly signed contemporaneous operating logs or other relevant evidence that:

- a. An emergency occurred and that the permittee can identify the cause(s) of the emergency;
- b. The facility at the time was being properly operated;
- c. During the period of the emergency, the permittee took all reasonable steps to minimize levels of emissions that exceeded the emissions standards or other requirements of the permit; and
- d. The permittee submitted notice of the emergency to the director by certified mail within two working days of the time when the emissions limitations were exceeded due to the emergency. This notice fulfills the requirement of paragraph 22.108(5)"b." – See G15. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

In any enforcement proceeding, the permittee seeking to establish the occurrence of an emergency has the burden of proof. This provision is in addition to any emergency or upset provision contained in any applicable requirement. *567 IAC 22.108(16)*

G15. Permit Deviation Reporting Requirements

A deviation is any failure to meet a term, condition or applicable requirement in the permit. Reporting requirements for deviations that result in a hazardous release or excess emissions have been indicated above (see G13 and G14). Unless more frequent deviation reporting is specified in the permit, any other deviation shall be documented in the semi-annual monitoring report and the annual compliance certification (see G4 and G5). *567 IAC 22.108(5)"b"*

G16. Notification Requirements for Sources That Become Subject to NSPS and NESHAP Regulations

During the term of this permit, the permittee must notify the department of any source that becomes subject to a standard or other requirement under 567-subrule 23.1(2) (standards of performance of new stationary sources) or section 111 of the Act; or 567-subrule 23.1(3) (emissions standards for hazardous air pollutants), 567-subrule 23.1(4) (emission standards for hazardous air pollutants for source categories) or section 112 of the Act. This notification shall be submitted in writing to the department pursuant to the notification requirements in 40 CFR Section 60.7, 40 CFR Section 61.07, and/or 40 CFR Section 63.9. *567 IAC 23.1(2), 567 IAC 23.1(3), 567 IAC 23.1(4)*

G17. Requirements for Making Changes to Emission Sources That Do Not Require Title V Permit Modification

1. Off Permit Changes to a Source. Pursuant to section 502(b)(10) of the CAAA, the permittee may make changes to this installation/facility without revising this permit if:
 - a. The changes are not major modifications under any provision of any program required by section 110 of the Act, modifications under section 111 of the act, modifications under section 112 of the act, or major modifications as defined in 567 IAC Chapter 22.
 - b. The changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions);
 - c. The changes are not modifications under any provisions of Title I of the Act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or as total emissions);

- d. The changes are not subject to any requirement under Title IV of the Act (revisions affecting Title IV permitting are addressed in rules 567—22.140(455B) through 567 - 22.144(455B)).
- e. The changes comply with all applicable requirements.
- f. For each such change, the permitted source provides to the department and the administrator by certified mail, at least 30 days in advance of the proposed change, a written notification, including the following, which must be attached to the permit by the source, the department and the administrator:
 - i. A brief description of the change within the permitted facility,
 - ii. The date on which the change will occur,
 - iii. Any change in emission as a result of that change,
 - iv. The pollutants emitted subject to the emissions trade
 - v. If the emissions trading provisions of the state implementation plan are invoked, then Title V permit requirements with which the source shall comply; a description of how the emissions increases and decreases will comply with the terms and conditions of the Title V permit.
 - vi. A description of the trading of emissions increases and decreases for the purpose of complying with a federally enforceable emissions cap as specified in and in compliance with the Title V permit; and
 - vii. Any permit term or condition no longer applicable as a result of the change.

567 IAC 22.110(1)

- 2. Such changes do not include changes that would violate applicable requirements or contravene federally enforceable permit terms and conditions that are monitoring (including test methods), record keeping, reporting, or compliance certification requirements. *567 IAC 22.110(2)*
- 3. Notwithstanding any other part of this rule, the director may, upon review of a notice, require a stationary source to apply for a Title V permit if the change does not meet the requirements of subrule 22.110(1). *567 IAC 22.110(3)*
- 4. The permit shield provided in subrule 22.108(18) shall not apply to any change made pursuant to this rule. Compliance with the permit requirements that the source will meet using the emissions trade shall be determined according to requirements of the state implementation plan authorizing the emissions trade. *567 IAC 22.110(4)*
- 5. No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes, for changes that are provided for in this permit. *567 IAC 22.108(11)*

G18. Duty to Modify a Title V Permit

1. Administrative Amendment.

- a. An administrative permit amendment is a permit revision that does any of the following:
 - i. Correct typographical errors
 - ii. Identify a change in the name, address, or telephone number of any person identified in the permit, or provides a similar minor administrative change at the source;
 - iii. Require more frequent monitoring or reporting by the permittee; or
 - iv. Allow for a change in ownership or operational control of a source where the director determines that no other change in the permit is necessary, provided that a written agreement containing a specific date for transfer of permit responsibility,

coverage and liability between the current and new permittee has been submitted to the director.

b. The permittee may implement the changes addressed in the request for an administrative amendment immediately upon submittal of the request. The request shall be submitted to the director.

c. Administrative amendments to portions of permits containing provisions pursuant to Title IV of the Act shall be governed by regulations promulgated by the administrator under Title IV of the Act.

2. Minor Title V Permit Modification.

a. Minor Title V permit modification procedures may be used only for those permit modifications that satisfy all of the following:

- i. Do not violate any applicable requirement;
- ii. Do not involve significant changes to existing monitoring, reporting or recordkeeping requirements in the Title V permit;
- iii. Do not require or change a case by case determination of an emission limitation or other standard, or an increment analysis;
- iv. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed in order to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include any federally enforceable emissions caps which the source would assume to avoid classification as a modification under any provision under Title I of the Act; and an alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Act;
- v. Are not modifications under any provision of Title I of the Act; and
- vi. Are not required to be processed as significant modification under rule 567 - 22.113(455B).

b. An application for minor permit revision shall be on the minor Title V modification application form and shall include at least the following:

- i. A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
- ii. The permittee's suggested draft permit;
- iii. Certification by a responsible official, pursuant to 567 IAC 22.107(4), that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used; and
- iv. Completed forms to enable the department to notify the administrator and the affected states as required by 567 IAC 22.107(7).

c. The permittee may make the change proposed in its minor permit modification application immediately after it files the application. After the permittee makes this change and until the director takes any of the actions specified in 567 IAC 22.112(4) "a" to "c", the permittee must comply with both the applicable requirements governing the change and the proposed permit terms and conditions. During this time, the permittee need not comply with the existing permit terms and conditions it seeks to modify. However, if the permittee fails to comply with its proposed permit terms and conditions during this time period, the existing permit terms and conditions it seeks to modify may be enforced against the facility.

3. Significant Title V Permit Modification.

Significant Title V modification procedures shall be used for applications requesting Title V permit modifications that do not qualify as minor Title V modifications or as administrative amendments. These include but are not limited to all significant changes in monitoring permit terms, every relaxation of reporting or recordkeeping permit terms, and any change in the method of measuring compliance with existing requirements. Significant Title V modifications shall meet all requirements of 567 IAC Chapter 22, including those for applications, public participation, review by affected states, and review by the administrator, as those requirements that apply to Title V issuance and renewal.

The permittee shall submit an application for a significant permit modification not later than three months after commencing operation of the changed source unless the existing Title V permit would prohibit such construction or change in operation, in which event the operation of the changed source may not commence until the department revises the permit. *567 IAC 22.111-567 IAC 22.113*

G19. Duty to Obtain Construction Permits

Unless exempted in 567 IAC 22.1(2) or to meet the parameters established in 567 IAC 22.1(1)"c", the permittee shall not construct, install, reconstruct or alter any equipment, control equipment or anaerobic lagoon without first obtaining a construction permit, or conditional permit, or permit pursuant to rule 567 IAC 22.8, or permits required pursuant to rules 567 IAC 22.4, 567 IAC 22.5, 567 IAC 31.3, and 567 IAC 33.3 as required in 567 IAC 22.1(1). A permit shall be obtained prior to the initiation of construction, installation or alteration of any portion of the stationary source or anaerobic lagoon. *567 IAC 22.1(1)*

G20. Asbestos

The permittee shall comply with 567 IAC 23.1(3)"a", and 567 IAC 23.2(3)"g" when activities involve asbestos mills, surfacing of roadways, manufacturing operations, fabricating, insulating, waste disposal, spraying applications, demolition and renovation operations (*567 IAC 23.1(3)"a"*); training fires and controlled burning of a demolished building (*567 IAC 23.2*).

G21. Open Burning

The permittee is prohibited from conducting open burning, except as provided in 567 IAC 23.2. *567 IAC 23.2 except 23.2(3)"j"; 567 IAC 23.2(3)"j" - State Only*

G22. Acid Rain (Title IV) Emissions Allowances

The permittee shall not exceed any allowances that it holds under Title IV of the Act or the regulations promulgated there under. Annual emissions of sulfur dioxide in excess of the number of allowances to emit sulfur dioxide held by the owners and operators of the unit or the designated representative of the owners and operators is prohibited. Exceedences of applicable emission rates are prohibited. "Held" in this context refers to both those allowances assigned to the owners and operators by USEPA, and those allowances supplementally acquired by the owners and operators. The use of any allowance prior to the year for which it was allocated is prohibited. Contravention of any other provision of the permit is prohibited. *567 IAC 22.108(7)*

G23. Stratospheric Ozone and Climate Protection (Title VI) Requirements

1. The permittee shall comply with the standards for labeling of products using ozone-depleting substances pursuant to 40 CFR Part 82, Subpart E:

- a. All containers in which a class I or class II substance is stored or transported, all products containing a class I substance, and all products directly manufactured with a class I substance must bear the required warning statement if it is being introduced into interstate commerce pursuant to § 82.106.
- b. The placement of the required warning statement must comply with the requirements pursuant to § 82.108.

- c. The form of the label bearing the required warning statement must comply with the requirements pursuant to § 82.110.
 - d. No person may modify, remove, or interfere with the required warning statement except as described in § 82.112.
2. The permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 CFR Part 82, Subpart F, except as provided for MVACs in Subpart B:
- a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to § 82.156.
 - b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to § 82.158.
 - c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to § 82.161.
 - d. Persons disposing of small appliances, MVACs, and MVAC-like appliances must comply with reporting and recordkeeping requirements pursuant to § 82.166. ("MVAC-like appliance" as defined at § 82.152)
 - e. Persons owning commercial or industrial process refrigeration equipment must comply with the leak repair requirements pursuant to § 82.156.
 - f. Owners/operators of appliances normally containing 50 or more pounds of refrigerant must keep records of refrigerant purchased and added to such appliances pursuant to § 82.166.
3. If the permittee manufactures, transforms, imports, or exports a class I or class II substance, the permittee is subject to all the requirements as specified in 40 CFR part 82, Subpart A, Production and Consumption Controls.
4. If the permittee performs a service on motor (fleet) vehicles when this service involves ozone-depleting substance refrigerant (or regulated substitute substance) in the motor vehicle air conditioner (MVAC), the permittee is subject to all the applicable requirements as specified in 40 CFR part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners. The term "motor vehicle" as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed. The term "MVAC" as used in Subpart B does not include the air-tight sealed refrigeration system used as refrigerated cargo, or system used on passenger buses using HCFC-22 refrigerant.
5. The permittee shall be allowed to switch from any ozone-depleting or greenhouse gas generating substances to any alternative that is listed in the Significant New Alternatives Program (SNAP) promulgated pursuant to 40 CFR part 82, Subpart G, Significant New Alternatives Policy Program. *40 CFR part 82*

G24. Permit Reopenings

1. This permit may be modified, revoked, reopened, and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition. *567 IAC 22.108(9)"c"*
2. Additional applicable requirements under the Act become applicable to a major part 70 source with a remaining permit term of 3 or more years. Revisions shall be made as expeditiously as practicable, but not later than 18 months after the promulgation of such standards and regulations.
 - a. Reopening and revision on this ground is not required if the permit has a remaining term of less than three years;
 - b. Reopening and revision on this ground is not required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original

permit or any of its terms and conditions have been extended pursuant to 40 CFR 70.4(b)(10)(i) or (ii) as amended to May 15, 2001.

c. Reopening and revision on this ground is not required if the additional applicable requirements are implemented in a general permit that is applicable to the source and the source receives approval for coverage under that general permit. *567 IAC 22.108(17)"a", 567 IAC 22.108(17)"b"*

3. A permit shall be reopened and revised under any of the following circumstances:
 - a. The department receives notice that the administrator has granted a petition for disapproval of a permit pursuant to 40 CFR 70.8(d) as amended to July 21, 1992, provided that the reopening may be stayed pending judicial review of that determination;
 - b. The department or the administrator determines that the Title V permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the Title V permit;
 - c. Additional applicable requirements under the Act become applicable to a Title V source, provided that the reopening on this ground is not required if the permit has a remaining term of less than three years, the effective date of the requirement is later than the date on which the permit is due to expire, or the additional applicable requirements are implemented in a general permit that is applicable to the source and the source receives approval for coverage under that general permit. Such a reopening shall be complete not later than 18 months after promulgation of the applicable requirement.
 - d. Additional requirements, including excess emissions requirements, become applicable to a Title IV affected source under the acid rain program. Upon approval by the administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.
 - e. The department or the administrator determines that the permit must be revised or revoked to ensure compliance by the source with the applicable requirements. *567 IAC 22.114(1)*
4. Proceedings to reopen and reissue a Title V permit shall follow the procedures applicable to initial permit issuance and shall effect only those parts of the permit for which cause to reopen exists. *567 IAC 22.114(2)*
5. A notice of intent shall be provided to the Title V source at least 30 days in advance of the date the permit is to be reopened, except that the director may provide a shorter time period in the case of an emergency. *567 IAC 22.114(3)*

G25. Permit Shield

1. The director may expressly include in a Title V permit a provision stating that compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that:
 - a. Such applicable requirements are included and are specifically identified in the permit;
 - or
 - b. The director, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the source, and the permit includes the determination or a concise summary thereof.
2. A Title V permit that does not expressly state that a permit shield exists shall be presumed not to provide such a shield.
3. A permit shield shall not alter or affect the following:
 - a. The provisions of Section 303 of the Act (emergency orders), including the authority of the administrator under that section;

- b. The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance;
- c. The applicable requirements of the acid rain program, consistent with Section 408(a) of the Act;
- d. The ability of the department or the administrator to obtain information from the facility pursuant to Section 114 of the Act. *567 IAC 22.108 (18)*

G26. Severability

The provisions of this permit are severable and if any provision or application of any provision is found to be invalid by this department or a court of law, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected by such finding. *567 IAC 22.108 (8)*

G27. Property Rights

The permit does not convey any property rights of any sort, or any exclusive privilege. *567 IAC 22.108 (9)"d"*

G28. Transferability

This permit is not transferable from one source to another. If title to the facility or any part of it is transferred, an administrative amendment to the permit must be sought consistent with the requirements of *567 IAC 22.111(1)*. *567 IAC 22.111 (1)"d"*

G29. Disclaimer

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions. *567 IAC 22.3(3)"c"*

G30. Notification and Reporting Requirements for Stack Tests or Monitor Certification

The permittee shall notify the department's stack test contact in writing not less than 30 days before a required test or performance evaluation of a continuous emission monitor is performed to determine compliance with applicable requirements of *567 – Chapter 23* or a permit condition. Such notice shall include the time, the place, the name of the person who will conduct the test and other information as required by the department. If the owner or operator does not provide timely notice to the department, the department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with applicable rules or permit conditions. Upon written request, the department may allow a notification period of less than 30 days. At the department's request, a pretest meeting shall be held not later than 15 days prior to conducting the compliance demonstration. A testing protocol shall be submitted to the department no later than 15 days before the owner or operator conducts the compliance demonstration. A representative of the department shall be permitted to witness the tests. Results of the tests shall be submitted in writing to the department's stack test contact in the form of a comprehensive report within six weeks of the completion of the testing. Compliance tests conducted pursuant to this permit shall be conducted with the source operating in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which the source shall be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the equipment manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the department that the source has been physically altered so that capacity cannot be exceeded, or the department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the department to determine whether such source is in compliance.

Stack test notifications, reports and correspondence shall be sent to:

Stack Test Review Coordinator
Iowa DNR, Air Quality Bureau
Wallace State Office Building
502 E 9th St.
Des Moines, IA 50319-0034
(515) 725-9545

Within Polk and Linn Counties, stack test notifications, reports and correspondence shall also be directed to the supervisor of the respective county air pollution program.

567 IAC 25.1(7)"a", 567 IAC 25.1(9)

G31. Prevention of Air Pollution Emergency Episodes

The permittee shall comply with the provisions of 567 IAC Chapter 26 in the prevention of excessive build-up of air contaminants during air pollution episodes, thereby preventing the occurrence of an emergency due to the effects of these contaminants on the health of persons.

567 IAC 26.1(1)

G32. Contacts List

The current address and phone number for reports and notifications to the EPA administrator is:

Iowa Compliance Officer
Air Branch
Enforcement and Compliance Assurance Division
U.S. EPA Region 7
11201 Renner Blvd.
Lenexa, KS 66219
(913) 551-7020

The current address and phone number for reports and notifications to the department or the Director is:

Chief, Air Quality Bureau
Iowa Department of Natural Resources
Wallace State Office Building
502 E 9th St.
Des Moines, IA 50319-0034
(515) 725-8200

Reports or notifications to the DNR Field Offices or local programs shall be directed to the supervisor at the appropriate field office or local program. Current addresses and phone numbers are:

Field Office 1

1101 Commercial Court, Suite 10
Manchester, IA 52057
(563) 927-2640

Field Office 2

2300-15th St., SW
Mason City, IA 50401
(641) 424-4073

Field Office 3

1900 N. Grand Ave.
Spencer, IA 51301
(712) 262-4177

Field Office 4

1401 Sunnyside Lane
Atlantic, IA 50022
(712) 243-1934

Field Office 5

Wallace State Office Building
502 E 9th St.
Des Moines, IA 50319-0034
(515) 725-0268

Field Office 6

1023 West Madison Street
Washington, IA 52353-1623
(319) 653-2135

Polk County Public Works Dept.

Air Quality Division
5885 NE 14th St.
Des Moines, IA 50313
(515) 286-3351

Linn County Public Health

Air Quality Branch
1020 6th Street SE
Cedar Rapids, IA 52401
(319) 892-6000

V. Appendix A: Agency O&M and CAM Plans

Appendix B: NESHAP

1. 40 CFR 63 Subpart ZZZZZZ —National Emission Standards for Hazardous Air Pollutants: Area Source Standards for Aluminum, Copper, and Other Nonferrous Foundries
<https://www.ecfr.gov/current/title-40/chapter-I/subchapter-C/part-63/subpart-ZZZZZZ>