

**Iowa Department of Natural Resources
Title V Operating Permit**

Name of Permitted Facility: Platinum Ethanol LLC
Facility Location: 2585 Quail Avenue, Arthur, IA 51431
Air Quality Operating Permit Number: 10-TV-008
Expiration Date: November 09, 2015
Permit Renewal Application Deadline: May 09, 2015

EIQ Number: 92-6807
Facility File Number: 47-04-001

Responsible Official

Name: Mr. Nick Bowdish
Title: General Manager
Mailing Address: 2585 Quail Avenue, Arthur, IA 51431
Phone #: (712) 367-2700

Permit Contact Person for the Facility

Name: Mr. Darby Sanders
Title: Environmental, Health and Safety Manager
Mailing Address: 2585 Quail Avenue, Arthur, IA 51431
Phone #: (712) 367-2700

This permit is issued in accordance with 567 Iowa Administrative Code Chapter 22, and is issued subject to the terms and conditions contained in this permit.

For the Director of the Department of Natural Resources

Douglas A. Campbell, Supervisor of Air Operating Permits Section

Date

Table of Contents

I. Facility Description and Equipment List	5
II. Plant - Wide Conditions.....	7
III. Emission Point Specific Conditions	11
IV. General Conditions.....	67
G1. Duty to Comply	
G2. Permit Expiration	
G3. Certification Requirement for Title V Related Documents	
G4. Annual Compliance Certification	
G5. Semi-Annual Monitoring Report	
G6. Annual Fee	
G7. Inspection of Premises, Records, Equipment, Methods and Discharges	
G8. Duty to Provide Information	
G9. General Maintenance and Repair Duties	
G10. Recordkeeping Requirements for Compliance Monitoring	
G11. Evidence used in establishing that a violation has or is occurring.	
G12. Prevention of Accidental Release: Risk Management Plan Notification and Compliance Certification	
G13. Hazardous Release	
G14. Excess Emissions and Excess Emissions Reporting Requirements	
G15. Permit Deviation Reporting Requirements	
G16. Notification Requirements for Sources That Become Subject to NSPS and NESHAP Regulations	
G17. Requirements for Making Changes to Emission Sources That Do Not Require Title V Permit Modification	
G18. Duty to Modify a Title V Permit	
G19. Duty to Obtain Construction Permits	
G20. Asbestos	
G21. Open Burning	
G22. Acid Rain (Title IV) Emissions Allowances	
G23. Stratospheric Ozone and Climate Protection (Title VI) Requirements	
G24. Permit Reopenings	
G25. Permit Shield	
G26. Severability	
G27. Property Rights	
G28. Transferability	
G29. Disclaimer	
G30. Notification and Reporting Requirements for Stack Tests or Monitor Certification	
G31. Prevention of Air Pollution Emergency Episodes	
G32. Contacts List	

V. Appendices:81

- A. 40 CFR 60 Subpart A – General Provisions
- B. 40 CFR 60 Subpart Db – Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units
- C. 40 CFR 60 Subpart Kb – Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction or Modification Commenced After July 23, 1984
- D. 40 CFR 60 Subpart VVa – Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry for Which Construction, Reconstruction, or Modification Commenced After November 7, 2006
- E. 40 CFR 60 Subpart IIII – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
- F. 40 CFR 63 Subpart VVVVVV – National Emission Standards for Hazardous Air Pollutants for Chemical Manufacturing Area Sources

Abbreviations

acfm.....	actual cubic feet per minute
CFR.....	Code of Federal Regulation
CE	control equipment
CEM.....	continuous emission monitor
°F.....	degrees Fahrenheit
EIQ.....	emissions inventory questionnaire
EP	emission point
EU	emission unit
gr./dscf	grains per dry standard cubic foot
gr./100 cf.....	grains per one hundred cubic feet
IAC.....	Iowa Administrative Code
IDNR.....	Iowa Department of Natural Resources
MVAC.....	motor vehicle air conditioner
NAICS.....	North American Industry Classification System
NSPS.....	new source performance standard
NESHAP	National Emission Standards for Hazardous Air Pollutants
ppmv	parts per million by volume
lb./hr	pounds per hour
lb./MMBtu	pounds per million British thermal units
SCC	Source Classification Codes
scfm.....	standard cubic feet per minute
SIC	Standard Industrial Classification
TPY	tons per year
USEPA.....	United States Environmental Protection Agency

Pollutants

PM.....	particulate matter
PM ₁₀	particulate matter ten microns or less in diameter
SO ₂	sulfur dioxide
NO _x	nitrogen oxides
VOC	volatile organic compound
CO.....	carbon monoxide
HAP.....	hazardous air pollutant

I. Facility Description and Equipment List

Facility Name: Platinum Ethanol LLC

Permit Number: 10-TV-008

Facility Description: Fuel Ethanol Manufacturing (SIC 2869)

Equipment List

Emission Point Number	Emission Unit Number	Emission Unit Description	IDNR Construction Permit Number
EP-S10	EU-S10	DDGS Dryers and Thermal Oxidizers	07-A-068-S3
EP-S12	EU-S12, S13	Liquefaction Tanks #1 & #2	08-A-537
EP-S20	EU-S20	Grain Receiving, Storage, and Handling System	07-A-069-S2
EP-S30	EU-S30	Hammermilling Process	07-A-070-S2
EP-S40	EU-S40	Fermentation System	07-A-071-S1
EP-S50	EU-S50	Fuel Loadout Flare	07-A-072-S1
EP-S60	EU-S60	Biomethanators	07-A-073-S1
EP-S70	EU-S70	DDGS Cooling System	07-A-074-S1
EP-F80	EU-F80	Cooling Tower	07-A-075-S1
EP-S90	EU-S90	DDGS Loadout	07-A-076-S1
EP-S110	EU-S110	Emergency Diesel Fire Water Pump	07-A-077-S1
EP-S120	EU-S120	Column Grain Dryer	10-A-323
EP-S130	EU-S130	Steel Corn Storage Bin	10-A-324
EP-T01	EU-T01	190 Proof Ethanol Storage Tank	07-A-080-S1
EP-T02	EU-T02	200 Proof Ethanol Storage Tank	07-A-081-S1
EP-T03	EU-T03	Denaturant Storage Tank	07-A-084-S1
EP-T04	EU-T04	Denatured Ethanol Storage Tank #1	07-A-082-S1
EP-T05	EU-T05	Denatured Ethanol Storage Tank #2	07-A-083-S1
EP-T06	EU-T06	Corrosion Inhibitor Storage Tank	08-A-228
EP-FUG5	EU-FUG5	VOC Equipment Leaks	07-A-078-S1
EP-FUG6	EU-FUG6	Haul Roads	07-A-079-S1

Insignificant Activities Equipment List

Insignificant Emission Unit Number	Insignificant Emission Unit Description
E201	Thin Stillage Tank
E202	Syrup Tank
E203	Cook Water Tank
E204	Corn Syrup Storage Tanks 1~4
E205	Whole Stillage Tank
E206	Corn Oil Stillage Tanks 1~4
E207	Temporary Corn Storage Pile
E208	Three DDGS Pellet Mills with Coolers

II. Plant-Wide Conditions

Facility Name: Platinum Ethanol LLC
Permit Number: 10-TV-008

Permit conditions are established in accord with 567 Iowa Administrative Code rule 22.108

Permit Duration

The term of this permit is: Five (5) years from issuance date
Commencing on: November 10, 2010
Ending on: November 15, 2015

Amendments, modifications and reopenings of the permit shall be obtained in accordance with 567 Iowa Administrative Code rules 22.110 - 22.114. Permits may be suspended, terminated, or revoked as specified in 567 Iowa Administrative Code Rules 22.115.

Emission Limits

Unless specified otherwise in the Source Specific Conditions, the following limitations and supporting regulations apply to all emission points at this plant:

Opacity (visible emissions): 40% opacity
Authority for Requirement: 567 IAC 23.3(2)"d"

Sulfur Dioxide (SO₂): 500 parts per million by volume
Authority for Requirement: 567 IAC 23.3(3)"e"

Particulate Matter:

No person shall cause or allow the emission of particulate matter from any source in excess of the emission standards specified in this chapter, except as provided in 567 – Chapter 24. For sources constructed, modified or reconstructed after July 21, 1999, the emission of particulate matter from any process shall not exceed an emission standard of 0.1 grain per dry standard cubic foot of exhaust gas, except as provided in 567 – 21.2(455B), 23.1(455B), 23.4(455B) and 567 – Chapter 24.

For sources constructed, modified or reconstructed prior to July 21, 1999, the emission of particulate matter from any process shall not exceed the amount determined from Table I, or amount specified in a permit if based on an emission standard of 0.1 grain per standard cubic foot of exhaust gas or established from standards provided in 23.1(455B) and 23.4(455B).
Authority for Requirement: 567 IAC 23.3(2)"a"

Fugitive Dust: Attainment and Unclassified Areas - No person shall allow, cause or permit any materials to be handled, transported or stored; or a building, its appurtenances or a construction haul road to be used, constructed, altered repaired or demolished, with the exception of farming operations or dust generated by ordinary travel on unpaved public roads, without taking reasonable precautions to prevent particulate matter in quantities sufficient to create a nuisance, as defined in Iowa Code section 657.1, from becoming airborne. All persons, with the above exceptions, shall take reasonable precautions to prevent the discharge of visible emissions of fugitive dusts beyond the lot line of the property on which the emissions originate. The highway authority shall be responsible for taking corrective action in those cases where said authority has received complaints of or has actual knowledge of dust conditions which require abatement pursuant to this subrule. Reasonable precautions may include, but not limited to, the following procedures.

1. Use, where practical, of water or chemicals for control of dusts in the demolition of existing buildings or structures, construction operations, the grading of roads or the clearing of land.
2. Application of suitable materials, such as but not limited to asphalt, oil, water or chemicals on unpaved roads, material stockpiles, race tracks and other surfaces which can give rise to airborne dusts.
3. Installation and use of containment or control equipment, to enclose or otherwise limit the emissions resulting from the handling and transfer of dusty materials, such as but not limited to grain, fertilizers or limestone.
4. Covering at all times when in motion, open-bodied vehicles transporting materials likely to give rise to airborne dusts.
5. Prompt removal of earth or other material from paved streets or to which earth or other material has been transported by trucking or earth-moving equipment, erosion by water or other means.

Authority for Requirement: 567 IAC 23.3(2)"c"

Compliance Plan

The owner/operator shall comply with the applicable requirements listed below. The compliance status is based on information provided by the applicant.

Unless otherwise noted in Section III of this permit, Platinum Ethanol LLC is in compliance with all applicable requirements and shall continue to comply with all such requirements. For those applicable requirements which become effective during the permit term, Platinum Ethanol LLC shall comply with such requirements in a timely manner.

Authority for Requirement: 567 IAC 22.108(15)

40 CFR 60 Subpart A Requirements

This facility is an affected source and these General Provisions apply to the facility. The affected units are EP-S10, EP-S40, EP-S50, EP-S60, EP-S70, EP-T01, EP-T02, EP-T04, EP-T05, and EP-T06.

See Appendix for the complete text of the Standard.

<http://www.tceq.state.tx.us/permitting/air/rules/federal/60/a/ahp.html>

Applicable requirements are incorporated in the Emission Point Specific conditions.

Authority for Requirements: 40 CFR 60 Subpart A
567 IAC 23.1(2)

40 CFR 60 Subpart Db Requirements

This facility is subject to Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units. The affected unit is EP-S10.

See Appendix for the complete text of the Standard.

<http://www.epa.gov/ttn/atw/combust/boiler/fr13jn07.pdf>

Applicable requirements are incorporated in the Emission Point Specific conditions.

Authority for Requirements: 40 CFR 60 Subpart Db
567 IAC 23.1(2) "ccc"

40 CFR 60 Subpart Kb Requirements

This facility is subject to the Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for which Construction, Reconstruction, or Modification Commenced after July 23, 1984. The affected units are EP-T03, EP-T04, and EP-T05.

See Appendix for the complete text of the Standard.

<http://www.tceq.state.tx.us/permitting/air/rules/federal/60/kb/kbhp.html>

Applicable requirements are incorporated in the Emission Point Specific conditions.

Authority for Requirements: 40 CFR 60 Subpart Kb
567 IAC 23.1(2) "ddd"

40 CFR 60 Subpart VVa Requirements

This facility is subject to the Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry for Which Construction, Reconstruction, or Modification Commenced After November 7, 2006. The affected units are EP-S10, EP-S40, EP-S50, EP-S60, EP-S70, EP-T01, EP-T02, EP-T04, EP-T05, and EP-T06.

See Appendix for the complete text of the Standard.

<http://ecfr.gpoaccess.gov/cgi/t/text/text-idx?c=ecfr;sid=c8befe3824fe313842b2251681aacec3;rgn=div6;view=text;node=40%3A6.0.1.1.1.62;idno=40;cc=ecfr>

Applicable requirements are incorporated in the Emission Point Specific conditions.

Authority for Requirements: 40 CFR 60 Subpart VVa
567 IAC 23.1(2) "nn"

40 CFR 60 Subpart III Requirements

This facility is subject to Standards of Performance for Stationary Compression Ignition Internal Combustion Engines. The affected unit is EP-S110.

See Appendix for the complete text of the Standard.

<http://www.epa.gov/ttn/atw/nsps/cinsps/fr11jy06.pdf>

Applicable requirements are incorporated in the Emission Point Specific conditions.

Authority for Requirements: 40 CFR 60 Subpart III
567 IAC 23.1(2) "yyy"

40 CFR 63 Subpart VVVVVV Requirements

Platinum Ethanol LLC is of the source type regulated by 40 CFR Part 63 Subpart VVVVVV- National Emission Standards for Hazardous Air Pollutants (NESHAP) for Chemical Manufacturing Area Sources. At the time of permit issuance, the Department has not adopted this subpart. Until such time that the Department adopts this subpart, USEPA is the administrator of Subpart VVVVVV. The compliance date for existing plants is October 29, 2012.

The affected units are EP-S10, EP-S40, EP-S70, EP-S90, and EP-FUG5.

<http://ecfr.gpoaccess.gov/cgi/t/text/text->

[idx?c=ecfr;rgn=div6;view=text;node=40%3A14.0.1.1.1.32;idno=40;sid=ce9a35561527d91c91cb d8738090c8ab;cc=ecfr](http://ecfr.gpoaccess.gov/cgi/t/text/text-idx?c=ecfr;rgn=div6;view=text;node=40%3A14.0.1.1.1.32;idno=40;sid=ce9a35561527d91c91cb d8738090c8ab;cc=ecfr)

Authority for Requirements: 40 CFR 63 Subpart VVVVVV

III. Emission Point-Specific Conditions

Facility Name: Platinum Ethanol LLC
 Permit Number: 10-TV-008

Emission Point ID Number: EP-S10

Associated Equipment

Associated Emission Unit ID Numbers: EU-S10
 Emissions Control Equipment ID Number: CE-C10A, CE-C10B
 Emissions Control Equipment Description: Thermal Oxidizer
 Continuous Emissions Monitors ID Numbers: None

Emission Unit Descriptions, Raw Material/Fuel, and Rated Capacity are listed in the following table:

EP=Emission Point, EU=Emission Unit

EP	EU	Emission Unit Description	Raw Material	Rated Capacity
EP-S10	EU-01	DDGS Dryer A	Natural Gas	45 MMBtu/hr
	EU-02	DDGS Dryer B	Natural Gas	45 MMBtu/hr
	EU-03	DDGS Dryer C	Natural Gas	45 MMBtu/hr
	EU-04	DDGS Dryer D	Natural Gas	45 MMBtu/hr
	CE-C10A	Thermal Oxidizer A	Natural Gas	122 MMBtu/hr
	CE-C10B	Thermal Oxidizer B	Natural Gas	122 MMBtu/hr

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40% ⁽¹⁾

Authority for Requirement: 567 IAC 23.3(2) "d"

⁽¹⁾An exceedance of the indicator opacity of "No Visible Emissions" will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM₁₀)

Emission Limit(s): 10.0 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-068-S3

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/dscf; 10.0 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-068-S3
 567 IAC 23.4(7)

Pollutant: Sulfur Dioxide (SO₂)
Emission Limit(s): 22.8 lb/hr; 500ppmv
Authority for Requirement: Iowa DNR Construction Permit 07-A-068-S3
567 IAC 23.3(3)

Pollutant: Nitrogen Oxides (NO_x)
Emission Limit(s): 0.1 lb/MMBtu; 34.3 lb/hr
Authority for Requirement: Iowa DNR Construction Permit 07-A-068-S3

Pollutant: Volatile Organic Compounds (VOC)
Emission Limit(s): 7.5 lb/hr
Authority for Requirement: Iowa DNR Construction Permit 07-A-068-S3

Pollutant: Carbon Monoxide (CO)
Emission Limit(s): 34.4 lb/hr
Authority for Requirement: Iowa DNR Construction Permit 07-A-068-S3

Pollutant: Single HAP
Emission Limit(s): 2.10 lb/hr; 9.4 ton/yr
Authority for Requirement: Iowa DNR Construction Permit 07-A-068-S3

Pollutant: Total HAP
Emission Limit(s): 5.57 lb/hr; 24.4 ton/yr
Authority for Requirement: Iowa DNR Construction Permit 07-A-068-S3

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. The thermal oxidizers shall maintain a temperature (3 hour average) during operation of within minus 50 degrees Fahrenheit of the average temperature of the oxidizer recorded during the most recent performance test which demonstrated compliance with the emission limits. The thermal oxidizers shall be operated at all times the dryers or distillation equipment is being used.
- B. The dryers/thermal oxidizer systems shall combust only natural gas and/or process off-gases.
- C. The control equipment shall be inspected and maintained according to manufacturer's recommendations.
- D. Plant-wide, DDGS Production shall not exceed 438,750 tons per rolling twelve (12) month period.
- E. Plant-wide, grain usage shall not exceed 48,214,286 bushels per rolling twelve (12) month period.
- F. The amount of anhydrous ammonia or sulfuric acid usage shall be maintained at the same rate or less than that rate demonstrated during compliance testing.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep hourly records of the operating temperatures of each thermal oxidizer, and record all three-hour periods (during actual operations) during which the average temperature of either thermal oxidizer is more than 50 degrees Fahrenheit below the average temperature of the oxidizer during its most recent performance test which demonstrated compliance with the emission limits.
- B. The owner or operator shall keep records as required in 40 CFR §60.486, and reports as required in 40 CFR §60.487.
- C. The owner or operator shall keep records of control equipment inspections and repairs.
- D. The owner or operator shall record and maintain records of the amounts of each fuel combusted during each day, and calculate the annual capacity factor on a rolling twelve month average basis with a new annual capacity factor calculated at the end of each calendar month, as required in 40 CFR §60.49b (d). The annual capacity factor is defined as the ratio between the actual heat input to a steam generating unit during a calendar year, and the potential heat input had it been operated for 8,760 hours during a calendar year at the maximum steady state design heat input capacity.
- E. The owner or operator shall maintain records of the following information for each steam generating unit operating day, as required in 40 CFR §60.49b(g). This information shall also be submitted in a report, as required in 40 CFR §60.49b(i):
 - E1. Calendar date
 - E2. Average hourly nitrogen oxides emission (as NO₂) rates measured or predicted.
 - E3. 30-day average nitrogen oxides emission rates calculated at the end of each steam generating unit operating day from the measured hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days.
 - E4. Identification of the steam generating unit operating days when the calculated 30-day average nitrogen oxides emission rates are in excess of the emission standard, with the reason for such excess emissions as well as a description of corrective actions taken.
 - E5. Identification of the steam generating unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken.
 - E6. Identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data.
 - E7. Identification of "F" factor used for calculations, method of determination, and type of fuel combusted.
 - E8. Identification of the times when the pollutant concentrations exceeded the full span of the continuous monitoring system.
 - E9. Description of any modifications to the continuous monitoring system that could affect the ability of the CEMS to comply with Performance Specification 2 or 3.
 - E10. Results of daily CEMS drift tests and quarterly accuracy assessments as required under 40 CFR Appendix F, Procedure 1.

- F. Plant-wide, for the first twelve (12) months of operation, the owner or operator shall determine the amount of DDGS for each month of operation. After the first twelve (12) months of operation, the owner or operator shall determine the cumulative amount of DDGS on a rolling 12-month basis for each month of operation.
- G. Plant-wide, for the first twelve (12) months of operation, the owner or operator shall determine the amount of grain received for each month of operation. After the first twelve (12) months of operation, the owner or operator shall determine the cumulative amount of grain received on a rolling 12-month basis for each month of operation.
- H. The owner or operator shall maintain a record of the test results, which demonstrated compliance, documenting the rate of anhydrous ammonia and sulfuric acid were used in the process. For the first twelve (12) months of operation, the owner or operator shall determine the amount of anhydrous ammonia and sulfuric acid used in the process for each month of operation. After the first twelve (12) months of operation, the owner or operator shall determine the cumulative amount of anhydrous ammonia and sulfuric acid used in the process on a rolling 12-month basis for each month of operation.

Authority for Requirement: Iowa DNR Construction Permit 07-A-068-S3

Continuous Emission Monitoring

The owner or operator shall install, calibrate, maintain and operate a continuous monitoring system, and record the output of the system, for measuring nitrogen oxides emissions discharged to the atmosphere. The CEM shall be operated and data collected as required under 40 CFR §60.48b(c), (d), (e) and (f). Alternatively, monitoring may be accomplished under the rules of 40 CFR §60.48b (g).

Authority for Requirement: Iowa DNR Construction Permit 07-A-068-S3

NSPS and NESHAP Applicability

This emission point is subject to NSPS Subpart A – General Provisions;
NSPS Subpart Db – Standards of Performance for Industrial – Commercial – Institutional Steam Generating Units;

NSPS Subpart VVa – Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry for Which Construction, Reconstruction, or Modification Commenced After November 7, 2006.

This emission point is not subject to any of the NESHAP at this time.

Authority for Requirement: Iowa DNR Construction Permit 07-A-068-S3

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 125

Stack Opening, (inches, dia.): 121

Exhaust Flow Rate (scfm): 153,392

Exhaust Temperature (°F): 300

Discharge Style: Vertical, Unobstructed

Authority for Requirement: Iowa DNR Construction Permit 07-A-068-S3

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

The following emission units are vented through this emission point (EP-S10) and the associated control equipment, (CE-C10A and CE-C10B).

Emission Unit	Emission Unit ID	Maximum Capacity
DDGS Dryers A – D	EU 01, EU 02, EU 03, & EU 04	45 MMBtu/hr (each)
Process Distillation Vents	EU 05	14,000 Gallons/hr
Mixer	EU 06	6,000 Bu/hr
Slurry Tank A and Tank B	EU 07 & EU 08	25,000 Gallons (each)
Cook Tube	EU 09	10,400 Gallons
Flash Tank	EU 10	4,500 Gallons
Receiver Tank	EU 11	470 Gallons
Yeast Tank A and Tank B	EU 14 & EU 15	13,000 Gallons (each)
Beer Column	EU 16	135 MMGallons/yr
Side Stripper	EU 17	135 MMGallons/yr
Rectifier Column	EU 18	135 MMGallons/yr
190 Proof Condenser	EU 19	135 MMGallons/yr
Molecular Sieves (8 total)	EU E47 to E52, E106, E107	135 MMGallons/yr (total)
200 Proof Condenser	EU 26	135 MMGallons/yr
Centrifuges (#1 - #6)	EU 27 through EU 32	44.4 tons/hr (total)
Evaporators (#1 - #8)	EU 33 through EU 40	44.4 tons/hr (total)

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Stack Testing:

Pollutant – Opacity, PM₁₀, PM, NO_x, VOC, CO, single HAP and total HAP

Platinum Ethanol LLC shall conduct one time stack testing for visible emissions, particulate matter, NO_x, VOC, CO, single HAP and total HAP. The most recent compliance test shall represent emissions from EP-S10. Last performance test on EP-S10 was conducted on 03/10/2009 and 06/23/2009. Acrolein, acetaldehyde, formaldehyde and methanol shall be tested for specifically. With the exception of acrolein, acetaldehyde, formaldehyde and methanol, any HAP whose emissions are less than the detection limit shall be assumed to be zero. Emission testing shall be completed at least once per calendar year. The time between testing shall be at least 3 months.

Emission testing for acetaldehyde shall be completed on a quarterly basis. Provided testing demonstrates no exceedance of the plant-wide limit on HAP (9.4 tons for any single HAP), the plant may request reduced frequency of testing after six (6) tests have been completed. (NOTE: plant-wide acetaldehyde emissions are required to be accounted for when calculating emissions and determining compliance.)

Test Method – See the table below

Pollutant	Test Run Time	Test Method
PM (state)	1 hour	Iowa Compliance Sampling Manual Method 5
PM ₁₀	1 hour	40 CFR 51, Appendix M, 201A with 202
Opacity	1 hour	40 CFR 60, Appendix A, Method 9
NO _x	1 hour	40 CFR 60, Appendix A, Method 7E
VOC	1 hour	40 CFR 60, Appendix A, Method 25A
CO	1 hour	40 CFR 60, Appendix A, Method 10
Pb	1 hour	40 CFR 60, Appendix A, Method 12
Total HAP	1 hour	According to IDNR approved method

Authority for Requirement Iowa DNR Construction Permit 07-A-068-S3

Continuous Emissions Monitoring:

The owner or operator shall install, calibrate, maintain and operate a continuous monitoring system, and record the output of the system, for measuring nitrogen oxides emissions discharged to the atmosphere. The CEM shall be operated and data collected as required under 40 CFR §60.48b(c), (d), (e) and (f). Alternatively, monitoring may be accomplished under the rules of 40 CFR §60.48b(g).

Authority for Requirement Iowa DNR Construction Permit 07-A-068-S3

The owner of this equipment or the owner’s authorized agent shall provide written notice to the Director, not less than 30 days before a required stack test or performance evaluation of a continuous emission monitor. Results of the test shall be submitted in writing to the Director in the form of a comprehensive report within 6 weeks of the completion of the testing. 567 IAC 25.1(7)

Agency Approved Operation & Maintenance Plan Required?

Yes No

Facility Maintained Operation & Maintenance Plan Required?

Yes No

Compliance Assurance Monitoring (CAM) Plan Required?

Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-S12

Associated Equipment

Associated Emission Unit ID Numbers: EU-S12 & EU-S13

Emissions Control Equipment ID Number: None

Emissions Control Equipment Description: None

Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EU-S12 & EU-S13

Emission Unit Description: Liquefaction Tanks #1 & #2

Raw Material/Fuel: Mash

Rated Capacity: 1,550 gal/min

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Volatile Organic Compounds (VOC)

Emission Limit(s): 6.0 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 08-A-537

Pollutant: Single HAP

Emission Limit(s): 2.10 lb/hr; 9.4 ton/yr

Authority for Requirement: Iowa DNR Construction Permit 08-A-537

Pollutant: Total HAP

Emission Limit(s): 5.57 lb/hr; 24.4 ton/yr

Authority for Requirement: Iowa DNR Construction Permit 08-A-537

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operational limits are not required at this time.

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (from the ground): 42'10"

Stack Opening, (inches, dia.): 8

Exhaust Flow Rate (scfm): Working and Breathing Loss

Exhaust Temperature (°F): Ambient

Discharge Style: Downward

Authority for Requirement: Iowa DNR Construction Permit 08-A-537

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-S20

Associated Equipment

Associated Emission Unit ID Numbers: EU-S20
Emissions Control Equipment ID Number: Baghouse
Emissions Control Equipment Description: CE-C20
Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EU-S20
Emission Unit Description: Grain Receiving, Storage, and Handling System
Raw Material/Fuel: Whole Kernel Corn
Rated Capacity: 40,000 Bu/hr

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40% ⁽¹⁾

Authority for Requirement: Iowa DNR Construction Permit 07-A-069-S2
567 AIC 23.3(2) "d"

⁽¹⁾An exceedance of the indicator opacity of "No Visible Emissions" will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedance continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM₁₀)

Emission Limit(s): 1.67 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-069-S2
NAAQS

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/dscf; 1.67 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-069-S2
567 IAC 23.4(7)

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. The owner or operator shall inspect and maintain the control equipment according to manufacturer's specifications.
- B. The owner/operator is limited to receiving no more than a facility wide total of 48,214,286 bushels of grain into the facility per rolling 12-month period.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep records of control equipment inspection and maintenance.
- B. The owner or operator shall calculate the amount of grain received per rolling 12-month period.

Authority for Requirement: Iowa DNR Construction Permit 07-A-069-S2

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 160

Stack Opening, (inches, dia.): 44

Exhaust Flow Rate (scfm): 39,000

Exhaust Temperature (°F): Ambient

Discharge Style: Vertical, Unobstructed

Authority for Requirement: Iowa DNR Construction Permit 07-A-069-S2

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

The following emission units are vented through this emission point (EP-S20) and the associated control equipment, (CE-C20).

Emission Unit	Emission Unit ID	Maximum Capacity
Truck and Truck/Rail Receiving Areas	EU-43 & EU-44	20,000 Bu/hr (each)
Storage Conveyor	EU-45	7,500 Bu/hr
Grain Elevator #1	EU-46	20,000 Bu/hr
Grain Silo #1 and Grain Silo #2	EU-47 & EU-48	1.0 MMBushels (combined total)
Emptying Conveyor	EU-49	7,500 Bu/hr
Grain Elevator #2	EU-50	20,000 Bu/hr
Grain Day Bin #1 and Day Bin #2	EU-51 & EU-52	36,000 Bushels (combined total)

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Stack Testing:

Pollutant – Opacity, PM₁₀ and PM

Platinum Ethanol LLC shall conduct one time stack testing for particulate matter and visible emissions. The most recent compliance test shall represent emissions from EP-S20. Last performance test on EP-S20 was conducted on 03/12/2009.

Test Method – See the table below

Pollutant	Test Run Time	Test Method
PM (state)	4 hours	Iowa Compliance Sampling Manual Method 5
PM ₁₀	7 hours	40 CFR 51, Appendix M, 201A with 202
Opacity	1 hour	40 CFR 60, Appendix A, Method 9

Authority for Requirement Iowa DNR Construction Permit 07-A-068-S3

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Facility operation and maintenance plans must be sufficient to yield reliable data from the relevant time period that are representative of the source’s compliance with the applicable requirements.

Facility operation and maintenance plans are to be developed by the facility within six (6) months of the issuance date of this permit and the data pertaining to the plan maintained on site for at least 5 years. The plan and associated recordkeeping provides documentation of this facility’s implementation of its obligation to operate according to good air pollution control practice.

Good air pollution control practice is achieved by adoption of quality control standards in the operation and maintenance procedures for air pollution control that are comparable to industry quality control standards for the production processes associated with this emission point.

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-S30

Associated Equipment

Associated Emission Unit ID Numbers: EU-S30 (Including EU-53: Hammermill Feed Conveyor 10,000 Bushel/hr, EU-54 through EU-57: Hammermills #1~#4, 100.0 ton/hr each)

Emissions Control Equipment ID Number: CE-C30

Emissions Control Equipment Description: Baghouse

Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EU-S30

Emission Unit Description: Hammermilling Process

Raw Material/Fuel: Whole Kernel Corn

Rated Capacity: 400.0 ton/hr

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40% ⁽¹⁾

Authority for Requirement: Iowa DNR Construction Permit 07-A-070-S2
567 IAC 23.3(2) "d"

⁽¹⁾An exceedance of the indicator opacity of "No Visible Emissions" will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM₁₀)

Emission Limit(s): 1.2 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-070-S2

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/dscf; 1.2 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-070-S2
567 IAC 23.4(7)

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. The owner or operator shall inspect and maintain the control equipment according to manufacturer's specifications.
- B. The owner/operator is limited to receiving no more than a facility wide total of 48,214,286 bushels of grain into the facility per rolling 12-month period.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep records of control equipment inspection and maintenance.
- B. The owner or operator shall calculate the amount of grain received per rolling 12-month period.

Authority for Requirement: Iowa DNR Construction Permit 07-A-070-S2

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 160

Stack Opening, (inches, dia.): 40

Exhaust Flow Rate (scfm): 28,000

Exhaust Temperature (°F): Ambient

Discharge Style: Vertical, Unobstructed

Authority for Requirement: Iowa DNR Construction Permit 07-A-070-S2

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Stack Testing:

Pollutant – Opacity, PM₁₀ and PM

Platinum Ethanol LLC shall conduct one time stack testing for particulate matter and visible emissions. The most recent compliance test shall represent emissions from EP-S30. Last performance test on EP-S30 was conducted on 03/11/2009.

Test Method – See the table below

Pollutant	Test Run Time	Test Method
PM (state)	4 hours	Iowa Compliance Sampling Manual Method 5
PM ₁₀	7 hours	40 CFR 51, Appendix M, 201A with 202
Opacity	1 hour	40 CFR 60, Appendix A, Method 9

Authority for Requirement Iowa DNR Construction Permit 07-A-070-S2

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Facility operation and maintenance plans must be sufficient to yield reliable data from the relevant time period that are representative of the source's compliance with the applicable requirements.

Facility operation and maintenance plans are to be developed by the facility within six (6) months of the issuance date of this permit and the data pertaining to the plan maintained on site for at least 5 years. The plan and associated recordkeeping provides documentation of this facility's implementation of its obligation to operate according to good air pollution control practice.

Good air pollution control practice is achieved by adoption of quality control standards in the operation and maintenance procedures for air pollution control that are comparable to industry quality control standards for the production processes associated with this emission point.

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-S40

Associated Equipment

Associated Emission Unit ID Numbers: EU-S40 (Including EU-58 through EU-64: Fermenters #1~ #9, 807,000 gallons, each, EU-65: Beerwell, 1.8 million gallons)

Emissions Control Equipment ID Number: CE-C40

Emissions Control Equipment Description: CO₂ Scrubber

Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EU-S40

Emission Unit Description: Fermentation Process

Raw Material/Fuel: Process Gas

Rated Capacity: 15,410.0 gal/hr

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40% ⁽¹⁾

Authority for Requirement: Iowa DNR Construction Permit 07-A-071-S2
567 IAC 23.3(2) "d"

⁽¹⁾An exceedance of the indicator opacity of "No Visible Emissions" will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM₁₀)

Emission Limit(s): 0.14 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-071-S2

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/dscf; 0.14 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-071-S2
567 IAC 23.3(2) "a"

Pollutant: Volatile Organic Compounds (VOC)

Emission Limit(s): 14.0 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-071-S2

Pollutant: Single HAPs

Emission Limit(s): 2.10 lb/hr; 9.4 ton/yr

Authority for Requirement: Iowa DNR Construction Permit 07-A-071-S2

Pollutant: Total HAPs

Emission Limit(s): 5.57 lb/hr; 24.4 ton/yr

Authority for Requirement: Iowa DNR Construction Permit 07-A-071-S2

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. The owner or operator shall inspect and maintain the control equipment according to manufacturer's specifications.
- B. The owner or operator shall follow the applicable standards of Subpart VVa, 40 CFR §60.480a through §60.489a.
- C. The amount of **sodium or ammonium bisulfite** used shall be maintained at the same rate or greater than that rate demonstrated during compliance testing.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep records of control equipment inspection and maintenance.
- B. The owner or operator shall keep records as required in 40 CFR §60.486a, and reports as required in 40 CFR §60.487a.
- C. The owner or operator shall maintain records of the completed testing for HAPs, which clearly shows the amount of **sodium or ammonium bisulfite** used during that test. The owner or operator shall record the **sodium or ammonium bisulfite** used per day.

Authority for Requirement: Iowa DNR Construction Permit 07-A-071-S2

NSPS and NESHAP Applicability

This emission point is subject to NSPS Subpart A – General Provisions and NSPS Subpart VVa – Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry for which Construction, Reconstruction, or Modification Commenced after November 7, 2006.

Authority for Requirement: Iowa DNR Construction Permit 07-A-071-S2

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 75

Stack Opening, (inches, dia.): 27

Exhaust Flow Rate (scfm): 13,272

Exhaust Temperature (°F): 76

Discharge Style: Vertical, Unobstructed

Authority for Requirement: Iowa DNR Construction Permit 07-A-071-S2

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Stack Testing:

Pollutant – VOC and Total HAPs

Platinum Ethanol LLC shall conduct stack testing for VOC and total HAP observation on EP-S40. Last performance test on EP-S40 was conducted on 03-13-2009 and 06-23-09. VOC shall be tested on annual basis and the time between testing shall be at least 3 months.

Acrolein, acetaldehyde, formaldehyde, and methanol shall be tested for specifically. With the exception of acrolein, acetaldehyde, formaldehyde, and methanol, any HAP whose emissions are less than the detection limit shall be assumed to be zero. Emission testing shall be completed at least once per calendar year. The time between testing shall be at least 3 months.

Emission testing for acetaldehyde shall be completed on a quarterly basis. Provided testing demonstrates no exceedance of the plant-wide limit on HAP (9.4 tons for any single HAP), the plant may request reduced frequency of testing after six (6) tests have been completed. (NOTE: plant-wide acetaldehyde emissions are required to be accounted for when calculating emissions and determining compliance.)

Test Method – See the table below

Pollutant	Test Run Time	Test Method
VOC	1 hour	40 CFR 60, Appendix A, Method 25A
Total HAP	1 hour	According to IDNR approved method

Authority for Requirement - Iowa DNR Construction Permit 07-A-071-S2

The owner of this equipment or the owner’s authorized agent shall provide written notice to the Director, not less than 30 days before a required stack test or performance evaluation of a continuous emission monitor. Results of the test shall be submitted in writing to the Director in the form of a comprehensive report within 6 weeks of the completion of the testing. 567 IAC 25.1(7)

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-S50

Associated Equipment

Associated Emission Unit ID Numbers: EU-S50 (EU-67)

Emissions Control Equipment ID Number: CE-C50

Emissions Control Equipment Description: Flare with Vapor Recovery System

Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EU-67

Emission Unit Description: Flare Loadout Rack

Raw Material/Fuel: Waste Gas

Rated Capacity: 12.4 MMBtu/hr

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%

Authority for Requirement: 567 IAC 23.3(2)"d"

Pollutant: Particulate Matter (PM₁₀)

Emission Limit(s): 0.50 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-072-S1

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.50 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-072-S1

Pollutant: Nitrogen Oxides (NO_x)

Emission Limit(s): 2.04 ton/yr

Authority for Requirement: Iowa DNR Construction Permit 07-A-072-S1

Pollutant: Volatile Organic Compounds (VOC)

Emission Limit(s): 7.20 ton/yr

Authority for Requirement: Iowa DNR Construction Permit 07-A-072-S1

Pollutant: Carbon Monoxide (CO)

Emission Limit(s): 5.00 ton/yr

Authority for Requirement: Iowa DNR Construction Permit 07-A-072-S1

Pollutant: Single HAPs

Emission Limit(s): 9.4 ton/yr

Authority for Requirement: Iowa DNR Construction Permit 07-A-072-S1

Pollutant: Total HAPs

Emission Limit(s): 24.4 ton/yr

Authority for Requirement: Iowa DNR Construction Permit 07-A-072-S1

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. The total amount denatured ethanol transported through the truck loading and rail loading shall not exceed 135,000,000 gallons per twelve-month rolling period.
- B. The flare shall be limited to operating 4,818 hours per twelve-month rolling period. (NOTE: the pilot light is allowed to operate 8760 hours per year).
- C. The control equipment shall be used whenever product is loaded through the rail or truck loadout.
- D. The flare shall be operated per the requirements of NSPS Subpart A - §60.18.
- E. The control equipment shall be inspected and maintained according to manufacturer's recommendations.
- F. Plant-wide HAP emissions shall not exceed 9.4 tons for any single HAP or 24.4 tons for all HAPs per twelve-month rolling period.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. Record the total amount of denatured ethanol transported through the truck & rail loadout per twelve-month rolling period.
- B. Record the number of hours the flare is operated per twelve-month rolling period.
- C. The owner or operator shall keep records of control equipment inspections and repairs.
- D. Plant-wide, record the HAP emissions (in tons) for each HAP and all HAPs per twelve-month rolling period.

Authority for Requirement: Iowa DNR Construction Permit 07-A-072-S1

NSPS and NESHAP Applicability

This emission point is subject to NSPS Subpart A – General Provisions and NSPS Subpart VVa – Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry for which Construction, Reconstruction, or Modification Commenced after November 7, 2006.

Authority for Requirement: Iowa DNR Construction Permit 07-A-072-S1

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 30

Stack Opening, (inches, dia.): 60

Exhaust Flow Rate (scfm): 300

Exhaust Temperature (°F): 1,800

Discharge Style: Vertical, Unobstructed

Authority for Requirement: Iowa DNR Construction Permit 07-A-072-S1

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Facility operation and maintenance plans must be sufficient to yield reliable data from the relevant time period that are representative of the source’s compliance with the applicable requirements.

Facility operation and maintenance plans are to be developed by the facility within six (6) months of the issuance date of this permit and the data pertaining to the plan maintained on site for at least 5 years. The plan and associated recordkeeping provides documentation of this facility’s implementation of its obligation to operate according to good air pollution control practice.

Good air pollution control practice is achieved by adoption of quality control standards in the operation and maintenance procedures for air pollution control that are comparable to industry quality control standards for the production processes associated with this emission point.

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-S60

Associated Equipment

Associated Emission Unit ID Numbers: EU-S60 (Including EU68 through EU71: Methanators #1~#4, 30,000 gallons each)

Emissions Control Equipment ID Number: CE-C60

Emissions Control Equipment Description: Biomethanator Flare

Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EU-S60

Emission Unit Description: Biomethanators

Raw Material/Fuel: Waste Gas

Rated Capacity: 6.4 MMBtu/hr

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%

Authority for Requirement: 567 IAC 23.3(2)"d"

Pollutant: Particulate Matter (PM₁₀)

Emission Limit(s): 0.25 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-073-S1

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.25 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-073-S1

Pollutant: Nitrogen Oxides (NO_x)

Emission Limit(s): 0.97 ton/yr

Authority for Requirement: Iowa DNR Construction Permit 07-A-073-S1

Pollutant: Volatile Organic Compounds (VOC)

Emission Limit(s): 0.74 ton/yr

Authority for Requirement: Iowa DNR Construction Permit 07-A-073-S1

Pollutant: Carbon Monoxide (CO)

Emission Limit(s): 5.27 ton/yr

Authority for Requirement: Iowa DNR Construction Permit 07-A-073-S1

Pollutant: Single HAPs

Emission Limit(s): 9.4 ton/yr

Authority for Requirement: Iowa DNR Construction Permit 07-A-073-S1

Pollutant: Total HAPs

Emission Limit(s): 24.4 ton/yr

Authority for Requirement: Iowa DNR Construction Permit 07-A-073-S1

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. The flare shall be limited to operating 4,380 hours per twelve-month rolling period. (NOTE: the pilot light is allowed to operate 8760 hours per year).
- B. The methanators shall be controlled by either the biomethanator flare or the thermal oxidizers (via the dryers). The methanators shall at no time operate uncontrolled.
- C. The flare shall be operated per the requirements of NSPS Subpart A - §60.18.
- D. The control equipment shall be inspected and maintained according to manufacturer's recommendations.
- E. Plant-wide HAP emissions shall not exceed 9.4 tons for any single HAP or 24.4 tons for all HAPs per twelve-month rolling period.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. Record the number of hours the flare is operated per twelve-month rolling period.
- B. The owner or operator shall keep records of control equipment inspections and repairs.
- C. Plant-wide, record the HAP emissions (in tons) for each HAP and all HAPs per twelve-month rolling period.

Authority for Requirement: Iowa DNR Construction Permit 07-A-073-S1

NSPS and NESHAP Applicability

This emission point is subject to NSPS Subpart A – General Provisions and NSPS Subpart VVa – Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry for which Construction, Reconstruction, or Modification Commenced after November 7, 2006.

Authority for Requirement: Iowa DNR Construction Permit 07-A-073-S1

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 34

Stack Opening, (inches, dia.): 24

Exhaust Flow Rate (scfm): 1,500

Exhaust Temperature (°F): 1,800

Discharge Style: Vertical, Unobstructed

Authority for Requirement: Iowa DNR Construction Permit 07-A-073-S1

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-S70

Associated Equipment

Associated Emission Unit ID Numbers: EU-S70 (EU73)

Emissions Control Equipment ID Number: CE-C70

Emissions Control Equipment Description: Baghouse

Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EU-S70

Emission Unit Description: DDGS Cooling Drum

Raw Material/Fuel: DDGS

Rated Capacity: 44.0 ton/hr

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40% (1)

Authority for Requirement: Iowa DNR Construction Permit 07-A-074-S1
567 IAC 23.3(2) "d"

⁽¹⁾An exceedance of the indicator opacity of "no visible emissions" will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM₁₀)

Emission Limit(s): 1.3 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-074-S1

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/dscf; 1.3 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-074-S1
567 IAC 23.4 (7)

Pollutant: Single HAPs

Emission Limit(s): 9.4 ton/yr

Authority for Requirement: Iowa DNR Construction Permit 07-A-074-S1

Pollutant: Total HAPs

Emission Limit(s): 24.4 ton/yr

Authority for Requirement: Iowa DNR Construction Permit 07-A-074-S1

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. The owner or operator shall inspect and maintain the control equipment according to manufacturer's specifications.
- B. Plant-wide, DDGS Production shall not exceed 438,750 tons per rolling twelve (12) month rolling period.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep records of control equipment inspection and maintenance.
- B. The owner or operator shall calculate the amount of grain received per rolling 12-month period.

Authority for Requirement: Iowa DNR Construction Permit 07-A-074-S1

NSPS and NESHAP Applicability

This emission point is subject to NSPS Subpart A – General Provisions and NSPS Subpart VVa – Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry for which Construction, Reconstruction, or Modification Commenced after November 7, 2006.

Authority for Requirement: Iowa DNR Construction Permit 07-A-074-S1

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 48

Stack Opening, (inches, dia.): 48

Exhaust Flow Rate (scfm): 27,893

Exhaust Temperature (°F): 110

Discharge Style: Vertical, Unobstructed

Authority for Requirement: Iowa DNR Construction Permit 07-A-074-S1

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Stack Testing:

Pollutant –PM, PM10, Opacity, VOC and Total HAPs.

Platinum Ethanol LLC shall conduct stack testing for particulate matter, visible emissions observations, VOC and total HAPs on EP-S70.

In addition, acrolein, acetaldehyde, formaldehyde and methanol shall be tested for specifically. With the exception of acrolein, acetaldehyde, formaldehyde and methanol, any HAP whose emissions are less than the detection limit shall be assumed to be zero. Emission testing shall be completed at least once per calendar year. The time between testing shall be at least 3 months.

Emission testing for acetaldehyde shall be completed on a quarterly basis. Provided testing demonstrates no exceedance of the plant-wide limit on HAP (9.4 tons for any single HAP), the plant may request reduced frequency of testing after six (6) tests have been completed. (NOTE: plant-wide acetaldehyde emissions are required to be accounted for when calculating emissions and determining compliance.)

Last performance test on EP-S70 for particulate matters, VOC and total HAPs was conducted on 03/10/2009. Last performance test for acetaldehyde was conducted on 06/02/2010.

Test Method – See the table below

Pollutant	Test Run Time	Test Method
PM (state)	4 hours	Iowa Compliance Sampling Manual Method 5
PM ₁₀	7 hours	40 CFR 51, Appendix M, 201A with 202
Opacity	1 hour	40 CFR 60, Appendix A, Method 9
VOC	1 hour	40 CFR 60, Appendix A, Method 25A
Total HAP	1 hour	According to IDNR approved method

Authority for Requirement - Iowa DNR Construction Permit 07-A-074-S1

The owner of this equipment or the owner's authorized agent shall provide written notice to the Director, not less than 30 days before a required stack test or performance evaluation of a continuous emission monitor. Results of the test shall be submitted in writing to the Director in the form of a comprehensive report within 6 weeks of the completion of the testing. 567 IAC 25.1(7)

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Facility operation and maintenance plans must be sufficient to yield reliable data from the relevant time period that are representative of the source's compliance with the applicable requirements.

Facility operation and maintenance plans are to be developed by the facility within six (6) months of the issuance date of this permit and the data pertaining to the plan maintained on site for at least 5 years. The plan and associated recordkeeping provides documentation of this facility's implementation of its obligation to operate according to good air pollution control practice.

Good air pollution control practice is achieved by adoption of quality control standards in the operation and maintenance procedures for air pollution control that are comparable to industry quality control standards for the production processes associated with this emission point.

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-F80

Associated Equipment

Associated Emission Unit ID Numbers: EU-F80 (4 Cells)
Emissions Control Equipment ID Number: None
Emissions Control Equipment Description: None
Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EU-S80
Emission Unit Description: Cooling Tower
Raw Material/Fuel: Water
Rated Capacity: 3MMgal/hr

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%

Authority for Requirement: 567 IAC 23.3(2)"d"

Pollutant: Particulate Matter (PM₁₀)

Emission Limit(s): 3.13 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-075-S1

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/dscf; 3.13 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-075-S1
567 IAC 23.3(2) "a"

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. The circulating water in the cooling tower shall not exceed 2500 parts per million (ppm) total dissolved solids (TDS). The owner or operator shall conduct TDS monitoring, at a minimum, on a monthly basis.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall maintain records of the monthly TDS sampling/testing results. The records shall include the testing dates and the methods used to determine the concentration of TDS in the circulating water.

Authority for Requirement: Iowa DNR Construction Permit 07-A-075-S1

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 40

Stack Opening, (inches, dia.): 304

Exhaust Flow Rate (scfm): 3,120,000 (total)

Exhaust Temperature (°F): 85

Discharge Style: Vertical

Authority for Requirement: Iowa DNR Construction Permit 07-A-075-S1

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-S90

Associated Equipment

Associated Emission Unit ID Numbers: EU-S90 (Including EU-74 and EU-75: DDGS Storage Silos, 4000 tons each; EU-76: DDGS Dump Pit Auger, 500 ton/hr; EU-77: DDGS Loadout, 500 ton/hr)

Emissions Control Equipment ID Number: CE-C90

Emissions Control Equipment Description: Baghouse

Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EU-S90

Emission Unit Description: DDGS Loadout

Raw Material/Fuel: DDGS

Rated Capacity: 500 ton/hr

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40% ⁽¹⁾

Authority for Requirement: Iowa DNR Construction Permit 07-A-076-S1

⁽¹⁾An exceedance of the indicator opacity of "No Visible Emissions" will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM₁₀)

Emission Limit(s): 0.47 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-076-S1

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/dscf; 0.47 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-076-S1
567 IAC 23.4 (7)

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. The owner or operator shall inspect and maintain the control equipment according to manufacturer's specifications.
- B. The owner or operator is limited to shipping no more than 438,750 tons of DDGS out of the facility via truck per 12-month rolling period.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep records of control equipment inspection and maintenance.
- B. For the first twelve (12) months of operation, the owner or operator shall determine the amount of DDGS shipped out via truck for each month of operation. After the first twelve (12) months of operation, the owner or operator shall monthly record the amount of DDGS shipped out via truck and calculate the rolling 12-month total amount of DDGS shipped out via truck for each month of operation.

Authority for Requirement: Iowa DNR Construction Permit 07-A-076-S1

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 40

Stack Opening, (inches, dia.): 26

Exhaust Flow Rate (scfm): 9,100

Exhaust Temperature (°F): Ambient

Discharge Style: Vertical, Unobstructed

Authority for Requirement: Iowa DNR Construction Permit 07-A-076-S1

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Stack Testing:

Pollutant –PM and PM10, and Opacity.

Platinum Ethanol LLC shall conduct stack testing for particulate matter and visible emissions observation on EP-S90. Last performance test on EP-S90 was conducted on 03/11/2009.

Test Method – See the table below

Pollutant	Test Run Time	Test Method
PM (state)	4 hours	Iowa Compliance Sampling Manual Method 5
PM ₁₀	7 hours	40 CFR 51, Appendix M, 201A with 202
Opacity	1 hour	40 CFR 60, Appendix A, Method 9

Authority for Requirement - Iowa DNR Construction Permit 07-A-076-S1

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Facility operation and maintenance plans must be sufficient to yield reliable data from the relevant time period that are representative of the source's compliance with the applicable requirements.

Facility operation and maintenance plans are to be developed by the facility within six (6) months of the issuance date of this permit and the data pertaining to the plan maintained on site for at least 5 years. The plan and associated recordkeeping provides documentation of this facility's implementation of its obligation to operate according to good air pollution control practice.

Good air pollution control practice is achieved by adoption of quality control standards in the operation and maintenance procedures for air pollution control that are comparable to industry quality control standards for the production processes associated with this emission point.

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-S110

Associated Equipment

Associated Emission Unit ID Numbers: EU-S110
Emissions Control Equipment ID Number: None
Emissions Control Equipment Description: None
Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EU-S110
Emission Unit Description: Emergency Fire Water Pump
Raw Material/Fuel: Diesel
Rated Capacity: 500 hr/yr

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40% ⁽¹⁾

Authority for Requirement: Iowa DNR Construction Permit 07-A-077-S1

⁽¹⁾An exceedance of the indicator opacity of 10% will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM₁₀)

Emission Limit(s): 0.66 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-077-S1

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/dscf; 0.66 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-077-S1
567 IAC 23.4(7)

Pollutant: Sulfur Dioxide (SO₂)

Emission Limit(s): 2.5 lb/MMBtu; 0.62 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-077-S1
567 IAC 23.3(3)

Pollutant: Nitrogen Oxides (NO_x)

Emission Limit(s): 9.30 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-077-S1

Pollutant: Volatile Organic Compounds (VOC)

Emission Limit(s): 0.09 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-077-S1

Pollutant: Carbon Monoxide (CO)

Emission Limit(s): 2.00 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 07-A-077-S1

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. This emission unit shall operate on #1 or #2 diesel fuel only.
- B. The sulfur content of the fuel used shall not exceed 0.5% (by wt).
- C. This emission unit shall not operate more than 500 hours per rolling twelve (12) month period.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. The type of fuel used and its sulfur content.
- B. For the first twelve (12) months of operation, determine the total amount of hours of operation for each month of operation.
- C. After the first twelve (12) months of operation, determine the cumulative amount of hours of operation on a rolling-12-month basis for each month of operation.

Authority for Requirement: Iowa DNR Construction Permit 07-A-077-S1

NSPS and NESHAP Applicability

This emission point is subject to NSPS Subpart A – General Provisions and NSPS Subpart III – Standards of Performance for Stationary Compression Ignition Internal Combustions Engines – starting at §60.4200.

Authority for Requirement: Iowa DNR Construction Permit 07-A-077-S1

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 8

Stack Opening, (inches, dia.): 3

Exhaust Flow Rate (scfm): 750

Exhaust Temperature (°F): 770

Discharge Style: Vertical, Unobstructed

Authority for Requirement: Iowa DNR Construction Permit 07-A-077-S1

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-S120

Associated Equipment

Associated Emission Unit ID Numbers: EU-S120
Emissions Control Equipment ID Number: None
Emissions Control Equipment Description: None
Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EU-S120
Emission Unit Description: Column Grain Dryer
Raw Material/Fuel: Natural Gas
Rated Capacity: 62.10 MMBtu/hr

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40% ⁽¹⁾

Authority for Requirement: Iowa DNR Construction Permit 10-A-323
567 IAC 23.3(2) "d"

⁽¹⁾ An exceedance of the indicator opacity of "25%" will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedance continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM₁₀)

Emission Limit(s): 21.03 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 10-A-323

Pollutant: Particulate Matter (PM)

Emission Limit(s): 21.03 lb/hr; 0.1 gr/dscf

Authority for Requirement: Iowa DNR Construction Permit 10-A-323
567 IAC 23.4(7)

Pollutant: Sulfur Dioxide (SO₂)

Emission Limit(s): 500 ppmv

Authority for Requirement: Iowa DNR Construction Permit 10-A-323
567 IAC 23.3(3)

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits are not required at this time.

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): NA

Stack Opening, (inches, dia.): NA

Exhaust Flow Rate (scfm): 500,000

Exhaust Temperature (°F): 120

Discharge Style: Horizontal

Authority for Requirement: Iowa DNR Construction Permit 10-A-323

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-S130

Associated Equipment

Associated Emission Unit ID Numbers: EU-S130
Emissions Control Equipment ID Number: CE-C130
Emissions Control Equipment Description: Baghouse
Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EU-S130
Emission Unit Description: Steel Corn Storage Bin
Raw Material/Fuel: Corn
Rated Capacity: 62.1 MMBu/hr

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40% ⁽¹⁾

Authority for Requirement: Iowa DNR Construction Permit 10-A-324
567 IAC 23.3(2) "d"

⁽¹⁾An exceedance of the indicator opacity of "25%" will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedance continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM₁₀)

Emission Limit(s): 2.36 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 10-A-324

Pollutant: Particulate Matter (PM)

Emission Limit(s): 2.36 lb/hr; 0.1 gr/dscf

Authority for Requirement: Iowa DNR Construction Permit 10-A-324
567 IAC 23.4(7)

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. The facility shall install the control equipment (baghouse) prior to receiving any additional grain in this emission unit, EU-S130.
- B. The facility is allowed to process any grain that is currently in the corn storage bin at the time of permit issuance.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. The facility shall record the date the baghouse is operational and submit a notification to the Department. The notification must be postmarked within 15 days after the baghouse is placed into operation.
- B. The facility shall record the date the emission unit next receives grain and submit a notification to the Department. The notification must be postmarked within 15 days after the emission unit next receives grain.

Authority for Requirement: Iowa DNR Construction Permit 10-A-324

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 160

Stack Opening, (inches, dia.): 40

Exhaust Flow Rate (scfm): 27,500

Exhaust Temperature (°F): Ambient

Discharge Style: Vertical, Unobstructed

Authority for Requirement: Iowa DNR Construction Permit 10-A-324

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Facility operation and maintenance plans must be sufficient to yield reliable data from the relevant time period that are representative of the source’s compliance with the applicable requirements.

Facility operation and maintenance plans are to be developed by the facility within six (6) months of the issuance date of this permit and the data pertaining to the plan maintained on site for at least 5 years. The plan and associated recordkeeping provides documentation of this facility’s implementation of its obligation to operate according to good air pollution control practice.

Good air pollution control practice is achieved by adoption of quality control standards in the operation and maintenance procedures for air pollution control that are comparable to industry quality control standards for the production processes associated with this emission point.

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-T01

Associated Equipment

Associated Emission Unit ID Numbers: EUT01
Emissions Control Equipment ID Number: CE-T01
Emissions Control Equipment Description: Internal Floating Roof
Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EUT01
Emission Unit Description: 190 Proof Ethanol Storage Tank
Raw Material/Fuel: 190 Proof Ethanol
Rated Capacity: 200,000 gallon capacity

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Emission limits are not required at this time.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. This tank shall be used to store only 190-proof ethanol.
- B. The owner or operator shall follow the applicable standards of Subpart VVa, 40 CFR §60.480a through 40 CFR §60.489a.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep records as required in 40 CFR §60.486a, and reports as required in 40 CFR §60.487a.

Authority for Requirement: Iowa DNR Construction Permit 07-A-080-S1

NSPS and NESHAP Applicability

This emission point is subject to NSPS Subpart A – General Provisions and NSPS Subpart VVa – Standards of Performance for Equipment Leaks of VOV in the Synthetic Organic Chemicals Manufacturing Industry for which Construction, Reconstruction, or Modification Commenced after November 7, 2006.

Authority for Requirement: Iowa DNR Construction Permit 07-A-080-S1

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 33.25

Stack Opening, (inches, dia.): 10

Exhaust Flow Rate (scfm): Working & Breathing Loss

Exhaust Temperature (°F): Ambient

Discharge Style: Downward

Authority for Requirement: Iowa DNR Construction Permit 07-A-080-S1

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-T02

Associated Equipment

Associated Emission Unit ID Numbers: EUT02
Emissions Control Equipment ID Number: CE-T02
Emissions Control Equipment Description: Internal Floating Roof
Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EUT02
Emission Unit Description: 200 Proof Ethanol Storage Tank
Raw Material/Fuel: 200 Proof Ethanol
Rated Capacity: 200,000 gallon capacity

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Emission limits are not required at this time.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. This tank shall be used to store only 200-proof ethanol.
- B. The owner or operator shall follow the applicable standards of Subpart VVa, 40 CFR §60.480a through 40 CFR §60.489a.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep records as required in 40 CFR §60.486a, and reports as required in 40 CFR §60.487a.

Authority for Requirement: Iowa DNR Construction Permit 07-A-081-S1

NSPS and NESHAP Applicability

This emission point is subject to NSPS Subpart A – General Provisions and NSPS Subpart VVa – Standards of Performance for Equipment Leaks of VOV in the Synthetic Organic Chemicals Manufacturing Industry for which Construction, Reconstruction, or Modification Commenced after November 7, 2006.

Authority for Requirement: Iowa DNR Construction Permit 07-A-081-S1

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 33.25

Stack Opening, (inches, dia.): 10

Exhaust Flow Rate (scfm): Working & Breathing Loss

Exhaust Temperature (°F): Ambient

Discharge Style: Downward

Authority for Requirement: Iowa DNR Construction Permit 07-A-081-S1

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-T03

Associated Equipment

Associated Emission Unit ID Numbers: EUT03
Emissions Control Equipment ID Number: CE-T03
Emissions Control Equipment Description: Internal Floating Roof
Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EUT03
Emission Unit Description: Denaturant Storage Tank
Raw Material/Fuel: Denaturant
Rated Capacity: 200,000 gallon capacity

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Emission limits are not required at this time.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. This tank shall be used to store only denaturant.
- B. The owner or operator shall follow the applicable standards of Subpart Kb, 40 CFR §60.112b(a)(1) and inspect as required in 40 CFR §60.113b(a).
- C. The owner or operator shall follow the applicable standards of Subpart VVa, 40 CFR §60.480a through 40 CFR §60.489a.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep readily accessible records showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel for the lifetime of the source.
- B. The owner or operator shall follow the applicable recordkeeping and reporting standards of Subpart Kb, 40 CFR §60.115b through §60.116b.
- C. The owner or operator shall keep records as required in 40 CFR §60.486a, and reports as required in 40 CFR §60.487a.

Authority for Requirement: Iowa DNR Construction Permit 07-A-084-S1

NSPS and NESHAP Applicability

This emission point is subject to the following NSPS Subparts:

NSPS Subpart A – General Provisions

NSPS Subpart VVa – Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry for which Construction, Reconstruction, or Modification Commenced after November 7, 2006

NSPS Subpart Kb – Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for which Construction, Reconstruction, or Modification Commenced after July 23, 1984

Authority for Requirement: Iowa DNR Construction Permit 07-A-084-S1

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 33.25

Stack Opening, (inches, dia.): 10

Exhaust Flow Rate (scfm): Working & Breathing Loss

Exhaust Temperature (°F): Ambient

Discharge Style: Downward

Authority for Requirement: Iowa DNR Construction Permit 07-A-084-S1

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-T04

Associated Equipment

Associated Emission Unit ID Numbers: EUT04
Emissions Control Equipment ID Number: CE-T04
Emissions Control Equipment Description: Internal Floating Roof
Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EUT04
Emission Unit Description: Denatured Ethanol Storage Tank #1
Raw Material/Fuel: Denatured Ethanol
Rated Capacity: 1.5 MM gallon capacity

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Emission limits are not required at this time.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. This tank shall be used to store only denatured ethanol.
- B. The owner or operator shall follow the applicable standards of Subpart Kb, 40 CFR §60.112b(a)(1) and inspect as required in 40 CFR 60.113b(a).
- C. The owner or operator shall follow the applicable standards of Subpart VVa, 40 CFR §60.480a through 40 CFR §60.489a.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep readily accessible records showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel for the lifetime of the source.
- B. The owner or operator shall follow the applicable recordkeeping and reporting standards of Subpart Kb, 40 CFR §60.115b through §60.116b.
- C. The owner or operator shall keep records as required in 40 CFR §60.486a, and reports as required in 40 CFR §60.487a.

Authority for Requirement: Iowa DNR Construction Permit 07-A-082-S1

NSPS and NESHAP Applicability

This emission point is subject to the following NSPS Subparts:

NSPS Subpart A – General Provisions

NSPS Subpart VVa – Standards of Performance for Equipment Leaks of VOV in the Synthetic Organic Chemicals Manufacturing Industry for which Construction, Reconstruction, or Modification Commenced after November 7, 2006

NSPS Subpart Kb – Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for which Construction, Reconstruction, or Modification Commenced after July 23, 1984

Authority for Requirement: Iowa DNR Construction Permit 07-A-082-S1

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 40.33

Stack Opening, (inches, dia.): 10

Exhaust Flow Rate (scfm): Working & Breathing Loss

Exhaust Temperature (°F): Ambient

Discharge Style: Downward

Authority for Requirement: Iowa DNR Construction Permit 07-A-082-S1

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-T05

Associated Equipment

Associated Emission Unit ID Numbers: EUT05
Emissions Control Equipment ID Number: CE-T05
Emissions Control Equipment Description: Internal Floating Roof
Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EUT05
Emission Unit Description: Denatured Ethanol Storage Tank #2
Raw Material/Fuel: Denatured Ethanol
Rated Capacity: 1.5 MM gallon capacity

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Emission limits are not required at this time.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. This tank shall be used to store only denatured ethanol.
- B. The owner or operator shall follow the applicable standards of Subpart Kb, 40 CFR §60.112b(a)(1) and inspect as required in 40 CFR §60.113b(a).
- C. The owner or operator shall follow the applicable standards of Subpart VVa, 40 CFR §60.480a through 40 CFR §60.489a.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep readily accessible records showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel for the lifetime of the source.
- B. The owner or operator shall follow the applicable recordkeeping and reporting standards of Subpart Kb, 40 CFR §60.115b through §60.116b.
- C. The owner or operator shall keep records as required in 40 CFR §60.486a, and reports as required in 40 CFR §60.487a.

Authority for Requirement: Iowa DNR Construction Permit 07-A-083-S1

NSPS and NESHAP Applicability

This emission point is subject to the following NSPS Subparts:

NSPS Subpart A – General Provisions

NSPS Subpart VVa – Standards of Performance for Equipment Leaks of VOV in the Synthetic Organic Chemicals Manufacturing Industry for which Construction, Reconstruction, or Modification Commenced after November 7, 2006

NSPS Subpart Kb – Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for which Construction, Reconstruction, or Modification Commenced after July 23, 1984

Authority for Requirement: Iowa DNR Construction Permit 07-A-083-S1

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 40.33

Stack Opening, (inches, dia.): 10

Exhaust Flow Rate (scfm): Working & Breathing Loss

Exhaust Temperature (°F): Ambient

Discharge Style: Downward

Authority for Requirement: Iowa DNR Construction Permit 07-A-083-S1

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-T06

Associated Equipment

Associated Emission Unit ID Numbers: EUT06
Emissions Control Equipment ID Number: None
Emissions Control Equipment Description: None
Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EUT06
Emission Unit Description: Corrosion Inhibitor Storage Tank
Raw Material/Fuel: Corrosion Inhibitor
Rated Capacity: 2,300 gallon capacity

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Emission limits are not required at this time.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operational limits are not required at this time.

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): NA
Stack Opening, (inches, dia.): NA
Exhaust Flow Rate (scfm): Working & Breathing Loss
Exhaust Temperature (°F): Ambient
Discharge Style: NA
Authority for Requirement: Iowa DNR Construction Permit 08-A-228

The temperature and flow rate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point design characteristics are different than the values stated above, the owner/operator must notify the Department and obtain a permit amendment, if required.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-FUG5

Associated Equipment

Associated Emission Unit ID Numbers: EUFUG5
Emissions Control Equipment ID Number: None
Emissions Control Equipment Description: None
Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EUFUG05
Emission Unit Description: VOC Emissions from Equipment Leaks
Raw Material/Fuel: VOC
Rated Capacity: NA

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Volatile Organic Compounds (VOC)
Emission Limit(s): 8.85 ton/yr
Authority for Requirement: Iowa DNR Construction Permit 07-A-078-S1

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. The Component Count shall be documented as to the number and types of components used. Components include, but are not limited to, valves, pumps, compressor seals, flanges, etc.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. Calculate and record the VOC emissions based on the documented component count. Update the VOC emission calculations as the component count varies. Emission factors shall be based on EPA document 453/R-95-017 titled Protocol for Equipment Leak Emission Estimates.

Authority for Requirement: Iowa DNR Construction Permit 07-A-078-S1

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

Emission Point ID Number: EP-FUG6

Associated Equipment

Associated Emission Unit ID Numbers: EU-FUG6
Emissions Control Equipment ID Number: None
Emissions Control Equipment Description: None
Continuous Emissions Monitors ID Numbers: None

Emission Unit vented through this Emission Point: EU-FUG06
Emission Unit Description: Dust Emissions from Internal Plant Roads (paved)
Raw Material/Fuel: Fugitive Dust
Rated Capacity: 10 mile/hr

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Emission limits are not required at this time.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limits

- A. Truck traffic on the haul road shall not exceed 10 mph. The speed limit shall be posted on the haul road.
- B. Any spills on the road shall be cleaned up immediately.
- C. Truck traffic emissions on the paved road shall be controlled by water flushing (except as noted in Item D and Item C in "Reporting and Recordkeeping" Section once per day. The water spray rate shall be a minimum of 0.23 gallons per square yard.
 - C 1. If water flushing followed by sweeping cannot be accomplished because the ambient air temperature (as measured at the facility during daylight operating hours) will be less than 35°F (1.7°C) only sweeping is required. Water flushing and/or sweeping is not required for days of inclement weather.
 - C 2. Water flushing and sweeping need not occur when a rain gauge located at the site indicates that at least 0.2 inches of precipitation (water equivalent) has occurred within the preceding 24-hr time period or the paved road(s) will not be used on a given day.
 - C 3. Water flushing and sweeping need not occur if the plant does not receive any truck traffic that day (i.e. on a weekend).
 - C 4. Daily water flushing need not occur provided that the haul road emissions do not exceed 14.7 tons PM for the last twelve months. This shall be calculated using the formula in Item D in "Reporting and Recordkeeping" of this permit. Provided emissions as calculated in Item D in "Reporting and Recordkeeping" remain below 14.7 tons for the last twelve months only daily sweeping is required. In the event that emissions exceed 14.7 tons for the last twelve months the plant shall be required to

commence daily water flushing with daily sweeping until PM emissions fall below 14.7 tons for the last twelve months.

- D. Silt load performance testing shall be completed monthly. Testing shall be completed prior to water flushing and/or sweeping for that day.
- E. The owner/operator shall record the number of trucks that load/unload material on a monthly basis. Based on the number of trucks the total Vehicle Miles Traveled (VMT) shall be calculated for that month.

Reporting and Recordkeeping

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.

- A. Record the frequency of sweeping performed on the haul roads. If the roads are not swept due to weather, a written record must be kept on site outlining the conditions.
- B. Performance testing on the haul road surface silt loading shall be completed on a monthly basis. For each performance test, silt loading samplings shall be done for at least 3 different locations. Performance testing shall be completed prior to water flushing and/or sweeping.
- C. The plant shall maintain a log for the haul roads that show the following:
 - C 1. The silt content of the road for that month based on testing;
 - C 2. The date of performance testing;
 - C 3. The vehicle miles traveled (VMT) for that month;
 - C 4. Each day record whether or not water flushing and sweeping was accomplished. For days w/o water flushing and/or sweeping record the circumstances (i.e. weather condition, equipment malfunction);
 - C 5. The amount of water applied and the areas treated;
 - C 6. The operator's initials.
- D. The owner or operator shall calculate and record the monthly haul road emissions according to the following formulas, which uses the equations from AP-42 Section 13.2.1, the empirical constants, and assumes a mean vehicle weight of 27.5 tons.

$$E_{PM} = \frac{[(2.120 \times (sL/2)^{0.65}) - 0.00044] \times VMT}{2000}$$

Where E = tons PM per month
sL = road surface silt loading (g/m²) for each performance test
VMT = Vehicle miles traveled

$$E_{PM10} = \frac{[(0.4132 \times (sL/2)^{0.65}) - 0.00044] \times VMT}{2000}$$

Where E = tons PM₁₀ per month
sL = road surface silt loading (g/m²) for each performance test
VMT = Vehicle miles traveled

Authority for Requirement: Iowa DNR Construction Permit 07-A-079-S1

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required? Yes No

Facility Maintained Operation & Maintenance Plan Required? Yes No

Compliance Assurance Monitoring (CAM) Plan Required? Yes No

Authority for Requirement: 567 IAC 22.108(3)

IV. General Conditions

This permit is issued under the authority of the Iowa Code subsection 455B.133(8) and in accordance with 567 Iowa Administrative Code chapter 22.

G1. Duty to Comply

1. The permittee must comply with all conditions of the Title V permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action; for a permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. *567 IAC 22.108(9)"a"*
2. Any compliance schedule shall be supplemental to, and shall not sanction noncompliance with, the applicable requirements on which it is based. *567 IAC 22.105 (2)"h"(3)*
3. Where an applicable requirement of the Act is more stringent than an applicable requirement of regulations promulgated under Title IV of the Act, both provisions shall be enforceable by the administrator and are incorporated into this permit. *567 IAC 22.108 (1)"b"*
4. Unless specified as either "state enforceable only" or "local program enforceable only", all terms and conditions in the permit, including provisions to limit a source's potential to emit, are enforceable by the administrator and citizens under the Act. *567 IAC 22.108 (14)*
5. It shall not be a defense for a permittee, in an enforcement action, that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. *567 IAC 22.108 (9)"b"*

G2. Permit Expiration

1. Except as provided in 567 IAC 22.104, the expiration of this permit terminates the permittee's right to operate unless a timely and complete application has been submitted for renewal. Any testing required for renewal shall be completed before the application is submitted. *567 IAC 22.116(2)*
2. To be considered timely, the owner, operator, or designated representative (where applicable) of each source required to obtain a Title V permit shall present or mail the Air Quality Bureau, Iowa Department of Natural Resources, Air Quality Bureau, 7900 Hickman Rd, Suite #1, Urbandale, Iowa 50322, two copies (three if your facility is located in Linn or Polk county) of a complete permit application, at least 6 months but not more than 18 months prior to the date of permit expiration. An additional copy must also be sent to EPA Region VII, Attention: Chief of Air Permits, 901 N. 5th St., Kansas City, KS 66101. The application must include all emission points, emission units, air pollution control equipment, and monitoring devices at the facility. All emissions generating activities, including fugitive emissions, must be included. The definition of a complete application is as indicated in 567 IAC 22.105(2). *567 IAC 22.105*

G3. Certification Requirement for Title V Related Documents

Any application, report, compliance certification or other document submitted pursuant to this permit shall contain certification by a responsible official of truth, accuracy, and completeness. All certifications shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. *567 IAC 22.107 (4)*

G4. Annual Compliance Certification

By March 31 of each year, the permittee shall submit compliance certifications for the previous calendar year. The certifications shall include descriptions of means to monitor the compliance status of all emissions sources including emissions limitations, standards, and work practices in

accordance with applicable requirements. The certification for a source shall include the identification of each term or condition of the permit that is the basis of the certification; the compliance status; whether compliance was continuous or intermittent; the method(s) used for determining the compliance status of the source, currently and over the reporting period consistent with all applicable department rules. For sources determined not to be in compliance at the time of compliance certification, a compliance schedule shall be submitted which provides for periodic progress reports, dates for achieving activities, milestones, and an explanation of why any dates were missed and preventive or corrective measures. The compliance certification shall be submitted to the administrator, director, and the appropriate DNR Field office. *567 IAC 22.108 (15)"e"*

G5. Semi-Annual Monitoring Report

By March 31 and September 30 of each year, the permittee shall submit a report of any monitoring required under this permit for the 6 month periods of July 1 to December 31 and January 1 to June 30, respectively. All instances of deviations from permit requirements must be clearly identified in these reports, and the report must be signed by a responsible official, consistent with *567 IAC 22.107(4)*. The semi-annual monitoring report shall be submitted to the director and the appropriate DNR Field office. *567 IAC 22.108 (5)*

G6. Annual Fee

1. The permittee is required under subrule *567 IAC 22.106* to pay an annual fee based on the total tons of actual emissions of each regulated air pollutant. Beginning July 1, 1996, Title V operating permit fees will be paid on July 1 of each year. The fee shall be based on emissions for the previous calendar year.
2. The fee amount shall be calculated based on the first 4,000 tons of each regulated air pollutant emitted each year. The fee to be charged per ton of pollutant will be available from the department by June 1 of each year. The Responsible Official will be advised of any change in the annual fee per ton of pollutant.
3. The following forms shall be submitted annually by March 31 documenting actual emissions for the previous calendar year.
 - a. Form 1.0 "Facility Identification";
 - b. Form 4.0 "Emissions unit-actual operations and emissions" for each emission unit;
 - c. Form 5.0 "Title V annual emissions summary/fee"; and
 - d. Part 3 "Application certification."
4. The fee shall be submitted annually by July 1. The fee shall be submitted with the following forms:
 - a. Form 1.0 "Facility Identification";
 - b. Form 5.0 "Title V annual emissions summary/fee";
 - c. Part 3 "Application certification."
5. If there are any changes to the emission calculation form, the department shall make revised forms available to the public by January 1. If revised forms are not available by January 1, forms from the previous year may be used and the year of emissions documented changed. The department shall calculate the total statewide Title V emissions for the prior calendar year and make this information available to the public no later than April 30 of each year.
6. Phase I acid rain affected units under section 404 of the Act shall not be required to pay a fee for emissions which occur during the years 1993 through 1999 inclusive.
7. The fee for a portable emissions unit or stationary source which operates both in Iowa and out of state shall be calculated only for emissions from the source while operating in Iowa.

8. Failure to pay the appropriate Title V fee represents cause for reation of the Title V permit as indicated in 567 IAC 22.115(1)"d".

G7. Inspection of Premises, Records, Equipment, Methods and Discharges

Upon presentation of proper credentials and any other documents as may be required by law, the permittee shall allow the director or the director's authorized representative to:

1. Enter upon the permittee's premises where a Title V source is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
3. Inspect, at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
4. Sample or monitor, at reasonable times, substances or parameters for the purpose of ensuring compliance with the permit or other applicable requirements. *567 IAC 22.108 (15)"b"*

G8. Duty to Provide Information

The permittee shall furnish to the director, within a reasonable time, any information that the director may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee also shall furnish to the director copies of records required to be kept by the permit, or for information claimed to be confidential, the permittee shall furnish such records directly to the administrator of EPA along with a claim of confidentiality. *567 IAC 22.108 (9)"e"*

G9. General Maintenance and Repair Duties

The owner or operator of any air emission source or control equipment shall:

1. Maintain and operate the equipment or control equipment at all times in a manner consistent with good practice for minimizing emissions.
2. Remedy any cause of excess emissions in an expeditious manner.
3. Minimize the amount and duration of any excess emission to the maximum extent possible during periods of such emissions. These measures may include but not be limited to the use of clean fuels, production cutbacks, or the use of alternate process units or, in the case of utilities, purchase of electrical power until repairs are completed.
4. Schedule, at a minimum, routine maintenance of equipment or control equipment during periods of process shutdowns to the maximum extent possible. *567 IAC 24.2(1)*

G10. Recordkeeping Requirements for Compliance Monitoring

1. In addition to any source specific recordkeeping requirements contained in this permit, the permittee shall maintain the following compliance monitoring records, where applicable:
 - a. The date, place and time of sampling or measurements
 - b. The date the analyses were performed.
 - c. The company or entity that performed the analyses.
 - d. The analytical techniques or methods used.
 - e. The results of such analyses; and
 - f. The operating conditions as existing at the time of sampling or measurement.
 - g. The records of quality assurance for continuous compliance monitoring systems (including but not limited to quality control activities, audits and calibration drifts.)
2. The permittee shall retain records of all required compliance monitoring data and support information for a period of at least 5 years from the date of compliance monitoring sample, measurement report or application. Support information includes all calibration and maintenance

records and all original strip chart recordings for continuous compliance monitoring, and copies of all reports required by the permit.

3. For any source which in its application identified reasonably anticipated alternative operating scenarios, the permittee shall:

- a. Comply with all terms and conditions of this permit specific to each alternative scenario.
- b. Maintain a log at the permitted facility of the scenario under which it is operating.
- c. Consider the permit shield, if provided in this permit, to extend to all terms and conditions under each operating scenario. *567 IAC 22.108(4), 567 IAC 22.108(12)*

G11. Evidence used in establishing that a violation has or is occurring.

Notwithstanding any other provisions of these rules, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions herein.

1. Information from the use of the following methods is presumptively credible evidence of whether a violation has occurred at a source:

- a. A monitoring method approved for the source and incorporated in an operating permit pursuant to *567 Chapter 22*;
- b. Compliance test methods specified in *567 Chapter 25*; or
- c. Testing or monitoring methods approved for the source in a construction permit issued pursuant to *567 Chapter 22*.

2. The following testing, monitoring or information gathering methods are presumptively credible testing, monitoring, or information gathering methods:

- a. Any monitoring or testing methods provided in these rules; or
- b. Other testing, monitoring, or information gathering methods that produce information comparable to that produced by any method in subrule *21.5(1)* or this subrule. *567 IAC 21.5(1)-567 IAC 21.5(2)*

G12. Prevention of Accidental Release: Risk Management Plan Notification and Compliance Certification

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Act, the permittee shall notify the department of this requirement. The plan shall be filed with all appropriate authorities by the deadline specified by EPA. A certification that this risk management plan is being properly implemented shall be included in the annual compliance certification of this permit. *567 IAC 22.108(6)*

G13. Hazardous Release

The permittee must report any situation involving the actual, imminent, or probable release of a hazardous substance into the atmosphere which, because of the quantity, strength and toxicity of the substance, creates an immediate or potential danger to the public health, safety or to the environment. A verbal report shall be made to the department at (515) 281-8694 and to the local police department or the office of the sheriff of the affected county as soon as possible but not later than six hours after the discovery or onset of the condition. This verbal report must be followed up with a written report as indicated in *567 IAC 131.2(2)*. *567 IAC Chapter 131-State Only*

G14. Excess Emissions and Excess Emissions Reporting Requirements

1. Excess Emissions. Excess emission during a period of startup, shutdown, or cleaning of control equipment is not a violation of the emission standard if the startup, shutdown or cleaning is accomplished expeditiously and in a manner consistent with good practice for minimizing

emissions. Cleaning of control equipment which does not require the shutdown of the process equipment shall be limited to one six-minute period per one-hour period. An incident of excess emission (other than an incident during startup, shutdown or cleaning of control equipment) is a violation. If the owner or operator of a source maintains that the incident of excess emission was due to a malfunction, the owner or operator must show that the conditions which caused the incident of excess emission were not preventable by reasonable maintenance and control measures. Determination of any subsequent enforcement action will be made following review of this report. If excess emissions are occurring, either the control equipment causing the excess emission shall be repaired in an expeditious manner or the process generating the emissions shall be shutdown within a reasonable period of time. An expeditious manner is the time necessary to determine the cause of the excess emissions and to correct it within a reasonable period of time. A reasonable period of time is eight hours plus the period of time required to shut down the process without damaging the process equipment or control equipment. In the case of an electric utility, a reasonable period of time is eight hours plus the period of time until comparable generating capacity is available to meet consumer demand with the affected unit out of service, unless, the director shall, upon investigation, reasonably determine that continued operation constitutes an unjustifiable environmental hazard and issue an order that such operation is not in the public interest and require a process shutdown to commence immediately.

2. Excess Emissions Reporting

a. Oral Reporting of Excess Emissions. An incident of excess emission (other than an incident of excess emission during a period of startup, shutdown, or cleaning) shall be reported to the appropriate field office of the department within eight hours of, or at the start of the first working day following the onset of the incident. The reporting exemption for an incident of excess emission during startup, shutdown or cleaning does not relieve the owner or operator of a source with continuous monitoring equipment of the obligation of submitting reports required in 567-subrule 25.1(6). An oral report of excess emission is not required for a source with operational continuous monitoring equipment (as specified in 567-subrule 25.1(1)) if the incident of excess emission continues for less than 30 minutes and does not exceed the applicable emission standard by more than 10 percent or the applicable visible emission standard by more than 10 percent opacity. The oral report may be made in person or by telephone and shall include as a minimum the following:

- i. The identity of the equipment or source operation from which the excess emission originated and the associated stack or emission point.
- ii. The estimated quantity of the excess emission.
- iii. The time and expected duration of the excess emission.
- iv. The cause of the excess emission.
- v. The steps being taken to remedy the excess emission.
- vi. The steps being taken to limit the excess emission in the interim period.

b. Written Reporting of Excess Emissions. A written report of an incident of excess emission shall be submitted as a follow-up to all required oral reports to the department within seven days of the onset of the upset condition, and shall include as a minimum the following:

- i. The identity of the equipment or source operation point from which the excess emission originated and the associated stack or emission point.
- ii. The estimated quantity of the excess emission.

- iii. The time and duration of the excess emission.
- iv. The cause of the excess emission.
- v. The steps that were taken to remedy and to prevent the recurrence of the incident of excess emission.
- vi. The steps that were taken to limit the excess emission.
- vii. If the owner claims that the excess emission was due to malfunction, documentation to support this claim. *567 IAC 24.1(1)-567 IAC 24.1(4)*

3. Emergency Defense for Excess Emissions. For the purposes of this permit, an “emergency” means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission limitation under the permit due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include non-compliance, to the extent caused by improperly designed equipment, lack of preventive maintenance, careless or improper operation or operator error. An emergency constitutes an affirmative defense to an action brought for non-compliance with technology based limitations if it can be demonstrated through properly signed contemporaneous operating logs or other relevant evidence that:

- a. An emergency occurred and that the permittee can identify the cause(s) of the emergency;
- b. The facility at the time was being properly operated;
- c. During the period of the emergency, the permittee took all reasonable steps to minimize levels of emissions that exceeded the emissions standards or other requirements of the permit; and
- d. The permittee submitted notice of the emergency to the director by certified mail within two working days of the time when the emissions limitations were exceeded due to the emergency. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken. *567 IAC 22.108(16)*

G15. Permit Deviation Reporting Requirements

A deviation is any failure to meet a term, condition or applicable requirement in the permit. Reporting requirements for deviations that result in a hazardous release or excess emissions have been indicated above (see G13 and G14). Unless more frequent deviation reporting is specified in the permit, any other deviation shall be documented in the semi-annual monitoring report and the annual compliance certification (see G4 and G5). *567 IAC 22.108(5)"b"*

G16. Notification Requirements for Sources That Become Subject to NSPS and NESHAP Regulations

During the term of this permit, the permittee must notify the department of any source that becomes subject to a standard or other requirement under 567-subrule 23.1(2) (standards of performance of new stationary sources) or section 111 of the Act; or 567-subrule 23.1(3) (emissions standards for hazardous air pollutants), 567-subrule 23.1(4) (emission standards for hazardous air pollutants for source categories) or section 112 of the Act. This notification shall be submitted in writing to the department pursuant to the notification requirements in 40 CFR Section 60.7, 40 CFR Section 61.07, and/or 40 CFR Section 63.9. *567 IAC 23.1(2), 567 IAC 23.1(3), 567 IAC 23.1(4)*

G17. Requirements for Making Changes to Emission Sources That Do Not Require Title V Permit Modification

1. Off Permit Changes to a Source. Pursuant to section 502(b)(10) of the CAAA, the permittee may make changes to this installation/facility without revising this permit if:
 - a. The changes are not major modifications under any provision of any program required by section 110 of the Act, modifications under section 111 of the act, modifications under section 112 of the act, or major modifications as defined in 567 IAC Chapter 22.
 - b. The changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions);
 - c. The changes are not modifications under any provisions of Title I of the Act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or as total emissions);
 - d. The changes are not subject to any requirement under Title IV of the Act.
 - e. The changes comply with all applicable requirements.
 - f. For such a change, the permitted source provides to the department and the administrator by certified mail, at least 30 days in advance of the proposed change, a written notification, including the following, which must be attached to the permit by the source, the department and the administrator:
 - i. A brief description of the change within the permitted facility,
 - ii. The date on which the change will occur,
 - iii. Any change in emission as a result of that change,
 - iv. The pollutants emitted subject to the emissions trade
 - v. If the emissions trading provisions of the state implementation plan are invoked, then Title V permit requirements with which the source shall comply; a description of how the emissions increases and decreases will comply with the terms and conditions of the Title V permit.
 - vi. A description of the trading of emissions increases and decreases for the purpose of complying with a federally enforceable emissions cap as specified in and in compliance with the Title V permit; and
 - vii. Any permit term or condition no longer applicable as a result of the change.
2. Such changes do not include changes that would violate applicable requirements or contravene federally enforceable permit terms and conditions that are monitoring (including test methods), record keeping, reporting, or compliance certification requirements. *567 IAC 22.110(2)*
3. Notwithstanding any other part of this rule, the director may, upon review of a notice, require a stationary source to apply for a Title V permit if the change does not meet the requirements of subrule 22.110(1). *567 IAC 22.110(3)*
4. The permit shield provided in subrule 22.108(18) shall not apply to any change made pursuant to this rule. Compliance with the permit requirements that the source will meet using the emissions trade shall be determined according to requirements of the state implementation plan authorizing the emissions trade. *567 IAC 22.110(4)*
5. No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes, for changes that are provided for in this permit. *567 IAC 22.108(11)*

G18. Duty to Modify a Title V Permit

1. Administrative Amendment.

- a. An administrative permit amendment is a permit revision that is required to do any of the following:
 - i. Correct typographical errors;
 - ii. Identify a change in the name, address, or telephone number of any person identified in the permit, or provides a similar minor administrative change at the source;
 - iii. Require more frequent monitoring or reporting by the permittee; or
 - iv. Allow for a change in ownership or operational control of a source where the director determines that no other change in the permit is necessary, provided that a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new permittee has been submitted to the director.
- b. The permittee may implement the changes addressed in the request for an administrative amendment immediately upon submittal of the request. The request shall be submitted to the director.
- c. Administrative amendments to portions of permits containing provisions pursuant to Title IV of the Act shall be governed by regulations promulgated by the administrator under Title IV of the Act.

2. Minor Permit Modification.

- a. Minor permit modification procedures may be used only for those permit modifications that do any of the following:
 - i. Do not violate any applicable requirements
 - ii. Do not involve significant changes to existing monitoring, reporting or recordkeeping requirements in the Title V permit.
 - iii. Do not require or change a case by case determination of an emission limitation or other standard, or increment analysis.
 - iv. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed in order to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include any federally enforceable emissions caps which the source would assume to avoid classification as a modification under any provision under Title I of the Act; and an alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Act.;
 - v. Are not modifications under any provision of Title I of the Act; and
 - vi. Are not required to be processed as significant modification.
- b. An application for minor permit revision shall be on the minor Title V modification application form and shall include at least the following:
 - i. A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs.
 - ii. The permittee's suggested draft permit
 - iii. Certification by a responsible official, pursuant to 567 IAC 22.107(4), that the proposed modification meets the criteria for use of a minor permit modification procedures and a request that such procedures be used; and

iv. Completed forms to enable the department to notify the administrator and the affected states as required by 567 IAC 22.107(7).

c. The permittee may make the change proposed in its minor permit modification application immediately after it files the application. After the permittee makes this change and until the director takes any of the actions specified in 567 IAC 22.112(4) "a" to "c", the permittee must comply with both the applicable requirements governing the change and the proposed permit terms and conditions. During this time, the permittee need not comply with the existing permit terms and conditions it seeks to modify. However, if the permittee fails to comply with its proposed permit terms and conditions during this time period, existing permit term terms and conditions it seeks to modify may subject the facility to enforcement action.

3. Significant Permit Modification. Significant Title V modification procedures shall be used for applications requesting Title V permit modifications that do not qualify as minor Title V modifications or as administrative amendments. These include but are not limited to all significant changes in monitoring permit terms, every relaxation of reporting or recordkeeping permit terms, and any change in the method of measuring compliance with existing requirements. Significant Title V modifications shall meet all requirements of 567 IAC Chapter 22, including those for applications, public participation, review by affected states, and review by the administrator, and those requirements that apply to Title V issuance and renewal. *567 IAC 22.111-567 IAC 22.113* The permittee shall submit an application for a significant permit modification not later than three months after commencing operation of the changed source unless the existing Title V permit would prohibit such construction or change in operation, in which event the operation of the changed source may not commence until the department revises the permit. *567 IAC 22.105(1)"a"(4)*

G19. Duty to Obtain Construction Permits

Unless exempted under 567 IAC 22.1(2), the permittee must not construct, install, reconstruct, or alter any equipment, control equipment or anaerobic lagoon without first obtaining a construction permit, conditional permit, or permit pursuant to 567 IAC 22.8, or permits required pursuant to 567 IAC 22.4 and 567 IAC 22.5. Such permits shall be obtained prior to the initiation of construction, installation or alteration of any portion of the stationary source. *567 IAC 22.1(1)*

G20. Asbestos

The permittee shall comply with 567 IAC 23.1(3)"a", and 567 IAC 23.2(3)"g" when activities involve asbestos mills, surfacing of roadways, manufacturing operations, fabricating, insulating, waste disposal, spraying applications, demolition and renovation operations, training fires and controlled burning of a demolished building. *567 IAC 23.1(3)"a", and 567 IAC 23.2*

G21. Open Burning

The permittee is prohibited from conducting open burning, except as may be allowed by 567 IAC 23.2. *567 IAC 23.2 except 23.2(3)"h"; 567 IAC 23.2(3)"h" - State Only*

G22. Acid Rain (Title IV) Emissions Allowances

The permittee shall not exceed any allowances that it holds under Title IV of the Act or the regulations promulgated there under. Annual emissions of sulfur dioxide in excess of the number of allowances to emit sulfur dioxide held by the owners and operators of the unit or the designated representative of the owners and operators is prohibited. Exceedances of applicable emission rates are prohibited. "Held" in this context refers to both those allowances assigned to the owners and operators by USEPA, and those allowances supplementally acquired by the

owners and operators. The use of any allowance prior to the year for which it was allocated is prohibited. Contravention of any other provision of the permit is prohibited. *567 IAC 22.108(7)*

G23. Stratospheric Ozone and Climate Protection (Title VI) Requirements

1. The permittee shall comply with the standards for labeling of products using ozone-depleting substances pursuant to 40 CFR Part 82, Subpart E:
 - a. All containers in which a class I or class II substance is stored or transported, all products containing a class I substance, and all products directly manufactured with a class I substance must bear the required warning statement if it is being introduced into interstate commerce pursuant to § 82.106.
 - b. The placement of the required warning statement must comply with the requirements pursuant to § 82.108.
 - c. The form of the label bearing the required warning statement must comply with the requirements pursuant to § 82.110.
 - d. No person may modify, remove, or interfere with the required warning statement except as described in § 82.112.
2. The permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 CFR Part 82, Subpart F, except as provided for MVACs in Subpart B:
 - a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to § 82.156.
 - b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to § 82.158.
 - c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to § 82.161.
 - d. Persons disposing of small appliances, MVACs, and MVAC-like appliances must comply with reporting and recordkeeping requirements pursuant to § 82.166. ("MVAC-like appliance" as defined at § 82.152)
 - e. Persons owning commercial or industrial process refrigeration equipment must comply with the leak repair requirements pursuant to § 82.156.
 - f. Owners/operators of appliances normally containing 50 or more pounds of refrigerant must keep records of refrigerant purchased and added to such appliances pursuant to § 82.166.
3. If the permittee manufactures, transforms, imports, or exports a class I or class II substance, the permittee is subject to all the requirements as specified in 40 CFR part 82, Subpart A, Production and Consumption Controls.
4. If the permittee performs a service on motor (fleet) vehicles when this service involves ozone-depleting substance refrigerant (or regulated substitute substance) in the motor vehicle air conditioner (MVAC), the permittee is subject to all the applicable requirements as specified in 40 CFR part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners. The term "motor vehicle" as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed. The term "MVAC" as used in Subpart B does not include the air-tight sealed refrigeration system used as refrigerated cargo, or system used on passenger buses using HCFC-22 refrigerant,
5. The permittee shall be allowed to switch from any ozone-depleting substance to any alternative that is listed in the Significant New Alternatives Program (SNAP) promulgated pursuant to 40 CFR part 82, Subpart G, Significant New Alternatives Policy Program. *40 CFR part 82*

G24. Permit Reopenings

1. This permit may be modified, revoked, reopened, and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition. *567 IAC 22.108(9)"c"*
2. Additional applicable requirements under the Act become applicable to a major part 70 source with a remaining permit term of 3 or more years. Revisions shall be made as expeditiously as practicable, but not later than 18 months after the promulgation of such standards and regulations.
 - a. Reopening and revision on this ground is not required if the permit has a remaining term of less than three years;
 - b. Reopening and revision on this ground is not required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions have been extended pursuant to 40 CFR 70.4(b)(10)(i) or (ii) as amended to May 15, 2001.
 - c. Reopening and revision on this ground is not required if the additional applicable requirements are implemented in a general permit that is applicable to the source and the source receives approval for coverage under that general permit. *567 IAC 22.108(17)"a"*, *567 IAC 22.108(17)"b"*
3. A permit shall be reopened and revised under any of the following circumstances:
 - a. The department receives notice that the administrator has granted a petition for disapproval of a permit pursuant to 40 CFR 70.8(d) as amended to July 21, 1992, provided that the reopening may be stayed pending judicial review of that determination;
 - b. The department or the administrator determines that the Title V permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the Title V permit;
 - c. Additional applicable requirements under the Act become applicable to a Title V source, provided that the reopening on this ground is not required if the permit has a remaining term of less than three years, the effective date of the requirement is later than the date on which the permit is due to expire, or the additional applicable requirements are implemented in a general permit that is applicable to the source and the source receives approval for coverage under that general permit. Such a reopening shall be complete not later than 18 months after promulgation of the applicable requirement.
 - d. Additional requirements, including excess emissions requirements, become applicable to a Title IV affected source under the acid rain program. Upon approval by the administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.
 - e. The department or the administrator determines that the permit must be revised or revoked to ensure compliance by the source with the applicable requirements. *567 IAC 22.114(1)*
4. Proceedings to reopen and reissue a Title V permit shall follow the procedures applicable to initial permit issuance and shall effect only those parts of the permit for which cause to reopen exists. *567 IAC 22.114(2)*

G25. Permit Shield

1. The director may expressly include in a Title V permit a provision stating that compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that:
 - a. Such applicable requirements are included and are specifically identified in the permit; or
 - b. The director, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the source, and the permit includes the determination or a concise summary thereof.
2. A Title V permit that does not expressly state that a permit shield exists shall be presumed not to provide such a shield.
3. A permit shield shall not alter or affect the following:
 - a. The provisions of Section 303 of the Act (emergency orders), including the authority of the administrator under that section;
 - b. The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance;
 - c. The applicable requirements of the acid rain program, consistent with Section 408(a) of the Act;
 - d. The ability of the department or the administrator to obtain information from the facility pursuant to Section 114 of the Act. *567 IAC 22.108 (18)*

G26. Severability

The provisions of this permit are severable and if any provision or application of any provision is found to be invalid by this department or a court of law, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected by such finding. *567 IAC 22.108 (8)*

G27. Property Rights

The permit does not convey any property rights of any sort, or any exclusive privilege. *567 IAC 22.108 (9)"d"*

G28. Transferability

This permit is not transferable from one source to another. If title to the facility or any part of it is transferred, an administrative amendment to the permit must be sought to determine transferability of the permit. *567 IAC 22.111 (1)"d"*

G29. Disclaimer

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions. *567 IAC 22.3(3)"c"*

G30. Notification and Reporting Requirements for Stack Tests or Monitor Certification

The permittee shall notify the department's stack test contact in writing not less than 30 days before a required test or performance evaluation of a continuous emission monitor is performed to determine compliance with applicable requirements of 567 – Chapter 23 or a permit condition. For the department to consider test results a valid demonstration of compliance with applicable rules or a permit condition, such notice shall be given. Such notice shall include the time, the place, the name of the person who will conduct the test and other information as required by the department. Unless specifically waived by the department's stack test contact, a pretest meeting shall be held not later than 15 days prior to conducting the compliance demonstration. The

department may accept a testing protocol in lieu of a pretest meeting. A representative of the department shall be permitted to witness the tests. Results of the tests shall be submitted in writing to the department's stack test contact in the form of a comprehensive report within six weeks of the completion of the testing. Compliance tests conducted pursuant to this permit shall be conducted with the source operating in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which the source shall be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the equipment manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the department that the source has been physically altered so that capacity cannot be exceeded, or the department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the department to determine whether such source is in compliance.

Stack test notifications, reports and correspondence shall be sent to:

Stack Test Review Coordinator
Iowa DNR, Air Quality Bureau
7900 Hickman Road, Suite #1
Urbandale, IA 50322
(515) 242-6001

Within Polk and Linn Counties, stack test notifications, reports and correspondence shall also be directed to the supervisor of the respective county air pollution program.

567 IAC 25.1(7)"a", 567 IAC 25.1(9)

G31. Prevention of Air Pollution Emergency Episodes

The permittee shall comply with the provisions of 567 IAC Chapter 26 in the prevention of excessive build-up of air contaminants during air pollution episodes, thereby preventing the occurrence of an emergency due to the effects of these contaminants on the health of persons.

567 IAC 26.1(1)

G32. Contacts List

The current address and phone number for reports and notifications to the EPA administrator is:

Chief of Air Permits
EPA Region 7
Air Permits and Compliance Branch
901 N. 5th Street
Kansas City, KS 66101
(913) 551-7020

The current address and phone number for reports and notifications to the department or the Director is:

Chief, Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite #1
Windsor Heights, IA 50324
(515) 242-5100

Reports or notifications to the DNR Field Offices or local programs shall be directed to the supervisor at the appropriate field office or local program. Current addresses and phone numbers are:

Field Office 1

909 West Main – Suite 4
Manchester, IA 52057
(563) 927-2640

Field Office 3

1900 N. Grand Ave.
Spencer, IA 51301
(712) 262-4177

Field Office 5

401 SW 7th Street, Suite I
Des Moines, IA 50309
(515) 725-0268

Polk County Public Works Dept.

Air Quality Division
5885 NE 14th St.
Des Moines, IA 50313
(515) 286-3351

Field Office 2

2300-15th St., SW
Mason City, IA 50401
(641) 424-4073

Field Office 4

1401 Sunnyside Lane
Atlantic, IA 50022
(712) 243-1934

Field Office 6

1023 West Madison Street
Washington, IA 52353-1623
(319) 653-2135

Linn County Public Health Dept.

Air Pollution Control Division
501 13th St., NW
Cedar Rapids, IA 52405
(319) 892-6000

V. Appendices:

- A. 40 CFR 60 Subpart A – General Provisions
<http://www.tceq.state.tx.us/permitting/air/rules/federal/60/a/ahp.html>
- B. 40 CFR 60 Subpart Db – Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units
<http://www.epa.gov/ttn/atw/combust/boiler/fr13jn07.pdf>
- C. 40 CFR 60 Subpart Kb – Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction or Modification Commenced After July 23, 1984
<http://www.tceq.state.tx.us/permitting/air/rules/federal/60/kb/kbhp.html>
- D. 40 CFR 60 Subpart VVa – Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry for Which Construction, Reconstruction, or Modification Commenced After November 7, 2006
<http://ecfr.gpoaccess.gov/cgi/t/text/text-idx?c=ecfr;sid=c8befe3824fe313842b2251681aacec3;rgn=div6;view=text;node=40%3A6.0.1.1.1.62;idno=40;cc=ecfr>
- E. 40 CFR 60 Subpart IIII – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
<http://www.epa.gov/ttn/atw/nsps/cinsps/fr11jy06.pdf>
- F. 40 CFR 63 Subpart VVVVVV – National Emission Standards for Hazardous Air Pollutants for Chemical Manufacturing Area Sources
<http://ecfr.gpoaccess.gov/cgi/t/text/text-idx?c=ecfr;rgn=div6;view=text;node=40%3A14.0.1.1.1.32;idno=40;sid=ce9a35561527d91c91cbd8738090c8ab;cc=ecfr>