

Iowa Department of Natural Resources

2021 Summary Information Underground Storage Tanks (USTs)

General Information

Public Record Posted Date: 10/1/2021

Total Number Of Active UST Facilities: 2482

Total Number Of Active UST

Compartments: 7862

Summary Information For On-Site Inspections

Number Of UST Facilities Inspected: 1269

Inspection Period Dates: 10/1/2020 To: 9/30/2021

Percent Significant Operational Compliance: 66%

Note: Tank, facility, and on-site inspection information is based on underground storage tanks in operation and inspected during federal fiscal year 2021. On-site inspections measure compliance with federal and state regulations for operating underground storage tanks.

Summary Information For Releases

Number Of Confirmed UST Releases: 30

Release Reporting Period Dates: 10/1/2020 To: 9/30/2021

Source			Cause													
			Spill		Overfill		Phys/Mech		Corrosion		Install		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	2	7%							2	7%						
Piping																
Dispenser	6	20%					6	20%								
STP																
Delivery																
Other	22	73%					2	7%					1	3%	19	63%
Totals	30	100%					8	27%	2	7%			1	3%	19	63%

= number, % = percent of total number of releases

Note: Release, source, and cause information is based on releases from underground storage tanks regulated by the Iowa Department of Natural Resources.

Questions about the general information, on-site inspections, and confirmed releases may be addressed to the Iowa DNR UST Section at 515.725.8450. Site specific information also can be reviewed on the Storage Tanks Database Web Application at <https://programs.iowadnr.gov/tanks/pages/advanced.aspx>.

