

Iowa Department of Natural Resources

2022 Summary Information Underground Storage Tanks (USTs)

General Information

Public Record Posted Date: 10/11/2022

Total Number Of Active UST Facilities: 2472

Total Number Of Active USTs: 6543

Total Number Of Active UST Compartments: 7884

Summary Information For On-Site Inspections

Number Of UST Facilities Inspected: 1275

Inspection Period Dates: 10/1/2021 To: 9/30/2022

Percent Compliance (Technical Compliance Rate Measure): 18%

Note: Tank, facility, and on-site inspection information is based on underground storage tanks in operation and inspected during federal fiscal year 2022. On-site inspections measure compliance with federal and state regulations for operating underground storage tanks.

Summary Information For Releases

Number Of Confirmed UST Releases: 25

Release Reporting Period Dates: 10/1/2021 To: 9/30/2022

Source			Cause													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank																
Piping	2	8%							1	4%	1	4%				
Dispenser	7	28%					7	28%								
STP	1	4%					1	4%								
Delivery Problem																
Other	15	60%													15	60%
Totals	25	100%					8	32%	1	4%	1	4%			15	60%

= number, % = percent of total number of releases

Note: Release, source, and cause information is based on releases from underground storage tanks regulated by the Iowa Department of Natural Resources.

Questions about the general information, on-site inspections, and confirmed releases may be addressed to the Iowa DNR UST Section at 515.725.8450. Site specific information also can be reviewed on the Storage Tanks Database Web Application at <https://programs.iowadnr.gov/tanks/pages/advanced.aspx>.