

WASTEWATER FACILITIES DESIGN STANDARDS

CHAPTER 14

Wastewater Treatment Works

14.1 GENERAL

- 14.1.1 Applicability
- 14.1.2 Waivers
- 14.1.3 Explanation of Terms
 - 14.1.3.1 Standard Required
 - 14.1.3.2 Definitions

14.2 TREATMENT WORKS SITING

- 14.2.1 General
- 14.2.2 Site Survey
- 14.2.3 Separation Requirements
- 14.2.4 Anaerobic Lagoons
- 14.2.5 Separation Distance Exceptions
- 14.2.6 Flood Protection

14.3 QUALITY OF EFFLUENT

14.4 DESIGN

- 14.4.1 General
 - 14.4.1.1 Type of Treatment
 - 14.4.1.2 Industrial Wastes
 - 14.4.1.3 Prohibited Wastes
- 14.4.2 Pre-Design Meeting
- 14.4.3 New Process, Equipment and Application Evaluation, Project Coordination Meetings and Project Performance Standards
- 14.4.4 Design Period
 - 14.4.4.1 General
- 14.4.5 Hydraulic Design
 - 14.4.5.1 General
 - 14.4.5.2 Critical Flow Conditions, Municipal
 - 14.4.5.3 Existing System, Municipal
 - 14.4.5.4 New Systems, Municipal
 - 14.4.5.5 Critical Flow Conditions, Industrial
 - 14.4.5.6 Flow and Load Equalization
- 14.4.6 Organic Design
 - 14.4.6.1 Domestic Loadings
 - 14.4.6.2 Industrial Loadings

- 14.4.6.3 Septage Loadings
- 14.4.7 Conduits
- 14.4.8 Design Details
 - 14.4.8.1 Unit Bypass During Construction
 - 14.4.8.2 Drains
 - 14.4.8.3 Buoyancy
 - 14.4.8.4 Pipe Identification
 - 14.4.8.5 Operating Equipment
 - 14.4.8.6 Erosion Control During Construction
 - 14.4.8.7 Grading and Landscaping
 - 14.4.8.8 Sludge Disposal During Construction
- 14.4.9 Plant Operability
 - 14.4.9.1 Unit Operation Bypassing
 - 14.4.9.2 Flexibility
 - 14.4.9.3 Flow Division Control

- 14.5 TREATMENT FACILITY RELIABILITY CLASSES
 - 14.5.1 Facility Reliability Classes
 - 14.5.2 Unit Process Reliability Criteria
 - 14.5.2.1 Unit Process Reliability Criteria A
 - 14.5.2.2 Unit Process Reliability Criteria B
 - 14.5.2.3 Unit Process Reliability Criteria C
 - 14.5.2.4 Unit Process Reliability Exceptions
 - 14.5.3 Power Source Reliability

- 14.6 PLANT OUTFALL
 - 14.6.1 General
 - 14.6.2 Protection And Maintenance
 - 14.6.3 Sampling Provisions
 - 14.6.4 Effluent Diffuser System

- 14.7 ESSENTIAL FACILITIES
 - 14.7.1 Water Supply
 - 14.7.1.1 General
 - 14.7.1.2 Direct Connections
 - 14.7.1.3 Indirect Connections
 - 14.7.1.4 Separate Potable Water Supply
 - 14.7.1.5 Separate Non-Potable Water Supply
 - 14.7.2 Flow Measurement
 - 14.7.2.1 General
 - 14.7.2.2 Requirements for Specific Systems
 - 14.7.2.3 Magnetic Flow Meters
 - 14.7.2.4 Volumetric Meters

- 14.7.2.5 Elapsed Time Meters
- 14.7.2.6 Reliability and Accuracy
- 14.7.3 Sampling Equipment

14.8 SAFETY

14.9 LABORATORY

- 14.9.1 Minimum Required Laboratory Analysis Capability
- 14.9.2 Laboratory Capability

APPENDIX 14A RECOMMENDED PROCESS PIPING COLOR CODING

APPENDIX 14B RECOMMENDED LABORATORY GUIDELINES

IOWA WASTEWATER FACILITIES DESIGN STANDARDS

CHAPTER 14

WASTEWATER TREATMENT WORKS

14.1 GENERAL

14.1.1 Applicability

This chapter is applicable to construction, installation or modification of any disposal system required to obtain a construction permit from this Department under Iowa Code section 455B.183 and rule 567 Iowa Administrative Code (IAC) 64.2.

14.1.2 Waivers [subrule 567 IAC 64.2(9)“c”]

When engineering justification satisfactory to the Director is provided substantially demonstrating that a waiver from the design standards or siting criteria will result in either at least equivalent effectiveness or improved effectiveness, a waiver from design standards or siting criteria may be accepted by the Director.

14.1.3 Explanation of Terms

14.1.3.1 Standard Required

The terms “shall” or “must” are used in these standards when it is required that the standard be used. Other terms such as “should” and “recommended” indicate desirable procedures or methods which should be considered but will not be required.

14.1.3.2 Definitions

- a. Anaerobic Lagoon - A treatment process that involves retention in a lagoon under anoxic conditions.
- b. Dry Weather Flow - A measure of total flows in the sanitary collection system when runoff is not occurring. It is the sum of the volume of wastewater discharges and the volume of groundwater infiltrating the collection system.
- c. Final Effluent - The effluent from the final treatment unit of a wastewater treatment plant.

- d. Flood Frequency - The percent frequency with which the maximum flood may be expected to occur at a site in any one year as determined by the Department. Sometimes expressed in terms of years; for example, a 1 percent annual chance would be a 100-year flood; a 4 percent annual chance would be a 25-year flood.
- e. Innovative Technology - A technology that is developed, but it has not been proven effective and reliable in a substantial number of applications in the circumstances of its contemplated use.
- f. Outfall - A sewer that receives wastewater from a treatment plant and carries it to a point of final discharge.
- g. Professional Engineer - A person engaged in the practice of engineering as defined by Iowa Code section 542B.2 who is issued a certificate of licensure as a professional engineer pursuant to Iowa Code section 542B.17.
- h. Public Use Area - Means any of the following:
 - (1) A portion of land owned by the United States, the state, or a political subdivision with facilities which attract the public to congregate and remain in the area for significant periods of time.
 - (2) A cemetery.
- i. Technology Not Fully Developed - Any new process, equipment or application where the supplemental information requirements of Section 14.4.3 of these standards are not satisfied in the circumstances of its contemplated use.
- j. Treatment Works - Any plant, disposal field, lagoon, holding or flow-regulating basin, pumping station, or other works installed for the purpose of treating, stabilizing, or disposing of sewage, industrial waste, or other wastes.

14.2 TREATMENT WORKS SITING

14.2.1 General

The engineering report or facilities plan required by Chapter 11 of these standards shall address site selection. All sites must comply with all applicable siting requirements of this Department and other state and local agencies.

14.2.2 Site Survey [subrule 567 IAC 60.4(1)“c”]

The applicant's engineer must submit the following information for a site survey:

- a. Engineering Report, Facilities Plan or a cover letter which contains a brief description of the proposed treatment process and assurance that the project is in conformance with the long-range planning for the area.
- b. Completed Schedule A - General Information
- c. Completed Schedule F - Treatment Project Site Selection
- d. Completed Schedule G - Treatment Project Design Data

14.2.3 Separation Requirements [subrule 567 IAC 64.2(3)]

The following separation distances from a treatment works shall apply unless a separation distance exception is provided by law or in these standards. The separation distance from lagoons shall be measured from the water surface. To the extent that these separation distances conflict with the separation distances in Section 14.2.4 of these standards, the greater distance shall prevail.

- a. 1,000 feet from the nearest inhabitable residence, commercial building, or other inhabitable structure. If the inhabitable or commercial building is the property of the owner of the proposed treatment facility, or there is written agreement with the owner of the building, the separation criteria shall not apply. Any such agreement shall be filed with the county recorder and recorded for abstract of title purposes, and a copy submitted to the Department.
- b. 1,000 feet from public shallow wells.
- c. 400 feet from public deep wells.
- d. 400 feet from private wells.
- e. 400 feet from lakes and public impoundments.
- f. 25 feet from property lines and right-of-way. In addition, a separation distance of at least 300 feet from property lines and right-of-way are recommended, especially where wastewater treatment facilities may be expanded in the future.

When the above separation distances cannot be maintained for the expansion, upgrading or replacement of existing facilities, the separation distances shall be maintained at no less than 90% of the existing separation distance of the site, providing no data is available indicating that a problem has existed or will be created.

14.2.4 Anaerobic Lagoons

In addition to the distance required in Section 14.2.3.b, c, d, e, and f of these standards, the following separation distances shall apply to all anaerobic lagoons which are used in connection with industrial wastewater treatment. These distances do not apply to controlled discharge facultative pond systems or aerated facultative pond systems.

- a. Where the average rated flow is 100,000 gpd or less, the separation distance from the anaerobic lagoon shall be at least 1,250 feet from the nearest inhabitable residence, commercial building, or other inhabitable structure not owned by the owner of the lagoon or from a public use area other than a public road.
- b. Where the average rated flow is greater than 100,000 gpd, the separation distance from the anaerobic lagoon shall be at least 1,875 feet from the nearest inhabitable residence, commercial building, or other inhabitable structure not owned by the owner of the lagoon or from a public use area other than a public road.
- c. A person may build or expand an anaerobic lagoon closer to an inhabitable residence, commercial building, or other inhabitable structure not owned by the owner of the anaerobic lagoon or to a public use area, if the affected landowners enter into a written agreement with the anaerobic lagoon owner to waive the separation distances under such terms the parties negotiate. Any such agreement shall be filed with the county recorder and recorded for abstract of title purposes, and a copy submitted to the Department.
- d. When the above separation distances cannot be maintained for the expansion, upgrading or replacement of existing anaerobic lagoon facilities, these separation distances may be reduced to 1,000 feet provided all of the following criteria are met:
 - i. The anaerobic lagoon will be completely covered and provided with an approved off gas treatment throughout the entire life of operation.
 - ii. An operation and maintenance manual shall be prepared and submitted to the Department in accordance with Section 11.6 of these standards.
 - iii. No data is available indicating that a problem has existed or will be created.

14.2.5 Separation Distance Exceptions

The explanation of terms in Subsection 14.1.3.1 of these standards shall apply.

- a. Pumping Stations - For a pumping station at a site that is remote from new or expanded wastewater treatment facilities, the distances in Section 14.2.3 of

these standards are recommended. All pumping stations shall be off the traffic ways of streets and alleys.

- b. Flow Equalization Basins - If a flow equalization basin is covered and at a site that is remote from new or expanded wastewater treatment facilities, the distance in Section 14.2.3.a may be reduced to 300 feet. If the top of a remote flow equalization basin is underneath the surface of the earth, the distance required in Section 14.2.3.a is recommended.
- c. Control Buildings - The separation distance in Section 14.2.3 of these standards shall not apply to control buildings (such as laboratories, offices, toilet/shower rooms, etc.).
- d. Wetted Disposal Areas - Chapter 21 of these standards shall establish the applicable site separation criteria for land application of wastewater.
- e. Boiler or Cooling Tower Blow Down Facilities - If a wastewater treatment pond will be used solely for the retention or storage of the industrial waste from a boiler or cooling tower blow down facility and its sole use is filed with the county recorder and recorded for abstract of title purposes, the distances in Section 14.2.3 are recommended.

14.2.6 Flood Protection

- a. Protection from physical damage by the five hundred (500) year flood plus one foot shall be considered in the evaluation of alternatives under Subsection 11.2.9.5 of these standards. At a minimum, the treatment works structures, electrical and mechanical equipment shall be protected from physical damage by the one hundred (100) year flood plus one foot.
- b. Treatment works should remain fully operational and accessible during the 100-year flood, if practicable. Lesser flood levels may be used dependent on local situations, but in no case shall less than a twenty-five (25) year flood be used. This applies to new construction and should be considered for existing facilities undergoing major modification.
- c. Wastewater treatment facilities shall not be located to conflict with encroachment limits on the floodway. The establishment of these encroachment limits is described in rule 567 IAC 75.4(455B).
- d. It is recommended that structures be offset one hundred feet or twice the width of the river or stream measured from top of bank to top of bank, whichever distance is less, unless a greater distance is required under rule 567 IAC 72.6 (455B).

14.3 QUALITY OF EFFLUENT

This Department establishes the effluent limitations for each wastewater discharger. Effluent limitations for existing wastewater dischargers are available from the Department. The effluent limitations for new dischargers or significantly modified dischargers are established by the Department upon request. The minimum degree of treatment shall be standard secondary treatment for municipal facilities and the industrial effluent guidelines as defined by Department rules and Federal regulations for industrial facilities. If the minimum degree of treatment requirements would violate state water quality standards, a higher degree of treatment will be required. Prior to preparation of the engineering report or facilities plan, design engineers must obtain effluent limitations and any other self-monitoring requirement (i.e., sample location, sample type, etc.). All facilities must be designed to meet average effluent limitations in the operation permit during any 30-day period and to not exceed maximum and seven-day average effluent limitations.

14.4 DESIGN

14.4.1 General

14.4.1.1 Type of Treatment

Careful consideration shall be given to the type of treatment selected in the engineering report or facilities plan as required by Subsection 11.2.9.5 of these standards.

14.4.1.2 Industrial Wastes

Consideration shall be given to the type and effects of industrial wastes on the treatment process. It may be necessary to pretreat industrial wastes prior to discharge to the sanitary sewer system.

14.4.1.3 Prohibited Wastes

The following wastes shall not be discharged to treatment facilities without assessment of their effects upon the treatment process or discharge requirements in accordance with state and federal law:

- a. Any toxic chemicals which may inhibit biological or bacteriological processes.
- b. Any strong oxidizing agents or disinfectants in quantities sufficient to inhibit the growth of microorganisms.
- c. Metal plating wastes or other toxic wastes containing heavy metals and/or toxic or noxious inorganic chemicals.

- d. Detergent wastes or other wastes containing excessive phosphorous or surfactants.
- e. Plastics, pharmaceutical wastes and/or other synthetic organic chemicals not amenable to biological treatment.
- f. Any wastes containing excessive amounts of nonbiodegradable oil and grease or tar.
- g. Any acidic or alkaline wastes which because of quantity, strength or unequalized flow may upset biological processes.
- h. Any wastes containing in excess of one milligram per liter phenols.
- i. Any wastes containing radioactive chemicals.
- j. Nutrient deficient wastes which cannot meet the normal ratio of 100 BOD₅: 5 Nitrogen: 1 Phosphorous necessary for the maintenance of the biomass.
- k. Any wastes that might cause excessive physical deterioration of the equipment, piping or structures.
- l. Any wastes with a closed cup flashpoint of less than 140 degrees Fahrenheit.
- m. Any other waste which may be defined as an incompatible pollutant.

14.4.2 Pre-Design Meeting

It is recommended that for treatment works projects a pre-design meeting be held with the applicant, design engineer, and the Department being in attendance. The purposes of this meeting would include:

- a. Discussion of changes subsequent to engineering report or facilities plan approval,
- b. Deviations from design standards, if any
- c. Schedule of submittal and review, and
- d. Facility reliability requirements determination.

14.4.3 New Process, Equipment and Application Evaluation, Project Coordination Meetings and Project Performance Standards

- a. The policy of the Department is to encourage rather than obstruct the development of any new methods or equipment for treatment of wastewater.

The lack of inclusion in the design standards of some types of wastewater treatment processes or equipment should not be construed as precluding their use. The Department may approve applications for construction permits accommodating other types of wastewater treatment processes and equipment under the condition that the operational reliability and effectiveness of the process or device shall have been demonstrated with one or more suitably-sized prototype unit operating at its design load conditions. The specific information required by the Department to demonstrate operational reliability and effectiveness will depend upon the process or device under consideration. Engineering reports assembling technical information or presenting design criteria and assumptions shall include a certification statement by a professional engineer. Information which may be required include:

- i. Monitoring observations, including test results (calibrated data) and engineering evaluations, demonstrating the efficiency of such processes or equipment.
 - ii. Detailed description of the test methods.
 - iii. Testing, including appropriately composited samples, under various ranges of strength and flow rates (including diurnal variations) and waste temperatures over a sufficient length of time to demonstrate adequate performance under climatic and other conditions which may be encountered in the area of the proposed installations. A control group may be required to demonstrate effectiveness.
 - iv. Other appropriate information deemed necessary by the Department.
- b. The Department may require that appropriate testing be conducted and evaluations be made under the supervision of a professional engineer other than the one employed by the manufacturer, patent holder or developer.
- c. A proposal for testing and engineering evaluation as a minimum should include the following:
- i. Goals, objectives and benefits with an explanation as to why a pilot study or field demonstration project is needed to obtain additional engineering data
 - ii. Literature search identifying key design parameters and related experience
 - iii. A description of the proposal with schematic diagrams, pictures, drawings or any other important information
 - iv. Environmental assessment, including both primary and secondary impacts

- v. Sampling and testing protocol
- vi. Cost for study and closure
- vii. Complete schedule for testing and evaluation including start, completion and submittal of summary report

d. Project Coordination Meetings

Coordination meetings are recommended and should be held with the applicant, design engineer, and the Department in attendance.

e. Standards of Performance

Where an innovative technology is recommended, the Department may require the permit holder to conduct additional monitoring and sampling following the initiation of operation, provide a contingency plan in the event that such technology fails to meet the expected performance and/or submit a certification by a professional engineer that the project meets the project performance standards.

14.4.4 Design Period

14.4.4.1 General

- a. The design period shall be clearly identified in the engineering report or facilities plan. The normal design period for municipal wastewater facilities shall be 20 years beyond the date of completion of construction. The Department may approve the use of a shorter design period on a case-by-case basis and contingent on the submission of a schedule of actions which identifies future improvements to avoid effluent quality violations caused by municipal growth.
- b. Industrial facilities shall, as a minimum, be sized to adequately treat wastewater produced during the maximum projected production period.

14.4.5 Hydraulic Design

14.4.5.1 General

Flow modeling should be considered for disposal systems impacted by infiltration and inflow from ordinary storms. The hydraulic design may be adjusted to account for infiltration and inflow which is eliminated by sewer system rehabilitation.

The peak hourly wet weather flow shall be used to evaluate the effect of hydraulic peaks on the design of pumps, piping, clarifiers, and any other flow sensitive aspects.

Initial low flow conditions must be evaluated in the design to minimize operation problems with freezing, septicity, flow measurements and solids dropout.

14.4.5.2 Critical Flow Conditions, Municipal

The following five flow conditions are critical to the design of the treatment plant:

- a. Average Dry Weather (ADW) flow - The daily average flow when the groundwater is at or near normal and runoff is not occurring. The period of measurement for this flow should extend for as long as favorable conditions exist up to 30 days if possible.
- b. Average Wet Weather (AWW) flow - The daily average flow for the wettest thirty (30) consecutive days for mechanical plants or for the wettest 180 consecutive days for controlled discharge lagoons.
- c. Maximum Seven Day Wet Weather (MSDWW) flow - The daily average flow for the wettest seven (7) consecutive days.
- d. Maximum Wet Weather (MWW) flow - the total maximum flow received during any 24 hour period when the groundwater is high and runoff is occurring.
- e. Peak Hourly Wet Weather (PHWW) flow - the total maximum flow received during one hour when the groundwater is high, runoff is occurring, and the domestic, commercial and industrial flows are at their peak. The domestic/commercial peak hour flow shall be based on actual monitoring information or the use of a peaking factor determined by use of Appendix I, Chapter 12 of these standards. The runoff flow component shall be adjusted to the storm event of two inches of rainfall in one hour.

14.4.5.3 Existing System, Municipal

Where there is an existing system, the volume and strength of existing flows shall be determined. The flow determination shall include, but not be limited to, all five (5) flow conditions listed in Subsection 14.4.5.2 of these standards. The strength determination shall include both dry weather and wet weather conditions. Composite 24-hour

samples proportional to flow shall be taken to be accurately representative of the strength of the wastewater. At least 3 years of flow data should be taken as the basis for the preparation of hydrographs for analysis to determine the flow conditions of the system. Eight (8) to ten (10) years of flow data is recommended. The increment of design flow for projected population growth shall be based upon the same criteria listed below for new systems.

14.4.5.4 New Systems, Municipal

The design for wastewater treatment plants to serve new collection systems shall be based on an average wet weather flow of 100 gallons per capita per day for residential and commercial flow, plus 20 gallons per capita per day for out-of-town students, plus industrial flow, plus any large commercial operation. Exceptions may be made on a case-by-case basis where there is an existing water supply with adequate available water use data. If adequate water use data from a water supply does not exist, exceptions may also be made where there is data from similar existing wastewater systems that can be utilized for new collection systems. However, in such cases, thorough investigation and adequate documentation shall be made to establish the reliability and applicability of such data.

14.4.5.5 Critical Flow Conditions, Industrial

Flow and loads from industrial sources may vary significantly during a day, a week or a month due to production patterns. In designing the facility, the flow rate which occurs during the time period of discharge must be considered. This flow rate is defined as the rated flow.

The following flow conditions must be considered in the design of the treatment facility:

- a. Average Rated Flow (30-Day) - The average rated flow which is expected to occur during production days in a 30 consecutive day period.
- b. Maximum Day Rated Flow - The maximum rated flow expected to occur during a single 24-hour period.
- c. Peak Hour Flow - The maximum flow which is expected to occur during a one-hour period.

Other flows must be considered when they are critical to the sizing and operation of the treatment process. When determining the critical flow

conditions, the following components shall be considered, as a minimum.

- Production Flows - for existing facilities, a minimum of one year of flow data shall be used for determining critical flows. This data shall be correlated with production data. For new facilities, the design flows shall be based on similar operating facilities, proposed operation mode, federal development documents for effluent limitations and new source performance data.
- Sanitary Flows - A minimum of 10 gallons per worker per shift per day shall be utilized. Higher values with suitable documentation shall be used if shower and cafeteria facilities are present.
- Contaminated Storm Runoff - If direct treatment of contaminated storm runoff is to be included, these flows shall be estimated using a rational method.

The treatment plant must be designed to meet the effluent limitations discussed in Section 14.3 of these standards.

14.4.5.6 Flow and Load Equalization

Measures creating uniform organic loadings to biological processes tend to reduce the probability of upsets.

- a. Facilities for the equalization of flows and organic shock load shall be considered when the ratio of PHWW flow to MSDWW flow is 2.5 or more. If flow equalization is not employed under these circumstances, an explanation must be included, outlining how the plant will handle transitions from MSDWW flow to PHWW flow.
- b. Where flow equalization is employed, the excess flow retained by the holding basin shall be returned to the treatment plant in a timely manner during off-peak periods. The hydraulic capacity of the plant should be in the range of the MSDWW flow to the MWW flow. Individual circumstances may dictate higher capacities. In no case shall the hydraulic capacity of the treatment plant be less than the AWW-30 flow. As necessary, any organic under loadings that may occur when excess flows are returned to the treatment plant must be carefully addressed.
- c. The maximum cumulative storage volume for flow equalization should be based on incoming sewers designed for unrestricted flow.

Where the ratio of PHWW flow to MSDWW is 2.5 or more, the maximum cumulative storage volume that must be provided for flow equalization at municipal facilities will typically be in the range of 2 to 3 days based upon the AWW-30 flow.

14.4.6 Organic Design

14.4.6.1 Domestic Loadings

- a. When an existing treatment works is to be upgraded or expanded, the organic design shall be based upon the actual strength of the wastewater as determined from the measurements taken in accordance with 14.4.5.3 of these standards, with an increment for growth. This growth increment shall be based on the design criteria for new systems stated below. A loading rate of 0.17 pounds BOD₅ per capita per day and 0.036 lbs TKN per capita per day may be used in lieu of actual loading rates whenever such loading rates are less than 0.17 pounds BOD₅ per capita per day and 0.036 lbs TKN per capita per day, respectively.
- b. Domestic waste treatment design to serve new collection systems shall be based on at least 0.17 pounds of BOD₅ per capita per day, 0.036 lb TKN per day and 0.20 pounds of suspended solids per capita per day plus 0.05 pounds of BOD₅, 0.01 pounds of TKN, and 0.05 pounds of suspended solids per out-of-town student per day.
- c. When garbage grinders are used in areas tributary to a domestic treatment plant, the design basis should be increased to 0.22 pounds of BOD₅ per capita per day, 0.046 lbs TKN per capita per day and 0.25 pounds of suspended solids per capita per day.
- d. Domestic waste treatment plants that will receive industrial wastewater flows shall be designed with additional capacity for these industrial waste loads.

14.4.6.2 Industrial Loadings

- a. The design loadings of industrial wastewater treatment works shall be based on actual sampling in accordance with Subsection 14.4.5.4 of these standards, data from similar industrial facilities, or federal development documents for effluent limitation guidelines and new source performance requirements.
- b. The treatment facility must be designed to meet the effluent limitations discussed in Section 14.3 of these standards. In

addition, diurnal peaks of organic loads must be addressed if such peaks adversely affect a unit process.

14.4.6.3 Septage Loadings

The waste loadings from other sources shall include, but not be limited to, the amount and rate of septage, if any, that will be accepted by the wastewater treatment plant above collection system loadings.

14.4.7 Conduits

All piping and channels shall be designed to carry the maximum expected flows into these conduits or channels without flooding. Bottom corners of the channels, except final effluent channels, must be filleted. Conduits shall be designed to avoid creation of pockets and corners where solids can accumulate. The use of shear gates, stop plates or stop planks is permitted where they can be used in place of gate valves or sluice gates. Corrosion resistant materials shall be used for valves, plates and gates. Pipes subject to clogging shall be provided with means for mechanical cleaning and flushing.

14.4.8 Design Details

14.4.8.1 Unit Bypass During Construction

Final plan and specification documents shall identify or require a construction sequence for uninterrupted operation of the existing plant during construction so as to minimize temporary water quality degradation.

14.4.8.2 Drains

A means shall be provided to dewater each unit in the process. This shall be accomplished by means of gravity drains or pumping. The drainage must receive a degree of treatment which will allow for discharge in compliance with the facilities' permit limitation.

14.4.8.3 Buoyancy

Suitable methods shall be included in the design to prevent flotation of structures in areas subject to high groundwater.

14.4.8.4 Pipe Identification

In order to facilitate identification of piping, it is required that process piping be clearly identified by labeling or color coding. Appendix

14A presents a recommended color scheme for purposes of standardization.

14.4.8.5 Operating Equipment

A complete outfit of tools, accessories, and spare parts necessary for the plant operator's use should be provided. Readily-accessible storage space and workbench facilities should be provided in non-lagoon facilities.

14.4.8.6 Erosion Control During Construction

Effective site erosion and sediment control shall be provided during construction. All temporary erosion and sediment control measures shall be removed or replaced with permanent measures after construction.

14.4.8.7 Grading and Landscaping

Upon completion of plant construction, the ground shall be graded and seeded or sodded. Surface water shall not be permitted to drain into any unit.

14.4.8.8 Sludge Disposal During Construction

- a. Sludge removal may be required when upgrading an existing disposal system. The approved sludge processing, storage and disposal plan may be implemented by inclusion in the final plan and specification documents to be bid for the project.
- b. Transferring sludge from an existing lagoon cell into any new pond cell for disposal is prohibited.

14.4.9 Plant Operability

14.4.9.1 Unit Operation Bypassing

- a. Bypassing shall be provided around each unit operation, except as follows. Unit operations with two or more units and involving open basins shall not be required to have provisions for bypassing if the peak wastewater flow can be handled hydraulically with the largest unit out of service. The comminution facility shall be provided with means for gravity bypassing regardless of the number and flow capacity of the comminutors.

- b. The actuation of all bypasses shall require manual action by operating personnel. All power actuated bypasses shall be designed to permit manual operation in the event of power failure and shall be designed so that the valve will fail as is, upon failure of the power operator.
- c. A fixed high-water level bypass overflow should be provided in addition to a manually or power actuated bypass to prevent flooding in case the operator bypass fails to function or is unattended at times.

14.4.9.2 Flexibility

Where duplicate units are provided, a central collection and distribution point including proportional flow splitting shall be provided for the wastewater flows before each unit operation. Exceptions to this requirement may be made, on a case-by-case basis, when the design incorporates more than one unit process in the same physical structure.

14.4.9.3 Flow Division Control

Flow division control facilities shall be provided as necessary to ensure positive, adjustable control of organic and hydraulic loading to the individual process units and shall be designed for easy operator access, change, observation, and maintenance. Where duplicate units are provided, a flow division control facility shall be designed to properly proportion flow to each unit operation so that proportioned flows are measurable.

14.5 **TREATMENT FACILITY RELIABILITY CLASSES**

14.5.1 Facility Reliability Classes

The Department will establish reliability classes for all new facilities and facilities undergoing major modifications in accordance with one of the following classes listed in this Section. Designated uses are described in Chapter 567 IAC 61, Water Quality Standards.

- a. Reliability Class I - Includes all facilities which discharge into waters that could be permanently or unacceptably damaged by effluent which was degraded in quality for a few hours. This includes those facilities discharging into Outstanding Iowa Waters or into waters designated as: Class A1 - primary contact recreational use; Class A3 - children's recreational use; Type 1 Class B(CW1) - cold water aquatic life; Type 2 Class B(CW2) - cold water aquatic life; Type 1 Class B(WW-1) - warm water; Class HH - human health; or Class C - drinking water supply.

- b. Reliability Class II - Includes all facilities which are not included in Reliability Class I where a reduction in effluent quality for several days would cause a violation of the water quality standards of the receiving body of water and includes waters designated as: Class A2 - secondary contact recreational use; Type 2 Class B(WW-2) - warm water; Type 3 Class B(WW-3) - warm water; or Class B(LW) - lakes and wetlands.
- c. Reliability Class III - Includes all facilities which are not included in Reliability Classes I or II. This includes controlled discharge lagoons, treatment prior to land application, and facilities which discharge into undesignated use waters that do not fall under the rebuttable presumption where the effluent limits are governed by the protection of undesignated use waters.

14.5.2 Unit Process Reliability Criteria

The requirements for system reliability are normally achieved by providing duplicate or multiple units for each treatment process, but reliability can also be achieved through flexibility in the design and operation of systems and components. As used in these criteria, a unit operation is a single physical, chemical or biological process.

14.5.2.1 Unit Process Reliability Criteria A

The following reliability is required for any mechanical treatment facility that is Facility Reliability Class II or III, and is required to provide secondary treatment.

- a. Duplication of major treatment units is not required. If provided, duplication for any unit process or operation shall, as a minimum, be in accordance with the appropriate part of Process Reliability Criteria B.
- b. When duplicate units are not provided, the facility shall include a pond having five (5) days storage capacity for the average wet weather flow and with the capability to bypass the pond when effluent limitations are being met. This pond may also be used for flow equalization. Provisions for returning the holding pond contents to the treatment process are required.

The pond shall be constructed in accordance with the applicable provisions of Section 18C.7 of these standards, particularly Section 18C.7.3 of these standards pertaining to sealing of the pond bottom and maximum percolation rate. Separate volumes must be provided in the pond for the five (5) days storage capacity for the average wet weather flow and for flow equalization if it is planned

to use the pond for both purposes. A minimum water level of two (2) feet shall be maintained at all times. Adequate provisions must be made for the necessary valving, piping, pumping, metering, aeration and sludge removal capabilities to permit the pond to be maintained and operated in a manner to effectively perform its intended functions.

- c. Sludge wasting, sludge stabilization (as defined by process) and holding, and a final sludge disposal site are required.

14.5.2.2 Unit Process Reliability Criteria B

The following reliability is required for any mechanical treatment facility providing either two-stage nitrification (which includes intermediate clarification) or standard secondary treatment with no nitrification requirement and which is not regulated by Process Reliability Criteria A:

- a. If primary screens are used, duplication shall be provided in accordance with the following:

There shall be a sufficient number of units of a size such that, with the largest flow capacity unit out of service, the remaining units shall have a peak flow capacity of at least 100% of the PHWW flow (or industrial peak hour flow) to that unit operation.

- b. Duplication of all primary clarifiers (if used), aeration basins, and fixed film reactors shall be of a sufficient number of units of a size such that, with the largest unit out of service, the remaining units shall have a design load capacity of at least 50% of the total design loading to that unit operation.
- c. Duplication of all final clarifiers shall be of a sufficient number of units of a size such that with the largest unit out of service, the remaining units shall have a design load capacity of at least 75% of the total design loading to that unit operation for Facility Reliability Class I and 50% for Facility Reliability Class II or III.
- d. Sludge wasting, sludge stabilization (as defined by process) and holding, and a final sludge disposal site are required.

14.5.2.3 Unit Process Reliability Criteria C

The following reliability is required for any mechanical treatment facility providing single stage combined carbonaceous oxidation and nitrification:

- a. If screens are used in lieu of primary clarifiers, duplication shall be of a sufficient number of units of a size such that, with the largest flow capacity unit out of service, the remaining units shall have a peak flow capacity of at least 100% of the PHWW flow (or industrial peak hour flow) to that unit operation.
- b. Duplication of all primary clarifiers (if used), aeration basins and fixed film reactors shall be of a sufficient number of units of a size such that, with the largest unit out of service, the remaining units shall have a design load capacity of at least 50% of the total design loading to that unit operation.
- c. Duplication of all final clarifiers shall be of a sufficient number of units of a size such that, with the largest unit out of service, the remaining units shall have a design load capacity of at least 75% of the total design loading to that unit operation, except that duplication of all final clarifiers for treatment facilities with no nitrification requirement other than enhanced nutrient control shall be of a sufficient number of units of a size such that with the largest unit out of service, the remaining units shall have a design load capacity of at least 75% of the total design loading to that unit operation for Facility Reliability Class I and 50% for Facility Reliability Class II or III.
- d. Sludge wasting, sludge stabilization (as defined by process) and holding, and a final sludge disposal site are required.

14.5.2.4 Unit Process Reliability Exceptions

- a. No duplication is required when upgrading an existing plant which contains one unit large enough to provide at least 100% of the total design load capacity to that unit operation.
- b. No duplication is required when upgrading of an existing unit to be operated in parallel with a larger new unit, so long as the existing unit provides at least 40% of the total design load capacity of that unit operation.
- c. For enhanced nutrient control facilities where the design for nitrification meets these design standards for activated sludge biological treatment and settling, including applicable unit process reliability criteria for single stage combined carbonaceous oxidation and nitrification, no duplication is required to accommodate denitrification as a supplemental treatment process

unless required to safeguard the public health or protection of water quality.

14.5.3 Power Source Reliability

Two separate and independent sources of electric power shall be provided to facilities from either a single substation and an emergency power generator or two separate utility substations. An emergency power generator is recommended where both substations may lose power from storm damage. If available from the electric utility, at least one of the facility's power sources shall be a preferred source (i.e., a utility source which is one of the last to lose power from the utility grid due to loss of power generating capacity). In areas where it is projected that sometime during the design period of the facility, the electric utility may reduce the rated line voltage (i.e., "brown out") during peak utility system load demands, an emergency power generator shall be provided as an alternate power source. Reliability and ease of starting, especially during cold weather conditions, shall be considered in the selection of the type of fuel for internal combustion engines. Where public utility gas is selected, consideration shall be given to a generator design that may be operated with an alternate fuel supply. At a minimum, the capacity of the backup power source for each Facility Reliability Class shall be as follows:

- a. For Facility Reliability Class I facilities, the backup power source shall be sufficient to operate all vital components, during peak wastewater flow conditions, together with critical lighting and ventilation. Vital components include those associated with flow, treatment, pumping, metering and disinfection, and those parts of sludge handling which cannot be delayed without adverse effects on plant performance. Critical lighting and ventilation is that needed to maintain safety and perform duties associated with operation of the vital components of the plant.
- b. For Facility Reliability Class II facilities, the backup power source shall be the same as for Reliability Class I facilities, except that vital components used to support the secondary processes (i.e., mechanical aerators or aeration basin air compressors) are not required so long as sedimentation and disinfection are provided.
- c. For Facility Reliability Class III facilities, the backup power source shall be sufficient to operate the screening or comminution facilities, the main wastewater pumps, the primary sedimentation basins, and the disinfection facility during peak wastewater flow condition, together with critical lighting and ventilation.
- d. Requirements concerning rated capacity of electric power sources are not intended to prohibit other forms of emergency power, such as diesel driven main wastewater pumps.

- e. Regardless of the reliability class, for facilities where a long-term (four hours or more) power outages has occurred, backup power for providing minimum aeration of an activated sludge system will be required.

14.6 PLANT OUTFALL

14.6.1 General

The outfall sewer shall be designed to discharge to the receiving stream in a manner acceptable to the Department. Consideration should be given to the following:

- a. Whether free fall or submerged discharge is preferable at the site selected;
- b. Utilization of cascade aeration of effluent discharge to increase dissolved oxygen; and
- c. Limited or complete across-stream dispersion of the final effluent as needed to protect aquatic life movement and growth in the immediate reaches of the receiving stream.

14.6.2 Protection and Maintenance

The outfall sewer shall be so constructed and protected against the effects of floodwater, ice, or other hazards as to reasonably ensure its structural stability and freedom from stoppage.

14.6.3 Sampling Provisions

- a. All outfalls shall be designed so that a sample of the effluent can be obtained at a point after the final treatment process and before discharge to or mixing with the receiving waters.
- b. If disinfection is provided, a sampling point also is required immediately prior to disinfection. However, where ultraviolet radiation is used, an exception to this Section may be approved by the Department on a case by case basis.

14.6.4 Effluent Diffuser System

If needed to enhance dispersion as described in Section 14.6.1“c”, the alternative of an effluent diffuser system may be considered for the plant outfall. Proposals will be reviewed on a case by case basis at the discretion of the Department. In addition to meeting the applicable requirements of these design standards, the design shall maximize initial dilution in the receiving stream and should be based on an approved USEPA mixing model. All designs shall be provided with the

necessary flexibility to conveniently maintain and operate the diffuser system. Pumping is recommended. The requirements for conduits as described in Section 14.4.7 of these standards shall apply to all outfall sewers. All wastewater treatment plants shall be provided with protection for the effluent diffuser system by installing bar screens. If flow bypasses the effluent diffuser system, additional flow measurement and recording shall be provided.

- a. At design pumping rates, a cleansing velocity of at least 3 feet per second should be maintained throughout each manifold.
- b. The required degree of mixing with the receiving waters shall be achieved within 100 feet of the diffuser. Dispersion of the effluent into the receiving stream shall be uniform. Generally, port spacing should be 3 to 6 feet on centers. A zone of passage for aquatic life shall be maintained outside of the acute zone of initial dilution. Where the receiving stream may deposit sand and mud to an elevation above the port openings, the velocity of the orifice flow at each port should be at least 10 feet per second at all rates of flow within the design limits.
- c. Each diffuser port opening should be 2 inches in diameter or larger.
- d. Risers shall be placed at no more than 60 degrees from the horizontal and shall discharge below the water surface at the 7Q10 flow of the receiving stream. In no case shall the jet of water from any riser break water surface or erode the streambed. Orifice flow velocities should not exceed 15 feet per second. Where pipe flow velocities greater than 10 feet per second are attained, special provisions as necessary should be made to protect against displacement caused by impact.
- e. Where multiple manifolds are provided, the effluent diffuser system shall have capacity such that, with any manifold out of service, the remaining manifolds will have capacity to disperse the maximum expected flows.
- f. The top of all outfall sewers entering or crossing streams shall be at a sufficient depth below the natural bottom of the stream bed to protect the line. For additional requirements, see Section 12.5.11 of these standards.
- g. Bends in the receiving stream where a sand bar may be created from channel migration should be avoided.
- h. Location of the effluent diffuser system shall be permanently posted both upstream and downstream of the diffuser to clearly identify to boaters and other recreational users the nature and presence of the plant outfall. It shall be the responsibility of the owner of the treatment plant to eliminate hazards to navigation and other public uses of the receiving stream.

14.7 ESSENTIAL FACILITIES

14.7.1 Water Supply

14.7.1.1 General

No piping, connections, or potential cross connection situations, shall exist in any part of the treatment works which, under any conditions, might cause the contamination of a potable water supply.

14.7.1.2 Direct Connections

- a. Potable water from a municipal or separate supply may be used directly at points above grade for the following hot and cold supplies:
 - i. Lavatories;
 - ii. Water closets;
 - iii. Laboratory sinks (with vacuum breaker);
 - iv. Showers;
 - v. Drinking fountains;
 - vi. Eye wash fountains; and
 - vii. Safety showers.
- b. Hot water for any of the above units shall not be taken directly from a boiler used for supplying hot water to a sludge heat exchanger or digester heating unit.

14.7.1.3 Indirect Connections

Where a potable water supply is to be used for any purpose in a plant other than those listed in Subsection 14.7.1.2 of these standards either a combination of break tank, pressure pump, and pressure tank or an approved reduced pressure backflow preventer (AWWA C506) is required.

- a. Water shall be discharged to a break tank through an air gap at least six inches above the maximum flood line or the spill line of the tank, whichever is higher.
- b. A sign shall be permanently posted at every hose bib, faucet, hydrant, or sill cock located on the water system beyond a break tank or backflow preventor to indicate that the water is not safe for drinking.

14.7.1.4 Separate Potable Water Supply

Where it is not possible to provide potable water from a public water supply, a separate well may be provided. Location and construction of the well must comply with requirements of the Department.

14.7.1.5 Separate Non-Potable Water Supply

Where a separate non-potable water supply is to be provided, a break tank will not be necessary, but all system outlets shall be posted with a permanent sign indicating the water is not safe for drinking.

14.7.2 Flow Measurement

Continuous flow measurement and recording shall be provided for all wastewater treatment plants serving a population equivalent (P.E.) greater than 100. For facilities serving less than 100 P.E, a flow measurement device shall be provided and the design of the structure shall facilitate the installation of continuous flow recording equipment and automatic samplers. At a minimum, all continuous flow recording equipment should be designed to report the volume of flow during each one hour period and each one minute period.

14.7.2.1 General

- a. All influent flow measurement devices shall be self-flushing. Weirs shall not be acceptable for influent flow measurement except for very low flows where an "H" flume or an equivalent self-flushing flow measuring devices are not accurate. Self-cleaning in-channel floats may be allowed for influent head measurements. Use of floats in stilling wells is acceptable.
- b. Nothing in these standards shall be construed to suggest flow measurement equipment should not be used.

14.7.2.2 Requirements for Specific Systems

- a. For controlled discharge lagoon, flow measurement facilities shall be provided for the total influent flow and any discharge from the lagoon. Equipment to continuously measure and record flow rates and total influent flow is required. A V-notch weir without level monitoring equipment is permitted for measuring intermittent discharges from controlled discharge facilities.
- b. Flow-through treatment systems must have the capability of continuously measuring and recording flow rates and total flow to the plant.

- c. If flow is equalized by a wastewater treatment process (such as sequencing batch reactors), additional flow measurement and recording shall be provided.
- d. If flow bypasses a portion of the plant, additional flow measurement and recording shall be provided.
- e. Operation permits may require additional flow measurement and recording on a case-by-case basis.
- f. Flow measuring devices for determining recycle flow, return sludge flow, and waste sludge volume shall be provided.
- g. Total retention facilities shall provide an accurate means of determining the total daily flow into the facility.

14.7.2.3 Magnetic Flow Meters

Where practicable, a magnetic flow meter on a lift station force main with automatic continuous recording equipment will be an acceptable method of providing continuous flow monitoring. Changes in pipe size or abrupt changes in pipe direction near the meter should be avoided.

14.7.2.4 Volumetric Meters

Volumetric meters may be considered for small pumping stations controlled by low level and high level contacts.

14.7.2.5 Elapsed Time Meters

Elapsed time meters (ETMs) with an event recorder on lift station pump controls may be used for continuous flow monitoring if all the following are true:

- a. The lift station is a component of a controlled discharge lagoon or for flow-through treatment facilities serving 500 P.E. or less, and
- b. The installation of a flume with automatic continuous recording equipment, or its equivalent, is an impractical alternative.

14.7.2.6 Reliability and Accuracy

Flow measurement equipment shall accurately measure flow with a maximum deviation of ± 10 percent of true discharge rates throughout the range of discharge levels of the flow measuring device plus a

deviation of ± 3 percent of the maximum design flow for the transmitting-recording equipment.

14.7.3 Sampling Equipment

- a. Effluent composite sampling equipment shall be provided as necessary to meet discharge monitoring requirements. Composite sampling equipment also shall be provided as needed for influent sampling and for monitoring plant operations. The influent sampling point for all plants shall be located at the plant. Where practical or required, the design shall flow proportion composite 24-hour samples.
- b. Section 13.4.7 of these standards shall be considered in the design and location of influent composite sampling equipment.
- c. Provisions to report the amount and rate of septage, if any, that will be accepted by the wastewater treatment plant above collection system loadings shall be provided.

14.8 **SAFETY**

It is the facility owner's responsibility to ensure that the Occupational Safety and Health Administration (OSHA), NFPA 70, NFPA 820, and other applicable building and construction codes and requirements are met during construction and subsequent operation. During construction this requirement may be met by including references to OSHA, NEC and other applicable building and construction codes in the contract documents.

14.9 **LABORATORY**

14.9.1 Minimum Required Laboratory Analysis Capability

Careful consideration should be given to the laboratory facilities needed for the operational control of each plant. Analyses shall be utilized which will evaluate the efficiency of the entire treatment facility as well as the efficiency of individual treatment units. The Department has established the minimum self-monitoring requirements and analytical procedures for wastewater treatment plants in 567 IAC Chapter 63 - Monitoring, Analytical and Reporting Requirements. Additional monitoring may be required based on a case-by-case evaluation of the impact of the discharge on the receiving stream, toxic or deleterious effects of wastewaters, industrial contribution to the system, complexity of the treatment process, history of non-compliance or any other factor which requires strict operational control to meet the effluent limitations of the permit.

14.9.2 Laboratory Capability

All treatment works shall include a laboratory for making the necessary analytical determinations and operating control tests, except in individual situations where operational testing is minimal or not required and self-monitoring analyses are to be performed off-site. The laboratory shall have sufficient size, bench space, equipment and supplies to perform all on-site self-monitoring analytical work required by the operation permits, and to perform the process control tests necessary for management of each treatment process included in the design. The laboratory should have the capability and supplies to perform analytical work to support industrial waste control programs. The laboratory size and arrangement must be sufficiently flexible and adaptable to accomplish these assignments. Laboratory guidelines are detailed in Appendix 14B.

APPENDIX 14A

RECOMMENDED PROCESS PIPING COLOR CODING

Raw sludge line - gray

Digested sludge line - black

Sludge recirculation suction line - brown with yellow bands

Sludge draw off line - brown with orange bands

Sludge recirculation discharge line - brown

Sludge gas line - red

Natural gas line - red with black bands

Non-potable water line - purple

Potable water line - blue

Chlorine line - yellow

Sulfur Dioxide - yellow with red bands

Sewage line - gray

Compressed air line - dark green

Process air line - light green

Water line for heating digesters or buildings - blue with a six-inch red band spaced 30 inches apart

Fuel oil/diesel - red

Plumbing drains and vents – black (or gray)

Polymer – unpainted PVC

If labeling is used the contents should be clearly indicated on the piping in a contrasting color.

APPENDIX 14B

LABORATORY GUIDELINES

Location and Space

The laboratory should be located on ground level, easily accessible to all sampling points, with environmental control as an important consideration. It shall be located away from vibrating machinery or equipment which might have adverse effects on the performance of laboratory instruments or the analyst or shall be designed to prevent adverse effects from vibration. A minimum of 180 square feet of floor space should be provided for activated sludge, physical-chemical and advanced wastewater treatment plants; a minimum of 150 square feet of floor space should be provided for other type of treatment plants; and a minimum of 400 square feet of floor space should be provided for laboratories having a full time laboratory chemist. Bench-top working surface should occupy at least 35 percent of the total floor space.

Minimum ceiling height should be eight feet six inches. If possible, this height should be increased to provide for the installation of wall-mounted water stills, distillation racks, and other equipment with extended height requirements.

Additional floor and bench space should be provided to facilitate performance of analysis of industrial wastes, as required by the operation permit and the utility's industrial waste pretreatment program. The above minimum space does not provide office or administration space.

Materials

Ceilings

Acoustical tile should be used for ceilings except in high humidity areas, where they should be constructed of cement board or equal.

Walls

Wall finishes should be light in color and nonglare.

Floors

Floor surfaces should be either vinyl or rubber, fire resistant, and highly resistant to acid, alkalines, solvents, and salts. Floor finishes should be of a single color for ease of locating small items that have been dropped.

Doors

Two exit doors should be located to permit a straight egress from the laboratory, preferably at least one to outside the building.

Panic hardware should be used. They should have large glass windows for easy visibility of approaching or departing personnel.

Automatic door closers should be installed; swinging doors should not be used.

Flush hardware should be provided on doors if cart traffic is anticipated. Kick plates are also recommended.

Cabinets and Bench Tops

Wall-hung cabinets are useful for dust-free storage of instruments and glassware. Units with sliding glass doors are preferable. They should be hung so the top shelf is easily accessible to the analyst. Thirty inches from the bench top is recommended.

One or more cupboard-style base cabinets should be provided for storing large items; however, drawer units are preferred for the remaining cabinets. Drawers should slide out so that entire contents are easily visible. They should be provided with rubber bumpers and with stops which prevent accidental removal. Drawers should be supported on ball bearings or nylon rollers which pull easily in adjustable steel channels. All metal drawer fronts should be double-wall construction.

All cabinet shelving should be acid-resistant and adjustable from inside the cabinet. Water, gas, air, and vacuum service fixtures; traps, strainers, overflows, plugs and tailpieces; and all electric service fixtures shall be supplied with the laboratory furniture.

Generally, bench-top height should be 36 inches. However, areas to be used exclusively for sit-down type operations should be 30 inches high and include kneehole space. One-inch overhangs and drip grooves should be provided to keep liquid spills from running along the face of the cabinet. Tops should be finished in large sections, 1-1 1/4 inches thick. They should be field joined into a

continuous surface with acid, alkali, and solvent-resistant cements which are at least as strong as the material of which the top is made.

Hoods

Fume hoods to promote safety and canopy hoods over heat-releasing equipment, if provided, should be installed near the area where most laboratory tests are made.

Sinks

The laboratory should have a minimum of two sinks (not including cup sinks). At least one of them should be double-wall with drainboards. Additional sinks should be provided in separate work areas as needed, and identified for the use intended.

Sinks should be made of epoxy resin or plastic material with all appropriate characteristics for laboratory applications. The sinks should be constructed of material highly resistant to acids, alkalies, solvents, and salts, and should be abrasion and heat resistant and nonabsorbent.

Traps should be made of glass, plastic, or lead and easily accessible for cleaning. Waste openings should be located toward the back so that standing overflow will not interfere. All water fixtures on which hoses may be used should be provided with vacuum relief valves to prevent contamination of water lines.

Ventilation and Lighting

Laboratories should be separately air conditioned, with external air supply for 100% make-up volume. In addition, separate exhaust ventilation should be provided. Ventilation outlet locations should be remote from ventilation inlets.

Air intake should be balanced against all supply air that is exhausted to maintain an overall positive pressure in the laboratory relative to atmospheric and other pressurized areas of the building which could be the source of airborne contaminants.

Good lighting, free from shadows, is important for reading dials, meniscuses, etc., in the laboratory.

Gas and Vacuum

Natural gas should be supplied to the laboratory. Digester gas should not be used.

An adequately-sized line source of vacuum should be provided with outlets available throughout the laboratory.

Equipment, Supplies and Reagents

The laboratory shall be provided with all of the equipment, supplies, and reagents that are needed to carry out all of the facility's analytical testing requirements. Operation permit, process control, and industrial waste monitoring requirements should be considered when specifying equipment needs. References such as Standard Methods and the U.S.E.P.A. Analytical Procedures Manual should be consulted prior to specifying equipment items.

Microscope

A binocular or trinocular microscope with a 20 watt halogen light source; phase contrast condenser; mechanical stage; 10x, 40x and 100x phase contrast objectives; wastewater reticle eyepiece and centering telescope is recommended for process control at activated sludge plants.

Balance and Table

An analytical balance, single pan 0.1 milligram sensitivity type, shall be provided for plants performing laboratory tests including biochemical oxygen demand, suspended solids and fecal coliform analysis. A heavy balance table which will minimize vibration of the balance is recommended. It shall be located as far as possible from windows, doors or other sources of drafts or air movements.

Power Supply Regulation

To eliminate voltage fluctuation, electrical lines supplying the laboratory should be controlled with a constant voltage, harmonic neutralized type of transformer. This transformer should contain less than 3% total root mean square (RMS) harmonic content in the output, should regulate to $\pm 1\%$ for an input range of $\pm 15\%$ of nominal voltage, with an output of 118 volts. For higher voltage requirements, the 240-volt lines should be similarly regulated.

Electrical devices in the laboratory not requiring a regulated supply (i.e., ordinary resistance heating devices) that are non-portable may be wired to an unregulated supply.

Water Still

An all-glass water still, with at least one gallon per hour capacity should be installed complete with all utility connections.