

# IOWA DEPARTMENT OF NATURAL RESOURCES

LEADING IOWANS IN CARING FOR OUR NATURAL RESOURCES

KAYLA LYON, DIRECTOR

April 2023

Water Supply Engineering Section

Tara Naber, PE | 515-725-0292 | tara.naber@dnr.iowa.gov

## Water Main and Sewer Separation Requirements FAQ

### Background on 2022 Changes

Updates to 567 IAC 43.3 (2)“a”(3) to replace subparagraph (3) with new subparagraphs (3) and (4) were made to allow for added flexibility for water main project design with regards to separation from sanitary and storm sewers effective March 16, 2022. Previously, water main separation from sewers was covered by Chapter 12 of the Wastewater Engineering Design Standards, which were written based on sewer construction rather than water main construction. The previous requirements did not account for conflicts with existing sewer infrastructure and treated sanitary sewers and storm sewers equally. The updates to 567 IAC 43.3(2)“a”(3) state the requirements for separation based on water main construction and provide common alternatives that were previously allowed through the waiver process. The following tables outline the requirements and options for handling separation conflicts between a water main and sewer based on the updated rule.

### Separation of Water Mains and Sanitary Sewers

#### **Horizontal Separation: Gravity Sanitary and Combined Sewers**

Scenario	Requirements
Separation $\geq$ 10 feet, edge to edge	No additional requirements
3 feet $\leq$ separation $<$ 10 feet, edge to edge, with water main located at least 18 inches above top of sewer	The water main must be placed in a separate trench or on a bench of undisturbed earth in the same trench as the sewer.
3 feet $\leq$ separation $<$ 10 feet, edge to edge, with water main located less than 18 inches above top of sewer	Option 1: construct water main within watertight casing pipe with evenly spaced annular gap and watertight end seals, or Option 2: construct sewer of water main materials.
If it is not possible to obtain 3 feet $\leq$ separation $<$ 10 feet, edge to edge, with water main located less than 18 inches above top of sewer; and if there is 2 feet $\leq$ separation $<$ 3 feet, edge to edge	Option 1: The water main shall be enclosed in watertight casing pipe with an evenly spaced annular gap and watertight end seals, or Option 2: Sewer must be constructed of water main materials
Separation $<$ 2 feet	Not allowed

#### **Horizontal Separation: Sanitary Sewer Force Mains**

Scenario	Requirements
Separation $\geq$ 10 feet, edge to edge	No additional requirements
4 feet $\leq$ separation $<$ 10 feet, edge to edge	Sewer must be constructed of water main materials
Separation $<$ 4 feet	Not allowed

### Vertical Separation / Crossings: Gravity Sanitary and Combined Sewers

Scenario	Requirements
Separation $\geq$ 18 inches, water main located above sewer	No additional requirements
6 inches $\leq$ separation < 18 inches, water main located above sewer	Option 1: construct water main within watertight casing pipe with evenly spaced annular gap and watertight end seals, or Option 2: construct sewer of water main materials
Separation $\geq$ 18 inches, water main located below sewer	
Separation < 6 inches, water main above sewer	Not allowed
Separation < 18 inches, water main below sewer	

**Manholes:** Water main must have 3 feet of horizontal separation from sanitary and combined sewer manholes.

### Separation of Water Mains and Storm Sewers

#### Horizontal Separation: Gravity Storm Sewers

Scenario	Requirements
Separation $\geq$ 10 feet, edge to edge	No additional requirements
3 feet $\leq$ separation < 10 feet, edge to edge	Option 1: construct water main of ductile iron pipe with gaskets impermeable to hydrocarbons, or Option 2: construct water main within watertight casing pipe with evenly spaced annular gap and watertight end seals, or Option 3: construct sewer of water main materials, or Option 4: reinforced concrete pipe storm sewers shall be constructed with gaskets manufactured in accordance with ASTM C443

\*A minimum of 3 feet of horizontal separation shall be maintained.

#### Vertical Separation / Crossings: Gravity Storm Sewers

Scenario	Requirements
Separation $\geq$ 18 inches	No additional requirements
6 inches $\leq$ separation < 18 inches, water main located above sewer	Option 1: construct water main of ductile iron pipe with gaskets impermeable to hydrocarbons, or Option 2: construct water main within watertight casing pipe with evenly spaced annular gap and watertight end seals, or Option 3: construct sewer of water main materials, or Option 4: reinforced concrete pipe storm sewers shall be constructed with gaskets manufactured in accordance with ASTM C443
Separation < 6 inches, water main above sewer	Not allowed
Separation < 18 inches, water main below sewer	