

DATE RECEIVED		FACILITY NAME		COUNTY NO.	PROGRAM AREA CODE	FACILITY TYPE CODE	SUBJECT AREA CODE
3 5/7/86		4 GARNAUILLO		5 22	6 CP	7 COS	8 OLD STDS. 300
RULE REFERENCE		DESIGN STANDARD REFERENCE		DECISION		APPEAL ACTION	
9 64.2(7)		10 18c.4.1		11 APPROVED 5/7/86		12	

13 BRIEF DESCRIPTION OF VARIANCE REQUESTED:

The hydraulic basis of design would be on $ADW_{10} + 30\% (AWW_{10} - ADW_{10})$ instead of AWW_{10}

14 JUSTIFICATION FOR DECISION:

This proposed method is contained in our revised design standards 18c.4.1.2 which has official Department approval since it was submitted for adoption to the Commission this way.

See attached

15 PRECEDENTS USED:

NONE

16 STAFF REVIEWER:

BOB GRAF

17 SUPERVISOR:

WCF

18 AUTHORIZED BY:

TEO

Following attached to each copy of variance request

The grantee was notified at the beginning of planning that Chapter 18c of the design standards were being revised. It was projected at that time that the proposed standards would be in effect at the time of Permit issuance. They were instructed to follow these draft standards since they were substantially complete.

The standards were scheduled for adoption on Feb. 18, 1986. They were nearly 100% ready at the commencement of design. Again we instructed them to use the new standards. They proceed that way.

The date of scheduled adoption was pushed back to April 1986, but still was not adopted by the commission due to public comments. We did not feel that it was fair to the city of Gainsville to further increase their project turnover and costs because of the actions of one individual and the commission.