



TERRY E. BRANSTAD, GOVERNOR

DEPARTMENT OF NATURAL RESOURCES

LARRY J. WILSON, DIRECTOR

July 10, 1998

City of Osage  
806 Main  
P.O. Box 29  
Osage, IA 50461

**SUBJECT: Variance Request for Final Clarification Sizing  
Wastewater Treatment Facility Improvements  
Osage, Iowa**

**The Iowa Department of Natural Resources in accordance with subrule 567--64.2(9)c of the Iowa Administrative Code has approved the request from Yaggy Colby Associates for a variance from Iowa Wastewater Facilities Design Standards 14.5.2.2.3 which pertains to reliability requirements for sizing of final clarifiers. Under this variance each of the two proposed final clarifiers can be designed based on 50% of the total design loading to that unit operation in lieu of the 75% total design loading required by our design standards.**

**The engineering justification submitted substantially demonstrates that this variance will result in at least equivalent effectiveness while significantly reducing costs.**

Sincerely,

DARREL MCALLISTER  
BUREAU CHIEF  
WATER QUALITY BUREAU

(fme191.bp)

cc: Yaggy Colby Associates, Mason City, IA  
Field Office No. 2

*MS*  
*City of Osage*

## VARIANCE REQUEST

Iowa Department of Natural Resources

9-11-06

1. Date: *March 24, 1998*  
2. Review Engineer: *Fred Evans*  
3. Date Received: *2/2/98, 5/6/98 and 5/27/98*  
4. County Number: *66*  
6. Program Area: *CP (Wastewater)*  
7. Facility Type: *C05*  
8. Subject Area: *321*  
9. Rule Reference: *567-64.2(9)a*  
10. Design Stds Ref: *14.5.2.2.3*  
11. Consulting Engr: *Yaggy Colby Associates*  
12. Variance Rule: *567-64.2(9)c*

13. Decision: *Approved*  
Date: *7/2/98*  
14. Appeal:  
Date:

### 15. Description of Variance Request

The City of Osage is in the process of upgrading their wastewater treatment plant by the addition of an oxidation ditch system. The proposed system will consist of two ditches and two final clarifiers meeting all applicable Iowa Design Standards with the possible exception of final clarifier sizing.

It has been determined that the treatment facility is a Class I facility with respect to reliability criteria. It has also been determined that the unit process reliability falls under Class B. As such, the Iowa Standards require that each final clarifier be sized to handle 75% of the design flow.

Yaggy Colby Associates is submitting this request for a variance from Iowa Design Standard 14.5.2.2.3 regarding the need for 75% flow capacity for final clarifiers on behalf of the City of Osage for wastewater treatment plant improvements presently being designed.

### 16. Consulting Engineer's Justifications

1. The Osage treatment facility includes a large polishing pond preceding disinfection. This pond has a total volume of 1.91 million gallons and provides a significant hydraulic retention time regardless of the flow experienced. This polishing pond is currently an integral portion of the treatment process and will continue to be an integral part of the

2, Yaggy Colby Associates wishes to take advantage of this polishing pond and the related hydraulic retention provide by such. The firm is proposing that each one of the two proposed final clarifier be designed based on 50% of the design flow rather than the 75% set forth in the Iowa Standards. It is the firm's opinion that a significant cost savings could be realized by the City of Osage should this variance be granted and the environment would be not subjected to any additional risk due to a wash out of a clarifier.

3, Here is some information on serpentine wiers to cut down weir loading rates and some information on stamford baffles. I couldn't find much on stamford baffles, but they are being used around the country and there are several "clarifier optimizing" companies that use them as well as other items to get better performance.

We would strongly consider both in Osage if allowed to use the 50% PHWW clarifier loading criteria for design.

17. Department's Justifications *Approval is recommended.*

- 1. Rock excavation will be required for new final clarifiers.*
- 2. The proposed 38 ft diameter final clarifiers will each provide 75% reliability for PHWW flows of 1.512 MGD. For any PHWW flows in excess of 1.512 MGD, when only a single final clarifier is in operation, the additional solids removal through the existing 1.91 MG polishing pond should provide for treatment equivalent or better than reliability requirements.*
- 3. In a telephone conversation of 6/9/98 the designing engineer advised that Stamford baffles will be included in the design of the final clarifiers to increase solids removal.*

18. Precedents Used

*Iowa Falls - Denied. It was proposed to use two existing final clarifiers in the upgrading of the WWT. The smaller of the two final clarifiers would only provide 75% reliability.*



TERRY E. BRANSTAD, GOVERNOR

DEPARTMENT OF NATURAL RESOURCES

LARRY J. WILSON, DIRECTOR

July 10, 1998

City of Osage  
806 Main  
P.O. Box 29  
Osage, IA 50461

SUBJECT: Variance Request for Final Clarification Sizing  
Wastewater Treatment Facility Improvements  
Osage, Iowa

The Iowa Department of Natural Resources in accordance with subrule 567--64.2(9)c of the Iowa Administrative Code has approved the request from Yaggy Colby Associates for a variance from Iowa Wastewater Facilities Design Standards 14.5.2.2.3 which pertains to reliability requirements for sizing of final clarifiers. Under this variance each of the two proposed final clarifiers can be designed based on 50% of the total design loading to that unit operation in lieu of the 75% total design loading required by our design standards.

The engineering justification submitted substantially demonstrates that this variance will result in at least equivalent effectiveness while significantly reducing costs.

Sincerely,

DARREL MCALLISTER  
BUREAU CHIEF  
WATER QUALITY BUREAU

(fme191.bp)

cc: Yaggy Colby Associates, Mason City, IA  
Field Office No. 2

City of Osage

**VARIANCE REQUEST**  
Iowa Department of Natural Resources

1. Date: *March 24, 1998*  
2. Review Engineer: *Fred Evans*  
3. Date Received: *2/2/98, 5/6/98 and 5/27/98*  
4. County Number: *66*  
5. Program Area: *CP (Wastewater)*  
6. Facility Type: *C05*  
7. Subject Area: *321*  
8. Rule Reference: *567-64.2(9)a*  
9. Design Stds Ref: *14.5.2.2.3*  
10. Consulting Engr: *Yaggy Colby Associates*  
11. Variance Rule: *567-64.2(9)c*

13. Decision: *Approved*  
Date: *7/2/98*

14. Appeal:  
Date:

**15. Description of Variance Request**

The City of Osage is in the process of upgrading their wastewater treatment plant by the addition of an oxidation ditch system. The proposed system will consist of two ditches and two final clarifiers meeting all applicable Iowa Design Standards with the possible exception of final clarifier sizing.

It has been determined that the treatment facility is a Class I facility with respect to reliability criteria. It has also been determined that the unit process reliability falls under Class B. As such, the Iowa Standards require that each final clarifier be sized to handle 75% of the design flow.

Yaggy Colby Associates is submitting this request for a variance from Iowa Design Standard 14.5.2.2.3 regarding the need for 75% flow capacity for final clarifiers on behalf of the City of Osage for wastewater treatment plant improvements presently being designed.

**16. Consulting Engineer's Justifications**

1. The Osage treatment facility includes a large polishing pond preceding disinfection. This pond has a total volume of 1.91 million gallons and provides a significant hydraulic retention time regardless of the flow experienced. This polishing pond is currently an integral portion of the treatment process and will continue to be an integral part of the proposed facility. Clarifier effluent will pass through the polishing pond prior to chlorination and ultimate discharge to the receiving stream.



2, Yaggy Colby Associates wishes to take advantage of this polishing pond and the related hydraulic retention provide by such. The firm is proposing that each one of the two proposed final clarifier be designed based on 50% of the design flow rather than the 75% set forth in the Iowa Standards. It is the firm's opinion that a significant cost savings could be realized by the City of Osage should this variance be granted and the environment would be not subjected to any additional risk due to a wash out of a clarifier.

3, Here is some information on serpentine wiers to cut down weir loading rates and some information on stamford baffles. I couldn't find much on stamford baffles, but they are being used around the country and there are several "clarifier optimizing" companies that use them as well as other items to get better performance.

We would strongly consider both in Osage if allowed to use the 50% PHWW clarifier loading criteria for design.

17. Department's Justifications *Approval is recommended.*

1. *Rock excavation will be required for new final clarifiers*
2. *The proposed 38 ft diameter final clarifiers will each provide 75% reliability for PHWW flows of 1.512 MGD. For any PHWW flows in excess of 1.512 MGD, when only a single final clarifier is in operation, the additional solids removal through the existing 1.91 MG polishing pond should provide for treatment equivalent or better than reliability requirements.*
3. *In a telephone conversation of 6/9/98 the designing engineer advised that Stamford baffles will be included in the design of the final clarifiers to increase solids removal.*

18. Precedents Used

*Iowa Falls - Denied. It was proposed to use two existing final clarifiers in the upgrading of the WWTP. The smaller of the two final clarifiers would only provide 36.6% reliability and there is no polishing pond following the final clarifiers.*

19. Staff Reviewer: *[Signature]*  
20. Supervisor: Wayne Farrand *[Signature]*  
21. Authorized by: Darrell McAllister *[Signature]*

Date: *6/12/98*  
Date: *7/2/98*  
Date: *7/2/98*





**YAGGY  
COLBY**  
ASSOCIATES

LANDSCAPE ARCHITECTS

PLANNERS

January 30, 1998

Mr. Wayne Farrand  
Iowa Department of Natural Resources  
Wastewater Section  
Wallace State Office Building  
900 East Grand  
Des Moines, Iowa 50319

RE: Variance Request for Final Clarification Sizing  
Wastewater Treatment Facility Improvements  
Osage, Iowa

Dear Mr. Farrand:

Yaggy Colby Associates is submitting this request for a variance from Iowa Design Standard 14.5.2.2.3 regarding the need for 75% flow capacity for final clarifiers on behalf of the City of Osage for wastewater treatment plant improvements presently being designed.

The City of Osage is in the process of upgrading their wastewater treatment plant by the addition of an oxidation ditch system. The proposed system will consist of two ditches and two final clarifiers meeting all applicable Iowa Design Standards with the possible exception of final clarifier sizing.

MASON CITY OFFICE:

215 North Adams

Mason City, IA 50401

515-424-6344

Fax 515-424-0351

It has been determined that the treatment facility is a Class I facility with respect to reliability criteria. It has also been determined that the unit process reliability falls under Class B. As such, the Iowa Standards require that each final clarifier be sized to handle 75% of the design flow.

The Osage treatment facility includes a large polishing pond preceding disinfection. This pond has a total volume of 1.91 million gallons and provides a significant hydraulic retention time regardless of the flow experienced. This polishing pond is currently an integral portion of the treatment process and will continue to be an integral part of the proposed facility. Clarifier effluent will pass through the polishing pond prior to chlorination and ultimate discharge to the receiving stream.

ROCHESTER OFFICE:

507-288-6464

Fax 507-288-5058

Yaggy Colby Associates wishes to take advantage of this polishing pond and the related hydraulic retention provide by such. The firm is proposing that each one of the two proposed final clarifier be designed based on 50% of the design flow rather than the 75% set forth in the Iowa Standards. It is the firm's opinion that a significant cost savings could be realized by the City of Osage should this variance be granted and the environment would be not subjected to any additional risk due to a wash out of a clarifier.


Mr. Wayne Farrand  
Iowa Department of Natural Resources  
January 30, 1998

Page 2

Yaggy Colby Associates and the City of Osage greatly appreciate your consideration of this variance request. Please call if you have any questions or require additional information pertaining to this matter.

Sincerely,

YAGGY COLBY ASSOCIATES

A handwritten signature in black ink, appearing to read "Craig R. Olson", is written over the printed name and title.

Craig R. Olson, P.E.  
Project Manager

cc: Mr. Jerry Dunlay, Director of Public Works, Osage  
Mr. Al Tompkins, IDNR, Mason City

CRO/jmw-5812dn\_3.doc



Reliability % provided by final clarifiers

Proposed diameter of 38',  $A = 1134 \text{ ft}^2$   
PHWW flow = 2.163 MGD

Maximum loading to clarifier @ 1000 gpd/ft<sup>2</sup>  
 $1134 \times 1000 = \underline{1.134 \text{ MGD}}$

% of Design PHWW flow

$$1.134 \div 2.163 = 0.52 = \underline{52\%}$$

Check PHWW flow which could be handled  
by a single final clarifier at a PHWW  
flow of 1000 gpd/ft<sup>2</sup>

$$\text{Flow} = 1134 \times 1000 = \underline{1.134 \text{ MGD}}$$

For 75% of PHWW

$$1.134 \div 0.75 = \underline{1.512 \text{ MGD}}$$

From flow chart submitted the  
wettest hour determined by the  
engineer from past plant records  
was approximately 1.5 MGD in  
May 1996





FIGURE #4  
 OSAGE W.W.T.F.  
 ALTERNATE #3





FIGURE #1  
OSAGE W.W.T.F.  
EXISTING FACILITIES





# YAGGY COLBY ASSOCIATES

ENGINEERS • ARCHITECTS • SURVEYORS • PLANNERS  
LANDSCAPE ARCHITECTS  
215 NORTH ADAMS  
MASON CITY, IOWA 50401

## FACSIMILE TRANSMITTAL HEADER SHEET

NAME	OFFICE SYMBOL	OFFICE NO.	FAX NO.		
FROM:	Yaggy Colby Assoc	(515)	(515)		
<b>Craig Olson</b>		<b>424-6344</b>	<b>424-0351</b>		
TO:	IDNR	515	515		
<b>Fred Evans</b>		<b>281-8885</b>	<b>281-8895</b>		
Wed May 6, 1998 3:58PM	NO. PAGES (including header)	7	Unclass	ASAP	

Fred,

Here is the much awaited information on Osage. Sorry it took so long. I guess we really wanted it to be right this time. For a change it seems like we have too much data. Nice problem.

I will be sending a letter to Ralph T. (I've already left him a voice mail message) that we will be revising the MWW and PHWW flows. The MWW of 1.3 MGD has a pretty decent basis in the existing flow data plus projected growth. The PHWW flow likewise is firmly rooted in the flow data. The attached circular chart shows our wettest hour we could find (approx. 1.5 MGD). By adding peaked growth to that number, we come up with the 2.163 MGD figure.

These numbers should be good. Fortunately, the primary design numbers for ADW and AWW have not changed at all.

The new PHWW flow changes the final clarifier diameters to:

38 feet to meet the 50% criteria, and;

46 feet to meet the 75% criteria. This is down from 40 and 50 respectively.

Regardless of clarifier diameter the basis of the variance requested is still valid, although the volume difference and corresponding cost difference of rock requiring excavation has been reduced somewhat.

If you have any further questions, please give me a call.

Craig

**CONSTRUCTION PERMIT APPLICATION**  
**SCHEDULE G, Treatment Project Design Data**

<b>DATE PREPARED</b> 4/28/98	<b>PROJECT IDENTITY</b>  City of Osage, Iowa Wastewater Treatment Facility Improvements	<b>DNR USE</b>
<b>DATE REVISED</b> 5/20/98		<b>PROJECT NO.</b>
		<b>PERMIT NO.</b>

1. Project Description: Conversion to oxidation ditch system with expanded sludge storage.

2. Design Basis:

Plant Design Loading		Present			Design Year (2020)		
		ADW	AWW	MWW	ADW	AWW	MWW
Residential Waste	Population	3439			3783		
	Flow, MGD	0.205	0.205	0.205	0.239	0.239	0.239
	BOD5, #/day	1191.0	1191.0	1191.0	1391	1391	1391
	TKN, #/day	71.0	71.0	71.0	82.9	82.9	82.9
Out of Town Students	Number	0			0		
	Flow, MGD	0	0	0	0	0	0
	BOD5, #/day	0	0	0	0	0	0
	TKN, #/day	0	0	0	0	0	0
Industrial	Flow, MGD	0.146	0.146	0.146	0.278	0.278	0.278
	Rated Flow, MGD	0.162	0.162	0.162	0.324	0.324	0.324
	BOD5, #/day	425	425	425	809	809	809
	TKN, #/day	8	8	8	15	15	15
Other (specify)	Flow, MGD	0	0	0	0	0	0
	Rated Flow, MGD	0	0	0	0	0	0
	BOD5, #/day	0	0	0	0	0	0
	TKN, #/day	0	0	0	0	0	0
Infiltration, MGD		0	0.229	0.466	0	0.233	0.843
Inflow, MGD		0	0	0	0	0	0
Total	Flow, MGD	0.351	0.580	0.817	0.517	0.750	1.360
	Rated Flow, MGD	0.367	0.596	0.833	0.563	0.796	1.406
	BOD5, mg/l	552	334	237	510	352	194
	BOD5, #/day	1616	1616	1616	2200	2200	2200
	TKN, mg/l	27	16	12	40	21	19
	TKN, #/day	79.0	79.0	79.0	98.1	98.1	98.1

Infiltration #'s derived from observed flow data - Industrial flow

3. Peak hourly Dry Weather Flow      1.320      MGD + Peak Hourly Infiltration      0.843      MGD + Peak Hourly Inflow      0.000      MGD = Total Peak Hourly Wet Weather Flow:      2.163      MGD (in design year 2020)

4. Identify effluent limitations:		BOD5/day		Suspended Solids		NH3-N			
		Ave	Max	Ave	Max	Ave	Max		
Operation Permit	mg/l	25	40	30	45				
Effluent Limits	#/day	157	252	189	283				
Design Effluent**	mg/l	25	40	30	45				
Quality	#/day	157	252	189	283				


\*\* Assume secondary standards pending new wastewater allocation.

5. Identify significant industrial/commercial contributors:

Waste Contributors	Pretreatment	Operation		Design Loadings				
				Flow (MGD)		BOD5	SS	TKN
		hrs/day	days/week	Total	Rated	(#/day)	(#/day)	(#/day)
A-Z Drying North	No	24		0.02	0.02	100	100	
A-Z Drying South	No	24		0.08	0.08	340	475	
Fox River Mills	No	24		0.155	0.155	350	200	
Floyd - Mitchell	No	8		0.023	0.069	19	20	8



PHWW



The drops  
like on Monday  
between 6 pm & 8 pm  
are from re filling  
the digester. And also  
on Friday from 4 pm to 6 pm  
chris