

Appendix D-2: DNR's NOx Control Cost Estimates Review

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

Utility ▼

What type of fuel does the unit burn?

Coal ▼

Is the SCR for a new boiler or retrofit of an existing boiler?

Retrofit ▼

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.

1

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

811.9 MW

What is the higher heating value (HHV) of the fuel?

8,597 Btu/lb

What is the estimated actual annual MWhs output?

4,224,041 MWhs

Enter the net plant heat input rate (NPHR)

9.678 MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation

581 Feet above sea level

Provide the following information for coal-fired boilers:

Type of coal burned:

Sub-Bituminous ▼

Enter the sulfur content (%S) =

0.24 percent by weight

For units burning coal blends:

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

- Method 1
- Method 2
- Not applicable

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates (t_{SCR})	365 days
Number of days the boiler operates (t_{plant})	365 days
Inlet NO_x Emissions ($NO_{x,in}$) to SCR	0.184 lb/MMBtu
Outlet NO_x Emissions ($NO_{x,out}$) from SCR	0.05 lb/MMBtu
Stoichiometric Ratio Factor (SRF)	1.050

*The SRF value of 1.05 is a default value. User should enter actual value, if known.

Estimated operating life of the catalyst ($H_{catalyst}$)	24,000 hours
Estimated SCR equipment life	30 Years*

* For utility boilers, the typical equipment life of an SCR is at least 30 years.

Concentration of reagent as stored (C_{stored})	29 percent*
Density of reagent as stored (ρ_{stored})	56 lb/cubic feet*
Number of days reagent is stored ($t_{storage}$)	14 days

*The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.

Select the reagent used

Number of SCR reactor chambers (n_{scr})	1
Number of catalyst layers (R_{layer})	3
Number of empty catalyst layers (R_{empty})	1
Ammonia Slip (Slip) provided by vendor	5 ppm
Volume of the catalyst layers ($Vol_{catalyst}$) (Enter "UNK" if value is not known)	UNK Cubic feet
Flue gas flow rate ($Q_{fluegas}$) (Enter "UNK" if value is not known)	UNK acfm

Gas temperature at the SCR inlet (T)	750 °F
Base case fuel gas volumetric flow rate factor (Q_{fuel})	516 ft ³ /min-MMBtu/hour

Densities of typical SCR reagents:	
50% urea solution	71 lbs/ft ³
29.4% aqueous NH ₃	56 lbs/ft ³

Enter the cost data for the proposed SCR:

Desired dollar-year	2019		
CEPCI for 2019	607.5	541.7	2016 CEPCI
Annual Interest Rate (i)	7.862 Percent		
Reagent (Cost _{reag})	0.293 \$/gallon for 29% ammonia*		
Electricity (Cost _{elect})	0.0660 \$/kWh		
Catalyst cost (CC _{replace})	\$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)	227.00	
Operator Labor Rate	60.00 \$/hour (including benefits)*		
Operator Hours/Day	4.00 hours/day*		

CEPCI = Chemical Engineering Plant Cost Index

* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.

* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.

* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.

* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =
 Administrative Charges Factor (ACF) =

0.005
0.03

Data Sources for Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 (https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf)	
Electricity Cost (\$/kWh)	0.0361	U.S. Energy Information Administration. Electric Power Annual 2016. Table 8.4. Published December 2017. Available at: https://www.eia.gov/electricity/annual/pdf/epa.pdf .	2019 EIA data-0.0660 \$/kWh
Percent sulfur content for Coal (% weight)	0.41	Average sulfur content based on U.S. coal data for 2016 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	Site Specific Sulfur Content-0.24%
Higher Heating Value (HHV) (Btu/lb)	8,826	2016 coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	Site Specific Coal HH Value-8597 BTU/lb
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6 .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6 .	
Interest Rate (Percent)	5.5	Default bank prime rate	Firm Specific Rate-7.862%

SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate (Q_B) =	$B_{mw} \times NPHR =$	7,857	MMBtu/hour
Maximum Annual MW Output (B_{mw}) =	$B_{mw} \times 8760 =$	7,112,244	MWhs
Estimated Actual Annual MWs Output (Boutput) =		4,224,041	MWhs
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.97	
Total System Capacity Factor (CF_{total}) =	$(B_{output}/B_{mw}) \times (t_{scr}/t_{plant}) =$	0.594	fraction
Total operating time for the SCR (t_{op}) =	$CF_{total} \times 8760 =$	5203	hours
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	72.8	percent
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_B =$	1052.88	lb/hour
Total NO _x removed per year =	$(NO_{x_{in}} \times EF \times Q_B \times t_{op})/2000 =$	2,738.89	tons/year
NO _x removal factor (NRF) =	$EF/80 =$	0.91	
Volumetric flue gas flow rate ($q_{flue\ gas}$) =	$Q_{fuel} \times Q_B \times (460 + T)/(460 + 700)n_{scr} =$	4,229,137	acfm
Space velocity (V_{space}) =	$q_{flue\ gas}/Vol_{catalyst} =$	195.16	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05	
SO ₂ Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$	< 3	lbs/MMBtu
Elevation Factor (ELEV) =	$14.7\ psia/P =$	1.02	
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7] / 518.6^{5.256} \times (1/144)^* =$	14.4	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.00	

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(\text{interest rate}) / (1 / ((1 + \text{interest rate})^Y - 1))$, where $Y = H_{\text{catalysts}} / (t_{\text{SCR}} \times 24 \text{ hours})$ rounded to the nearest integer	0.3084	Fraction
Catalyst volume ($\text{Vol}_{\text{catalyst}}$) =	$2.81 \times Q_B \times EF_{\text{adj}} \times \text{Slip}_{\text{adj}} \times \text{NOx}_{\text{adj}} \times S_{\text{adj}} \times (T_{\text{adj}} / N_{\text{scr}})$	21,670.53	Cubic feet
Cross sectional area of the catalyst (A_{catalyst}) =	$Q_{\text{flue gas}} / (16 \text{ ft/sec} \times 60 \text{ sec/min})$	4,405	ft ²
Height of each catalyst layer (H_{layer}) =	$(\text{Vol}_{\text{catalyst}} / (R_{\text{layer}} \times A_{\text{catalyst}})) + 1$ (rounded to next highest integer)	3	feet

SCR Reactor Data:

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor (A_{SCR}) =	$1.15 \times A_{\text{catalyst}}$	5,066	ft ²
Reactor length and width dimensions for a square reactor =	$(A_{\text{SCR}})^{0.5}$	71.2	feet
Reactor height =	$(R_{\text{layer}} + R_{\text{empty}}) \times (7 \text{ ft} + h_{\text{layer}}) + 9 \text{ ft}$	48	feet

Reagent Data:

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/ft ³

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m_{reagent}) =	$(\text{NOx}_{\text{in}} \times Q_B \times EF \times \text{SRF} \times \text{MW}_R) / \text{MW}_{\text{NOx}}$	409	lb/hour
Reagent Usage Rate (m_{sol}) =	$m_{\text{reagent}} / \text{Csol} =$	1,411	lb/hour
	$(m_{\text{sol}} \times 7.4805) / \text{Reagent Density}$	188	gal/hour
Estimated tank volume for reagent storage =	$(m_{\text{sol}} \times 7.4805 \times t_{\text{storage}} \times 24) / \text{Reagent Density} =$	63,400	gallons (storage needed to store a 14 day reagent supply rounded to

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1 + i)^n / (1 + i)^n - 1 =$ Where n = Equipment Life and i = Interest Rate	0.0877

Other parameters	Equation	Calculated Value	Units
Electricity Usage: Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = Bmw for utility boilers	4578.09	kW

Cost Estimate

Total Capital Investment (TCI)

TCI for Coal-Fired Boilers

For Coal-Fired Boilers:

$$TCI = 1.3 \times (SCR_{cost} + RPC + APHC + BPC)$$

Capital costs for the SCR (SCR_{cost}) =	\$167,872,642	in 2019 dollars
Reagent Preparation Cost (RPC) =	\$3,602,976	in 2019 dollars
Air Pre-Heater Costs (APHC)* =	\$0	in 2019 dollars
Balance of Plant Costs (BPC) =	\$10,162,546	in 2019 dollars
Total Capital Investment (TCI) =	\$236,129,614	in 2019 dollars

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 3lb/MMBtu of sulfur dioxide.

SCR Capital Costs (SCR_{cost})

For Coal-Fired Utility Boilers >25 MW:

$$SCR_{cost} = 310,000 \times (NRF)^{0.2} \times (B_{MW} \times HRF \times CoalF)^{0.92} \times ELEVF \times RF$$

For Coal-Fired Industrial Boilers >250 MMBtu/hour:

$$SCR_{cost} = 310,000 \times (NRF)^{0.2} \times (0.1 \times Q_B \times CoalF)^{0.92} \times ELEVF \times RF$$

SCR Capital Costs (SCR_{cost}) =

\$167,872,642 in 2019 dollars

Reagent Preparation Costs (RPC)

For Coal-Fired Utility Boilers >25 MW:

$$RPC = 564,000 \times (NO_{x,in} \times B_{MW} \times NPHR \times EF)^{0.25} \times RF$$

For Coal-Fired Industrial Boilers >250 MMBtu/hour:

$$RPC = 564,000 \times (NO_{x,in} \times Q_B \times EF)^{0.25} \times RF$$

Reagent Preparation Costs (RPC) =

\$3,602,976 in 2019 dollars

Air Pre-Heater Costs (APHC)*

For Coal-Fired Utility Boilers >25MW:

$$APHC = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

For Coal-Fired Industrial Boilers >250 MMBtu/hour:

$$APHC = 69,000 \times (0.1 \times Q_B \times CoalF)^{0.78} \times AHF \times RF$$

Air Pre-Heater Costs (APH_{cost}) =

\$0 in 2019 dollars

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

Balance of Plant Costs (BPC)

For Coal-Fired Utility Boilers >25MW:

$$BPC = 529,000 \times (B_{MW} \times HRF \times CoalF)^{0.42} \times ELEVF \times RF$$

For Coal-Fired Industrial Boilers >250 MMBtu/hour:

$$BPC = 529,000 \times (0.1 \times Q_B \times CoalF)^{0.42} \times ELEVF \times RF$$

Balance of Plant Costs (BOP_{cost}) =

\$10,162,546 in 2019 dollars

Annual Costs

Total Annual Cost (TAC)

$$\text{TAC} = \text{Direct Annual Costs} + \text{Indirect Annual Costs}$$

Direct Annual Costs (DAC) =	\$3,545,430 in 2019 dollars
Indirect Annual Costs (IDAC) =	\$20,725,363 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC	\$24,270,793 in 2019 dollars

Direct Annual Costs (DAC)

$$\text{DAC} = (\text{Annual Maintenance Cost}) + (\text{Annual Reagent Cost}) + (\text{Annual Electricity Cost}) + (\text{Annual Catalyst Cost})$$

Annual Maintenance Cost =	0.005 x TCI =	\$1,180,648 in 2019 dollars
Annual Reagent Cost =	$m_{\text{sol}} \times \text{Cost}_{\text{reag}} \times t_{\text{op}} =$	\$287,322 in 2019 dollars
Annual Electricity Cost =	$P \times \text{Cost}_{\text{elect}} \times t_{\text{op}} =$	\$1,571,765 in 2019 dollars
Annual Catalyst Replacement Cost =		\$505,695 in 2019 dollars

For coal-fired boilers, the following methods may be used to calculate the catalyst replacement cost.

Method 1 (for all fuel types):	$n_{\text{scr}} \times \text{Vol}_{\text{cat}} \times (\text{CC}_{\text{replace}} / R_{\text{layer}}) \times \text{FWF}$	* Calculation Method 1 selected.
Method 2 (for coal-fired utility boilers):	$B_{\text{MW}} \times 0.4 \times (\text{CoalF})^{2.9} \times (\text{NRF})^{0.71} \times (\text{CC}_{\text{replace}}) \times 35.3$	
Direct Annual Cost =		\$3,545,430 in 2019 dollars

Indirect Annual Cost (IDAC)

$$\text{IDAC} = \text{Administrative Charges} + \text{Capital Recovery Costs}$$

Administrative Charges (AC) =	0.03 x (Operator Cost + 0.4 x Annual Maintenance Cost) =	\$16,796 in 2019 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$20,708,567 in 2019 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$20,725,363 in 2019 dollars

Cost Effectiveness

$$\text{Cost Effectiveness} = \text{Total Annual Cost} / \text{NOx Removed/year}$$

Total Annual Cost (TAC) =	\$24,270,793 per year in 2019 dollars
NOx Removed =	2,739 tons/year
Cost Effectiveness =	\$8,862 per ton of NOx removed in 2019 dollars

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

Utility

What type of fuel does the unit burn?

Coal

Is the SNCR for a new boiler or retrofit of an existing boiler?

Retrofit

Please enter a retrofit factor equal to or greater than 0.84 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.

1

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

811.9 MW

What is the higher heating value (HHV) of the fuel?

8,597 Btu/lb

What is the estimated actual annual MWh output?

4,224,041 MWh

Is the boiler a fluid-bed boiler?

No

Enter the net plant heat input rate (NPHR)

9.6777 MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Provide the following information for coal-fired boilers:

Type of coal burned:

Sub-Bituminous

Enter the sulfur content (%S) =

0.24 percent by weight

or

Select the appropriate SO₂ emission rate:

Not Applicable

Ash content (%Ash):

5.84 percent by weight

**The ash content of 5.84% is a default value. See below for data source. Enter actual value, if known.*

For units burning coal blends:

Note: The table below is pre-populated with default values for HHV, %S, %Ash and cost. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

	Fraction in Coal Blend	%S	%Ash	HHV (Btu/lb)	Fuel Cost (\$/MMBtu)
Bituminous	0	1.84	9.23	11,841	2.4
Sub-Bituminous	0	0.41	5.84	8,826	1.89
Lignite	0	0.82	13.6	6,626	1.74

Please click the calculate button to calculate weighted values based on the data in the table above.

Enter the following design parameters for the proposed SNCR:

Number of days the SNCR operates (t_{SNCR})	365 days	default 155	Plant Elevation	581 Feet above sea level						
Inlet NO_x Emissions ($NO_{x,in}$) to SNCR	0.184 lb/MMBtu									
Outlet NO_x Emissions ($NO_{x,out}$) from SNCR	0.1564 lb/MMBtu									
Estimated Normalized Stoichiometric Ratio (NSR)	1.22		*The NSR for a urea system may be calculated using equation 1.17 in Section 4, Chapter 1 of the Air Pollution Control Cost Manual (as updated March 2019).							
Concentration of reagent as stored (C_{stored})	50 Percent	<table border="1"> <tr> <th colspan="2">Densities of typical SNCR reagents:</th> </tr> <tr> <td>50% urea solution</td> <td>71 lbs/ft³</td> </tr> <tr> <td>29.4% aqueous NH₃</td> <td>56 lbs/ft³</td> </tr> </table>			Densities of typical SNCR reagents:		50% urea solution	71 lbs/ft ³	29.4% aqueous NH ₃	56 lbs/ft ³
Densities of typical SNCR reagents:										
50% urea solution	71 lbs/ft ³									
29.4% aqueous NH ₃	56 lbs/ft ³									
Density of reagent as stored (ρ_{stored})	71 lb/ft ³									
Concentration of reagent injected (C_{inj})	50 percent									
Number of days reagent is stored ($t_{storage}$)	14 days									
Estimated equipment life	20 Years									
Select the reagent used	Urea									

Enter the cost data for the proposed SNCR:

Desired dollar-year	2019			
CEPCI for 2019	607.5 Enter the CEPCI value for 2019	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	7.862 Percent			
Fuel ($Cost_{fuel}$)	1.89 \$/MMBtu*			
Reagent ($Cost_{reag}$)	1.66 \$/gallon for a 50 percent solution of urea*			
Water ($Cost_{water}$)	0.0042 \$/gallon*			
Electricity ($Cost_{elect}$)	0.0660 \$/kWh			
Ash Disposal (for coal-fired boilers only) ($Cost_{ash}$)	48.80 \$/ton*			

* The values marked are default values. See the table below for the default values used and their references. Enter actual values, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.015
Administrative Charges Factor (ACF) =	0.03

Data Sources for Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$1.66/gallon of 50% urea solution	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6, Using the Integrated Planning Model, Updates to the Cost and Performance for APC Technologies, SNCR Cost Development Methodology, Chapter 5, Attachment 5-4, January 2017. Available at: https://www.epa.gov/sites/production/files/2018-05/documents/attachment_5-4_sncr_cost_development_methodology.pdf .	
Water Cost (\$/gallon)	0.00417	Average water rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf .	
Electricity Cost (\$/kWh)	0.0361	U.S. Energy Information Administration. Electric Power Annual 2016. Table 8.4. Published December 2017. Available at: https://www.eia.gov/electricity/annual/pdf/epa.pdf .	2019 EIA data-0.0660 \$/kWh
Fuel Cost (\$/MMBtu)	1.89	U.S. Energy Information Administration. Electric Power Annual 2016. Table 7.4. Published December 2017. Available at: https://www.eia.gov/electricity/annual/pdf/epa.pdf .	
Ash Disposal Cost (\$/ton)	48.8	Waste Business Journal. The Cost to Landfill MSW Continues to Rise Despite Soft Demand. July 11, 2017. Available at: http://www.wastebusinessjournal.com/news/wbj20170711A.htm .	
Percent sulfur content for Coal (% weight)	0.41	Average sulfur content based on U.S. coal data for 2016 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	Site Specific Sulfur Content-0.24%
Percent ash content for Coal (% weight)	5.84	Average ash content based on U.S. coal data for 2016 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	
Higher Heating Value (HHV) (Btu/lb)	8,826	2016 coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	Site Specific Coal HH Value-8597 BTU/lb
Interest Rate (%)	5.5	Default bank prime rate	Firm Specific Rate-7.862%

SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate (Q_B) =	$B_{mw} \times NPHR =$	7,857	MMBtu/hour
Maximum Annual MWh Output =	$B_{mw} \times 8760 =$	7,112,244	MWh
Estimated Actual Annual MWh Output (Boutput) =		4,224,041	MWh
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.97	
Total System Capacity Factor (CF_{total}) =	$(Boutput/B_{mw}) \times (tsnrcr/365) =$	0.59	fraction
Total operating time for the SNCR (t_{op}) =	$CF_{total} \times 8760 =$	5203	hours
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	15	percent
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_B =$	216.86	lb/hour
Total NO _x removed per year =	$(NO_{x_{in}} \times EF \times Q_B \times t_{op})/2000 =$	564.13	tons/year
Coal Factor (Coal _f) =	1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05	
SO ₂ Emission rate =	$(\%S/100) \times (64/32) \times (1 \times 10^6)/HHV =$	< 3	lbs/MMBtu
Elevation Factor (ELEV _F) =	14.7 psia/P =	1.02	
Atmospheric pressure at 581 feet above sea level (P) =	$2116 \times [(59 - (0.00356 \times h) + 459.7)/518.6]^{5.256} \times (1/144) * =$	14.4	psia
Retrofit Factor (RF) =	Retrofit to existing boiler	1.00	

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html>.

Reagent Data:

Type of reagent used

Urea

Molecular Weight of Reagent (MW) =

60.06 g/mole

Density =

71 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m_{reagent}) =	$(\text{NO}_{x,\text{in}} \times Q_{\text{B}} \times \text{NSR} \times \text{MW}_{\text{R}}) / (\text{MW}_{\text{NO}_x} \times \text{SR}) =$ (whre SR = 1 for NH_3 ; 2 for Urea)	1151	lb/hour
Reagent Usage Rate (m_{sol}) =	$m_{\text{reagent}} / C_{\text{sol}} =$	2,302	lb/hour
	$(m_{\text{sol}} \times 7.4805) / \text{Reagent Density} =$	242.6	gal/hour
Estimated tank volume for reagent storage =	$(m_{\text{sol}} \times 7.4805 \times t_{\text{storage}} \times 24 \text{ hours/day}) / \text{Reagent Density} =$	81,600	gallons (storage needed to store a 14 day reagent supply rounded up to the nearest 100 gallons)

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i = Interest Rate	0.1008

Parameter	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$(0.47 \times \text{NO}_{x,\text{in}} \times \text{NSR} \times Q_{\text{B}}) / \text{NPHR} =$	85.7	kW/hour
Water Usage:			
Water consumption (q_{w}) =	$(m_{\text{sol}} / \text{Density of water}) \times ((C_{\text{stored}} / C_{\text{inj}}) - 1) =$	0	gallons/hour
Fuel Data:			
Additional Fuel required to evaporate water in injected reagent (ΔFuel) =	$H_v \times m_{\text{reagent}} \times ((1/C_{\text{inj}}) - 1) =$	1.04	MMBtu/hour
Ash Disposal:			
Additional ash produced due to increased fuel consumption (Δash) =	$(\Delta\text{fuel} \times \% \text{Ash} \times 1 \times 10^6) / \text{HHV} =$	7.0	lb/hour

Cost Estimate

Total Capital Investment (TCI)

For Coal-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$$

For Fuel Oil and Natural Gas-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$$

Capital costs for the SNCR ($SNCR_{cost}$) =	\$4,347,697 in 2019 dollars
Air Pre-Heater Costs (APH_{cost})* =	\$0 in 2019 dollars
Balance of Plant Costs (BOP_{cost}) =	\$6,243,316 in 2019 dollars
Total Capital Investment (TCI) =	\$13,768,317 in 2019 dollars

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide.

SNCR Capital Costs ($SNCR_{cost}$)

For Coal-Fired Utility Boilers:

$$SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times \text{CoalF} \times \text{BTF} \times \text{ELEV} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times \text{ELEV} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times \text{CoalF} \times \text{BTF} \times \text{ELEV} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$SNCR_{cost} = 147,000 \times ((Q_B/NPHR) \times HRF)^{0.42} \times \text{ELEV} \times \text{RF}$$

SNCR Capital Costs ($SNCR_{cost}$) =	\$4,347,697 in 2019 dollars
--	-----------------------------

Air Pre-Heater Costs (APH_{cost})*

For Coal-Fired Utility Boilers:

$$APH_{cost} = 69,000 \times (B_{MW} \times HRF \times \text{CoalF})^{0.78} \times \text{AHF} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times \text{CoalF})^{0.78} \times \text{AHF} \times \text{RF}$$

Air Pre-Heater Costs (APH_{cost}) =	\$0 in 2019 dollars
---	---------------------

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

Balance of Plant Costs (BOP_{cost})

For Coal-Fired Utility Boilers:

$$BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{BTF} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$BOP_{cost} = 213,000 \times (B_{MW})^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{BTF} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$BOP_{cost} = 213,000 \times (Q_B/NPHR)^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{RF}$$

Balance of Plant Costs (BOP_{cost}) =	\$6,243,316 in 2019 dollars
---	-----------------------------

Annual Costs

Total Annual Cost (TAC)

$$\text{TAC} = \text{Direct Annual Costs} + \text{Indirect Annual Costs}$$

Direct Annual Costs (DAC) =	\$2,342,055 in 2019 dollars
Indirect Annual Costs (IDAC) =	\$1,394,042 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC	\$3,736,097 in 2019 dollars

Direct Annual Costs (DAC)

$$\text{DAC} = (\text{Annual Maintenance Cost}) + (\text{Annual Reagent Cost}) + (\text{Annual Electricity Cost}) + (\text{Annual Water Cost}) + (\text{Annual Fuel Cost}) + (\text{Annual Ash Cost})$$

Annual Maintenance Cost =	$0.015 \times \text{TCl} =$	\$206,525 in 2019 dollars
Annual Reagent Cost =	$q_{\text{sol}} \times \text{Cost}_{\text{reag}} \times t_{\text{op}} =$	\$2,095,036 in 2019 dollars
Annual Electricity Cost =	$P \times \text{Cost}_{\text{elect}} \times t_{\text{op}} =$	\$29,414 in 2019 dollars
Annual Water Cost =	$q_{\text{water}} \times \text{Cost}_{\text{water}} \times t_{\text{op}} =$	\$0 in 2019 dollars
Additional Fuel Cost =	$\Delta \text{Fuel} \times \text{Cost}_{\text{fuel}} \times t_{\text{op}} =$	\$10,188 in 2019 dollars
Additional Ash Cost =	$\Delta \text{Ash} \times \text{Cost}_{\text{ash}} \times t_{\text{op}} \times (1/2000) =$	\$893 in 2019 dollars
Direct Annual Cost =		\$2,342,055 in 2019 dollars

Indirect Annual Cost (IDAC)

$$\text{IDAC} = \text{Administrative Charges} + \text{Capital Recovery Costs}$$

Administrative Charges (AC) =	$0.03 \times \text{Annual Maintenance Cost} =$	\$6,196 in 2019 dollars
Capital Recovery Costs (CR)=	$\text{CRF} \times \text{TCl} =$	\$1,387,846 in 2019 dollars
Indirect Annual Cost (IDAC) =	$\text{AC} + \text{CR} =$	\$1,394,042 in 2019 dollars

Cost Effectiveness

$$\text{Cost Effectiveness} = \text{Total Annual Cost} / \text{NOx Removed/year}$$

Total Annual Cost (TAC) =	\$3,736,097 per year in 2019 dollars
NOx Removed =	564 tons/year
Cost Effectiveness =	\$6,623 per ton of NOx removed in 2019 dollars

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

Utility ▼

What type of fuel does the unit burn?

Coal ▼

Is the SNCR for a new boiler or retrofit of an existing boiler?

Retrofit ▼

Please enter a retrofit factor equal to or greater than 0.84 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.

1

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

811.9 MW

What is the higher heating value (HHV) of the fuel?

8,597 Btu/lb

What is the estimated actual annual MWh output?

4,224,041 MWh

Is the boiler a fluid-bed boiler?

No ▼

Enter the net plant heat input rate (NPHR)

9.6777 MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Provide the following information for coal-fired boilers:

Type of coal burned:

Sub-Bituminous ▼

Enter the sulfur content (%S) =

0.24 percent by weight

or

Select the appropriate SO₂ emission rate:

Not Applicable ▼

Ash content (%Ash):

5.84 percent by weight

**The ash content of 5.84% is a default value. See below for data source. Enter actual value, if known.*

For units burning coal blends:

Note: The table below is pre-populated with default values for HHV, %S, %Ash and cost. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

	Fraction in Coal Blend	%S	%Ash	HHV (Btu/lb)	Fuel Cost (\$/MMBtu)
Bituminous	0	1.84	9.23	11,841	2.4
Sub-Bituminous	0	0.41	5.84	8,826	1.89
Lignite	0	0.82	13.6	6,626	1.74

Please click the calculate button to calculate weighted values based on the data in the table above.

Enter the following design parameters for the proposed SNCR:

Number of days the SNCR operates (t_{SNCR})	365 days	default 155	Plant Elevation	581 Feet above sea level						
Inlet NO_x Emissions ($NO_{x,in}$) to SNCR	0.184 lb/MMBtu									
Outlet NO_x Emissions ($NO_{x,out}$) from SNCR	0.1472 lb/MMBtu									
Estimated Normalized Stoichiometric Ratio (NSR)	1.22		*The NSR for a urea system may be calculated using equation 1.17 in Section 4, Chapter 1 of the Air Pollution Control Cost Manual (as updated March 2019).							
Concentration of reagent as stored (C_{stored})	50 Percent	<table border="1"> <tr> <th colspan="2">Densities of typical SNCR reagents:</th> </tr> <tr> <td>50% urea solution</td> <td>71 lbs/ft³</td> </tr> <tr> <td>29.4% aqueous NH₃</td> <td>56 lbs/ft³</td> </tr> </table>			Densities of typical SNCR reagents:		50% urea solution	71 lbs/ft ³	29.4% aqueous NH ₃	56 lbs/ft ³
Densities of typical SNCR reagents:										
50% urea solution	71 lbs/ft ³									
29.4% aqueous NH ₃	56 lbs/ft ³									
Density of reagent as stored (ρ_{stored})	71 lb/ft ³									
Concentration of reagent injected (C_{inj})	50 percent									
Number of days reagent is stored ($t_{storage}$)	14 days									
Estimated equipment life	20 Years									
Select the reagent used	Urea									

Enter the cost data for the proposed SNCR:

Desired dollar-year	2019			
CEPCI for 2019	607.5 Enter the CEPCI value for 2019	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	7.862 Percent			
Fuel ($Cost_{fuel}$)	1.89 \$/MMBtu*			
Reagent ($Cost_{reag}$)	1.66 \$/gallon for a 50 percent solution of urea*			
Water ($Cost_{water}$)	0.0042 \$/gallon*			
Electricity ($Cost_{elect}$)	0.0660 \$/kWh			
Ash Disposal (for coal-fired boilers only) ($Cost_{ash}$)	48.80 \$/ton*			

* The values marked are default values. See the table below for the default values used and their references. Enter actual values, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.015
Administrative Charges Factor (ACF) =	0.03

Data Sources for Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$1.66/gallon of 50% urea solution	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6, Using the Integrated Planning Model, Updates to the Cost and Performance for APC Technologies, SNCR Cost Development Methodology, Chapter 5, Attachment 5-4, January 2017. Available at: https://www.epa.gov/sites/production/files/2018-05/documents/attachment_5-4_sncr_cost_development_methodology.pdf .	
Water Cost (\$/gallon)	0.00417	Average water rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf .	
Electricity Cost (\$/kWh)	0.0361	U.S. Energy Information Administration. Electric Power Annual 2016. Table 8.4. Published December 2017. Available at: https://www.eia.gov/electricity/annual/pdf/epa.pdf .	2019 EIA data-0.0660 \$/kWh
Fuel Cost (\$/MMBtu)	1.89	U.S. Energy Information Administration. Electric Power Annual 2016. Table 7.4. Published December 2017. Available at: https://www.eia.gov/electricity/annual/pdf/epa.pdf .	
Ash Disposal Cost (\$/ton)	48.8	Waste Business Journal. The Cost to Landfill MSW Continues to Rise Despite Soft Demand. July 11, 2017. Available at: http://www.wastebusinessjournal.com/news/wbj20170711A.htm .	
Percent sulfur content for Coal (% weight)	0.41	Average sulfur content based on U.S. coal data for 2016 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	Site Specific Sulfur Content-0.24%
Percent ash content for Coal (% weight)	5.84	Average ash content based on U.S. coal data for 2016 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	
Higher Heating Value (HHV) (Btu/lb)	8,826	2016 coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	Site Specific Coal HH Value-8597 BTU/lb

SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate (Q_B) =	$B_{mw} \times NPHR =$	7,857	MMBtu/hour
Maximum Annual MWh Output =	$B_{mw} \times 8760 =$	7,112,244	MWh
Estimated Actual Annual MWh Output (Boutput) =		4,224,041	MWh
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.97	
Total System Capacity Factor (CF_{total}) =	$(Boutput/B_{mw}) \times (tsnrcr/365) =$	0.59	fraction
Total operating time for the SNCR (t_{op}) =	$CF_{total} \times 8760 =$	5203	hours
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	20	percent
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_B =$	289.15	lb/hour
Total NO _x removed per year =	$(NO_{x_{in}} \times EF \times Q_B \times t_{op})/2000 =$	752.17	tons/year
Coal Factor (Coal _f) =	1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05	
SO ₂ Emission rate =	$(\%S/100) \times (64/32) \times (1 \times 10^6)/HHV =$	< 3	lbs/MMBtu
Elevation Factor (ELEV _F) =	14.7 psia/P =	1.02	
Atmospheric pressure at 581 feet above sea level (P) =	$2116 \times [(59 - (0.00356 \times h) + 459.7)/518.6]^{5.256} \times (1/144) * =$	14.4	psia
Retrofit Factor (RF) =	Retrofit to existing boiler	1.00	

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html>.

Reagent Data:

Type of reagent used

Urea

Molecular Weight of Reagent (MW) =

60.06 g/mole

Density =

71 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m_{reagent}) =	$(\text{NO}_{x,\text{in}} \times Q_{\text{B}} \times \text{NSR} \times \text{MW}_{\text{R}}) / (\text{MW}_{\text{NO}_x} \times \text{SR}) =$ (whre SR = 1 for NH_3 ; 2 for Urea)	1151	lb/hour
Reagent Usage Rate (m_{sol}) =	$m_{\text{reagent}} / C_{\text{sol}} =$	2,302	lb/hour
	$(m_{\text{sol}} \times 7.4805) / \text{Reagent Density} =$	242.6	gal/hour
Estimated tank volume for reagent storage =	$(m_{\text{sol}} \times 7.4805 \times t_{\text{storage}} \times 24 \text{ hours/day}) / \text{Reagent Density} =$	81,600	gallons (storage needed to store a 14 day reagent supply rounded up to the nearest 100 gallons)

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.1008

Parameter	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$(0.47 \times \text{NO}_{x,\text{in}} \times \text{NSR} \times Q_{\text{B}}) / \text{NPHR} =$	85.7	kW/hour
Water Usage:			
Water consumption (q_{w}) =	$(m_{\text{sol}} / \text{Density of water}) \times ((C_{\text{stored}} / C_{\text{inj}}) - 1) =$	0	gallons/hour
Fuel Data:			
Additional Fuel required to evaporate water in injected reagent (ΔFuel) =	$H_v \times m_{\text{reagent}} \times ((1/C_{\text{inj}}) - 1) =$	1.04	MMBtu/hour
Ash Disposal:			
Additional ash produced due to increased fuel consumption (Δash) =	$(\Delta\text{fuel} \times \% \text{Ash} \times 1 \times 10^6) / \text{HHV} =$	7.0	lb/hour

Cost Estimate

Total Capital Investment (TCI)

For Coal-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$$

For Fuel Oil and Natural Gas-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$$

Capital costs for the SNCR (SNCR _{cost}) =	\$4,347,697 in 2019 dollars
Air Pre-Heater Costs (APH _{cost})* =	\$0 in 2019 dollars
Balance of Plant Costs (BOP _{cost}) =	\$6,462,610 in 2019 dollars
Total Capital Investment (TCI) =	\$14,053,400 in 2019 dollars

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide.

SNCR Capital Costs (SNCR_{cost})

For Coal-Fired Utility Boilers:

$$SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times \text{CoalF} \times \text{BTF} \times \text{ELEV} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times \text{ELEV} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times \text{CoalF} \times \text{BTF} \times \text{ELEV} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$SNCR_{cost} = 147,000 \times ((Q_B/NPHR) \times HRF)^{0.42} \times \text{ELEV} \times \text{RF}$$

SNCR Capital Costs (SNCR _{cost}) =	\$4,347,697 in 2019 dollars
--	-----------------------------

Air Pre-Heater Costs (APH_{cost})*

For Coal-Fired Utility Boilers:

$$APH_{cost} = 69,000 \times (B_{MW} \times HRF \times \text{CoalF})^{0.78} \times \text{AHF} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times \text{CoalF})^{0.78} \times \text{AHF} \times \text{RF}$$

Air Pre-Heater Costs (APH _{cost}) =	\$0 in 2019 dollars
---	---------------------

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

Balance of Plant Costs (BOP_{cost})

For Coal-Fired Utility Boilers:

$$BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{BTF} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$BOP_{cost} = 213,000 \times (B_{MW})^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{BTF} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$BOP_{cost} = 213,000 \times (Q_B/NPHR)^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{RF}$$

Balance of Plant Costs (BOP _{cost}) =	\$6,462,610 in 2019 dollars
---	-----------------------------

Annual Costs

Total Annual Cost (TAC)

$$\text{TAC} = \text{Direct Annual Costs} + \text{Indirect Annual Costs}$$

Direct Annual Costs (DAC) =	\$2,346,331 in 2019 dollars
Indirect Annual Costs (IDAC) =	\$1,422,907 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC	\$3,769,238 in 2019 dollars

Direct Annual Costs (DAC)

$$\text{DAC} = (\text{Annual Maintenance Cost}) + (\text{Annual Reagent Cost}) + (\text{Annual Electricity Cost}) + (\text{Annual Water Cost}) + (\text{Annual Fuel Cost}) + (\text{Annual Ash Cost})$$

Annual Maintenance Cost =	$0.015 \times \text{TCl} =$	\$210,801 in 2019 dollars
Annual Reagent Cost =	$q_{\text{sol}} \times \text{Cost}_{\text{reag}} \times t_{\text{op}} =$	\$2,095,036 in 2019 dollars
Annual Electricity Cost =	$P \times \text{Cost}_{\text{elect}} \times t_{\text{op}} =$	\$29,414 in 2019 dollars
Annual Water Cost =	$q_{\text{water}} \times \text{Cost}_{\text{water}} \times t_{\text{op}} =$	\$0 in 2019 dollars
Additional Fuel Cost =	$\Delta \text{Fuel} \times \text{Cost}_{\text{fuel}} \times t_{\text{op}} =$	\$10,188 in 2019 dollars
Additional Ash Cost =	$\Delta \text{Ash} \times \text{Cost}_{\text{ash}} \times t_{\text{op}} \times (1/2000) =$	\$893 in 2019 dollars
Direct Annual Cost =		\$2,346,331 in 2019 dollars

Indirect Annual Cost (IDAC)

$$\text{IDAC} = \text{Administrative Charges} + \text{Capital Recovery Costs}$$

Administrative Charges (AC) =	$0.03 \times \text{Annual Maintenance Cost} =$	\$6,324 in 2019 dollars
Capital Recovery Costs (CR)=	$\text{CRF} \times \text{TCl} =$	\$1,416,583 in 2019 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$1,422,907 in 2019 dollars

Cost Effectiveness

$$\text{Cost Effectiveness} = \text{Total Annual Cost} / \text{NOx Removed/year}$$

Total Annual Cost (TAC) =	\$3,769,238 per year in 2019 dollars
NOx Removed =	752 tons/year
Cost Effectiveness =	\$5,011 per ton of NOx removed in 2019 dollars

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

What type of fuel does the unit burn?

Is the SCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

What is the higher heating value (HHV) of the fuel?

What is the estimated actual annual MWhs output?

Enter the net plant heat input rate (NPHR)

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation

Provide the following information for coal-fired boilers:

Type of coal burned:

Enter the sulfur content (%S) = percent by weight

For units burning coal blends:

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

- Method 1
- Method 2
- Not applicable

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates (t_{SCR})	365 days
Number of days the boiler operates (t_{plant})	365 days
Inlet NO _x Emissions (NO _{x,in}) to SCR	0.223 lb/MMBtu
Outlet NO _x Emissions (NO _{x,out}) from SCR	0.05 lb/MMBtu
Stoichiometric Ratio Factor (SRF)	1.050

*The SRF value of 1.05 is a default value. User should enter actual value, if known.

Number of SCR reactor chambers (n_{scr})	1
Number of catalyst layers (R_{layer})	3
Number of empty catalyst layers (R_{empty})	1
Ammonia Slip (Slip) provided by vendor	5 ppm
Volume of the catalyst layers ($Vol_{catalyst}$) (Enter "UNK" if value is not known)	UNK Cubic feet
Flue gas flow rate ($Q_{fluegas}$) (Enter "UNK" if value is not known)	UNK acfm

Estimated operating life of the catalyst ($H_{catalyst}$)	24,000 hours
Estimated SCR equipment life	30 Years*

* For utility boilers, the typical equipment life of an SCR is at least 30 years.

Gas temperature at the SCR inlet (T)	750 °F
Base case fuel gas volumetric flow rate factor (Q_{fuel})	516 ft ³ /min-MMBtu/hour

Concentration of reagent as stored (C_{stored})	29 percent*
Density of reagent as stored (ρ_{stored})	56 lb/cubic feet*
Number of days reagent is stored ($t_{storage}$)	14 days

*The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.

<u>Densities of typical SCR reagents:</u>	
50% urea solution	71 lbs/ft ³
29.4% aqueous NH ₃	56 lbs/ft ³

Select the reagent used Ammonia

Enter the cost data for the proposed SCR:

Desired dollar-year	2019		
CEPCI for 2019	607.5	541.7	2016 CEPCI
Annual Interest Rate (i)	7.862 Percent		
Reagent (Cost _{reag})	0.293 \$/gallon for 29% ammonia*		
Electricity (Cost _{elect})	0.0660 \$/kWh		
Catalyst cost (CC _{replace})	\$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)		
Operator Labor Rate	60.00 \$/hour (including benefits)*		
Operator Hours/Day	4.00 hours/day*		

CEPCI = Chemical Engineering Plant Cost Index

* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.

* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.

* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.

* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

Data Sources for Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 (https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf)	
Electricity Cost (\$/kWh)	0.0361	U.S. Energy Information Administration. Electric Power Annual 2016. Table 8.4. Published December 2017. Available at: https://www.eia.gov/electricity/annual/pdf/epa.pdf .	2019 EIA data-0.0660 \$/kWh
Percent sulfur content for Coal (% weight)	0.41	Average sulfur content based on U.S. coal data for 2016 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	Site Specific Sulfur Content-0.24%
Higher Heating Value (HHV) (Btu/lb)	8,826	2016 coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	Site Specific Coal HH Value-8827 BTU/lb
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6 .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6 .	
Interest Rate (Percent)	5.5	Default bank prime rate	Firm Specific Rate-7.862%

SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate (Q_B) =	$B_{mw} \times NPHR =$	7,164	MMBtu/hour
Maximum Annual MW Output (B_{mw}) =	$B_{mw} \times 8760 =$	6,358,008	MWhs
Estimated Actual Annual MWhs Output (Boutput) =		4,576,617	MWhs
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.99	
Total System Capacity Factor (CF_{total}) =	$(B_{output}/B_{mw}) \times (t_{scr}/t_{plant}) =$	0.720	fraction
Total operating time for the SCR (t_{op}) =	$CF_{total} \times 8760 =$	6306	hours
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	77.6	percent
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_B =$	1239.31	lb/hour
Total NO _x removed per year =	$(NO_{x_{in}} \times EF \times Q_B \times t_{op})/2000 =$	3,907.31	tons/year
NO _x removal factor (NRF) =	$EF/80 =$	0.97	
Volumetric flue gas flow rate ($q_{flue\ gas}$) =	$Q_{fuel} \times Q_B \times (460 + T)/(460 + 700)n_{scr} =$	3,855,771	acfm
Space velocity (V_{space}) =	$q_{flue\ gas}/Vol_{catalyst} =$	183.77	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05	
SO ₂ Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$	< 3	lbs/MMBtu
Elevation Factor (ELEVF) =	$14.7\ psia/P =$	1.04	
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7] / 518.6^{5.256} \times (1/144)^* =$	14.1	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.00	

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html>.

Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(\text{interest rate}) / (1 / ((1 + \text{interest rate})^Y - 1))$, where $Y = H_{\text{catalysts}} / (t_{\text{SCR}} \times 24 \text{ hours})$ rounded to the nearest integer	0.3084	Fraction
Catalyst volume ($\text{Vol}_{\text{catalyst}}$) =	$2.81 \times Q_B \times \text{EF}_{\text{adj}} \times \text{Slip}_{\text{adj}} \times \text{NOx}_{\text{adj}} \times S_{\text{adj}} \times (T_{\text{adj}} / N_{\text{scr}})$	20,980.95	Cubic feet
Cross sectional area of the catalyst (A_{catalyst}) =	$q_{\text{flue gas}} / (16 \text{ft/sec} \times 60 \text{ sec/min})$	4,016	ft ²
Height of each catalyst layer (H_{layer}) =	$(\text{Vol}_{\text{catalyst}} / (R_{\text{layer}} \times A_{\text{catalyst}})) + 1$ (rounded to next highest integer)	3	feet

SCR Reactor Data:

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor (A_{SCR}) =	$1.15 \times A_{\text{catalyst}}$	4,619	ft ²
Reactor length and width dimensions for a square reactor =	$(A_{\text{SCR}})^{0.5}$	68.0	feet
Reactor height =	$(R_{\text{layer}} + R_{\text{empty}}) \times (7 \text{ft} + h_{\text{layer}}) + 9 \text{ft}$	48	feet

Reagent Data:

Type of reagent used

Ammonia

Molecular Weight of Reagent (MW) = 17.03 g/mole

Density = 56 lb/ft³

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m_{reagent}) =	$(\text{NOx}_{\text{in}} \times Q_B \times \text{EF} \times \text{SRF} \times \text{MW}_R) / \text{MW}_{\text{NOx}} =$	482	lb/hour
Reagent Usage Rate (m_{sol}) =	$m_{\text{reagent}} / \text{Csol} =$	1,661	lb/hour
	$(m_{\text{sol}} \times 7.4805) / \text{Reagent Density}$	222	gal/hour
Estimated tank volume for reagent storage =	$(m_{\text{sol}} \times 7.4805 \times t_{\text{storage}} \times 24) / \text{Reagent Density} =$	74,600	gallons (storage needed to store a 14 day reagent supply rounded to t

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1 + i)^n / (1 + i)^n - 1 =$ Where n = Equipment Life and i = Interest Rate	0.0877

Other parameters	Equation	Calculated Value	Units
Electricity Usage: Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = Bmw for utility boilers	4127.36	kW

Cost Estimate

Total Capital Investment (TCI)

TCI for Coal-Fired Boilers

For Coal-Fired Boilers:

$$TCI = 1.3 \times (SCR_{cost} + RPC + APHC + BPC)$$

Capital costs for the SCR (SCR_{cost}) =	\$159,054,491	in 2019 dollars
Reagent Preparation Cost (RPC) =	\$3,752,853	in 2019 dollars
Air Pre-Heater Costs (APHC)* =	\$0	in 2019 dollars
Balance of Plant Costs (BPC) =	\$9,957,446	in 2019 dollars
Total Capital Investment (TCI) =	\$224,594,227	in 2019 dollars

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 3lb/MMBtu of sulfur dioxide.

SCR Capital Costs (SCR_{cost})

For Coal-Fired Utility Boilers >25 MW:

$$SCR_{cost} = 310,000 \times (NRF)^{0.2} \times (B_{MW} \times HRF \times CoalF)^{0.92} \times ELEVF \times RF$$

For Coal-Fired Industrial Boilers >250 MMBtu/hour:

$$SCR_{cost} = 310,000 \times (NRF)^{0.2} \times (0.1 \times Q_B \times CoalF)^{0.92} \times ELEVF \times RF$$

SCR Capital Costs (SCR_{cost}) =

\$159,054,491 in 2019 dollars

Reagent Preparation Costs (RPC)

For Coal-Fired Utility Boilers >25 MW:

$$RPC = 564,000 \times (NO_{x,in} \times B_{MW} \times NPHR \times EF)^{0.25} \times RF$$

For Coal-Fired Industrial Boilers >250 MMBtu/hour:

$$RPC = 564,000 \times (NO_{x,in} \times Q_B \times EF)^{0.25} \times RF$$

Reagent Preparation Costs (RPC) =

\$3,752,853 in 2019 dollars

Air Pre-Heater Costs (APHC)*

For Coal-Fired Utility Boilers >25MW:

$$APHC = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

For Coal-Fired Industrial Boilers >250 MMBtu/hour:

$$APHC = 69,000 \times (0.1 \times Q_B \times CoalF)^{0.78} \times AHF \times RF$$

Air Pre-Heater Costs (APH_{cost}) =

\$0 in 2019 dollars

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

Balance of Plant Costs (BPC)

For Coal-Fired Utility Boilers >25MW:

$$BPC = 529,000 \times (B_{MW} \times HRF \times CoalF)^{0.42} \times ELEVF \times RF$$

For Coal-Fired Industrial Boilers >250 MMBtu/hour:

$$BPC = 529,000 \times (0.1 \times Q_B \times CoalF)^{0.42} \times ELEVF \times RF$$

Balance of Plant Costs (BOP_{cost}) =

\$9,957,446 in 2019 dollars

Annual Costs

Total Annual Cost (TAC)

$$\text{TAC} = \text{Direct Annual Costs} + \text{Indirect Annual Costs}$$

Direct Annual Costs (DAC) =	\$3,739,896 in 2019 dollars
Indirect Annual Costs (IDAC) =	\$19,713,017 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC	\$23,452,914 in 2019 dollars

Direct Annual Costs (DAC)

$$\text{DAC} = (\text{Annual Maintenance Cost}) + (\text{Annual Reagent Cost}) + (\text{Annual Electricity Cost}) + (\text{Annual Catalyst Cost})$$

Annual Maintenance Cost =	0.005 x TCI =	\$1,122,971 in 2019 dollars
Annual Reagent Cost =	$m_{\text{sol}} \times \text{Cost}_{\text{reag}} \times t_{\text{op}} =$	\$409,894 in 2019 dollars
Annual Electricity Cost =	$P \times \text{Cost}_{\text{elect}} \times t_{\text{op}} =$	\$1,717,428 in 2019 dollars
Annual Catalyst Replacement Cost =		\$489,603 in 2019 dollars

For coal-fired boilers, the following methods may be used to calculate the catalyst replacement cost.

Method 1 (for all fuel types):	$n_{\text{scr}} \times \text{Vol}_{\text{cat}} \times (\text{CC}_{\text{replace}} / R_{\text{layer}}) \times \text{FWF}$	* Calculation Method 1 selected.
Method 2 (for coal-fired utility boilers):	$B_{\text{MW}} \times 0.4 \times (\text{CoalF})^{2.9} \times (\text{NRF})^{0.71} \times (\text{CC}_{\text{replace}}) \times 35.3$	
Direct Annual Cost =		\$3,739,896 in 2019 dollars

Indirect Annual Cost (IDAC)

$$\text{IDAC} = \text{Administrative Charges} + \text{Capital Recovery Costs}$$

Administrative Charges (AC) =	0.03 x (Operator Cost + 0.4 x Annual Maintenance Cost) =	\$16,104 in 2019 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$19,696,914 in 2019 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$19,713,017 in 2019 dollars

Cost Effectiveness

$$\text{Cost Effectiveness} = \text{Total Annual Cost} / \text{NOx Removed/year}$$

Total Annual Cost (TAC) =	\$23,452,914 per year in 2019 dollars
NOx Removed =	3,907 tons/year
Cost Effectiveness =	\$6,002 per ton of NOx removed in 2019 dollars

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler? Utility

What type of fuel does the unit burn? Coal

Is the SNCR for a new boiler or retrofit of an existing boiler? Retrofit

Please enter a retrofit factor equal to or greater than 0.84 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty. 1

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)? 725.8 MW

What is the higher heating value (HHV) of the fuel? 8,827 Btu/lb

What is the estimated actual annual MWh output? 4,576,617 MWh

Is the boiler a fluid-bed boiler? No

Enter the net plant heat input rate (NPHR) 9.87 MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Provide the following information for coal-fired boilers:

Type of coal burned: Sub-Bituminous

Enter the sulfur content (%S) = 0.24 percent by weight
or
Select the appropriate SO₂ emission rate: Not Applicable

Ash content (%Ash): 5.84 percent by weight
*The ash content of 5.84% is a default value. See below for data source. Enter actual value, if known.

For units burning coal blends:

Note: The table below is pre-populated with default values for HHV, %S, %Ash and cost. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

	Fraction in Coal Blend	%S	%Ash	HHV (Btu/lb)	Fuel Cost (\$/MMBtu)
Bituminous	0	1.84	9.23	11,841	2.4
Sub-Bituminous	0	0.41	5.84	8,826	1.89
Lignite	0	0.82	13.6	6,626	1.74

Please click the calculate button to calculate weighted values based on the data in the table above.

Enter the following design parameters for the proposed SNCR:

Number of days the SNCR operates (t_{SNCR})	365 days	default 155	Plant Elevation	1089 Feet above sea level
Inlet NO_x Emissions ($NO_{x,in}$) to SNCR	0.223 lb/MMBtu			
Outlet NO_x Emissions ($NO_{x,out}$) from SNCR	0.1896 lb/MMBtu			
Estimated Normalized Stoichiometric Ratio (NSR)	1.22			
Concentration of reagent as stored (C_{stored})	50 Percent			
Density of reagent as stored (ρ_{stored})	71 lb/ft ³			
Concentration of reagent injected (C_{inj})	50 percent			
Number of days reagent is stored ($t_{storage}$)	14 days			
Estimated equipment life	20 Years			
Select the reagent used	Urea			

*The NSR for a urea system may be calculated using equation 1.17 in Section 4, Chapter 1 of the Air Pollution Control Cost Manual (as updated March 2019).

Densities of typical SNCR reagents:	
50% urea solution	71 lbs/ft ³
29.4% aqueous NH ₃	56 lbs/ft ³

Enter the cost data for the proposed SNCR:

Desired dollar-year	2019			
CEPCI for 2019	607.5 Enter the CEPCI value for 2019	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	7.862 Percent			
Fuel ($Cost_{fuel}$)	1.89 \$/MMBtu*			
Reagent ($Cost_{reag}$)	1.66 \$/gallon for a 50 percent solution of urea*			
Water ($Cost_{water}$)	0.0042 \$/gallon*			
Electricity ($Cost_{elect}$)	0.0660 \$/kWh			
Ash Disposal (for coal-fired boilers only) ($Cost_{ash}$)	48.80 \$/ton*			

* The values marked are default values. See the table below for the default values used and their references. Enter actual values, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.015
Administrative Charges Factor (ACF) =	0.03

Data Sources for Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$1.66/gallon of 50% urea solution	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6, Using the Integrated Planning Model, Updates to the Cost and Performance for APC Technologies, SNCR Cost Development Methodology, Chapter 5, Attachment 5-4, January 2017. Available at: https://www.epa.gov/sites/production/files/2018-05/documents/attachment_5-4_sncr_cost_development_methodology.pdf .	
Water Cost (\$/gallon)	0.00417	Average water rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf .	
Electricity Cost (\$/kWh)	0.0361	U.S. Energy Information Administration. Electric Power Annual 2016. Table 8.4. Published December 2017. Available at: https://www.eia.gov/electricity/annual/pdf/epa.pdf .	2019 EIA data-0.0660 \$/kWh
Fuel Cost (\$/MMBtu)	1.89	U.S. Energy Information Administration. Electric Power Annual 2016. Table 7.4. Published December 2017. Available at: https://www.eia.gov/electricity/annual/pdf/epa.pdf .	
Ash Disposal Cost (\$/ton)	48.8	Waste Business Journal. The Cost to Landfill MSW Continues to Rise Despite Soft Demand. July 11, 2017. Available at: http://www.wastebusinessjournal.com/news/wbj20170711A.htm .	
Percent sulfur content for Coal (% weight)	0.41	Average sulfur content based on U.S. coal data for 2016 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	Site Specific Sulfur Content-0.24%
Percent ash content for Coal (% weight)	5.84	Average ash content based on U.S. coal data for 2016 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	
Higher Heating Value (HHV) (Btu/lb)	8,826	2016 coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	Site Specific Coal HH Value-8827 BTU/lb
Interest Rate (%)	5.5	Default bank prime rate	Firm Specific Rate-7.862%

SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate (Q_B) =	$B_{mw} \times NPHR =$	7,164	MMBtu/hour
Maximum Annual MWh Output =	$B_{mw} \times 8760 =$	6,358,008	MWh
Estimated Actual Annual MWh Output (Boutput) =		4,576,617	MWh
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.99	
Total System Capacity Factor (CF_{total}) =	$(Boutput/B_{mw}) \times (tsnrcr/365) =$	0.72	fraction
Total operating time for the SNCR (t_{op}) =	$CF_{total} \times 8760 =$	6306	hours
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	15.0	percent
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_B =$	239.27	lb/hour
Total NO _x removed per year =	$(NO_{x_{in}} \times EF \times Q_B \times t_{op})/2000 =$	754.36	tons/year
Coal Factor (Coal _f) =	1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05	
SO ₂ Emission rate =	$(\%S/100) \times (64/32) \times (1 \times 10^6)/HHV =$	< 3	lbs/MMBtu
Elevation Factor (ELEV _F) =	14.7 psia/P =	1.04	
Atmospheric pressure at 1089 feet above sea level (P) =	$2116 \times [(59 - (0.00356 \times h) + 459.7)/518.6]^{5.256} \times (1/144) * =$	14.1	psia
Retrofit Factor (RF) =	Retrofit to existing boiler	1.00	

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

Reagent Data:

Type of reagent used

Urea

Molecular Weight of Reagent (MW) =

60.06 g/mole

Density =

71 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m_{reagent}) =	$(\text{NO}_{x,\text{in}} \times Q_{\text{B}} \times \text{NSR} \times \text{MW}_{\text{R}}) / (\text{MW}_{\text{NO}_x} \times \text{SR}) =$ (whre SR = 1 for NH_3 ; 2 for Urea)	1272	lb/hour
Reagent Usage Rate (m_{sol}) =	$m_{\text{reagent}} / C_{\text{sol}} =$	2,544	lb/hour
	$(m_{\text{sol}} \times 7.4805) / \text{Reagent Density} =$	268.0	gal/hour
Estimated tank volume for reagent storage =	$(m_{\text{sol}} \times 7.4805 \times t_{\text{storage}} \times 24 \text{ hours/day}) / \text{Reagent Density} =$	90,100	gallons (storage needed to store a 14 day reagent supply rounded up to the nearest 100 gallons)

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.1008

Parameter	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$(0.47 \times \text{NO}_{x,\text{in}} \times \text{NSR} \times Q_{\text{B}}) / \text{NPHR} =$	92.8	kW/hour
Water Usage:			
Water consumption (q_{w}) =	$(m_{\text{sol}} / \text{Density of water}) \times ((C_{\text{stored}} / C_{\text{inj}}) - 1) =$	0	gallons/hour
Fuel Data:			
Additional Fuel required to evaporate water in injected reagent (ΔFuel) =	$H_v \times m_{\text{reagent}} \times ((1/C_{\text{inj}}) - 1) =$	1.14	MMBtu/hour
Ash Disposal:			
Additional ash produced due to increased fuel consumption (Δash) =	$(\Delta\text{fuel} \times \% \text{Ash} \times 1 \times 10^6) / \text{HHV} =$	7.6	lb/hour

Cost Estimate

Total Capital Investment (TCI)

For Coal-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$$

For Fuel Oil and Natural Gas-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$$

Capital costs for the SNCR ($SNCR_{cost}$) =	\$4,259,953 in 2019 dollars
Air Pre-Heater Costs (APH_{cost})* =	\$0 in 2019 dollars
Balance of Plant Costs (BOP_{cost}) =	\$6,087,973 in 2019 dollars
Total Capital Investment (TCI) =	\$13,452,303 in 2019 dollars

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide.

SNCR Capital Costs ($SNCR_{cost}$)

For Coal-Fired Utility Boilers:

$$SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times \text{CoalF} \times \text{BTF} \times \text{ELEV} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times \text{ELEV} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times \text{CoalF} \times \text{BTF} \times \text{ELEV} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$SNCR_{cost} = 147,000 \times ((Q_B/NPHR) \times HRF)^{0.42} \times \text{ELEV} \times \text{RF}$$

SNCR Capital Costs ($SNCR_{cost}$) =	\$4,259,953 in 2019 dollars
--	-----------------------------

Air Pre-Heater Costs (APH_{cost})*

For Coal-Fired Utility Boilers:

$$APH_{cost} = 69,000 \times (B_{MW} \times HRF \times \text{CoalF})^{0.78} \times \text{AHF} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times \text{CoalF})^{0.78} \times \text{AHF} \times \text{RF}$$

Air Pre-Heater Costs (APH_{cost}) =	\$0 in 2019 dollars
---	---------------------

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

Balance of Plant Costs (BOP_{cost})

For Coal-Fired Utility Boilers:

$$BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{BTF} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$BOP_{cost} = 213,000 \times (B_{MW})^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{BTF} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$BOP_{cost} = 213,000 \times (Q_B/NPHR)^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{RF}$$

Balance of Plant Costs (BOP_{cost}) =	\$6,087,973 in 2019 dollars
---	-----------------------------

Annual Costs

Total Annual Cost (TAC)

$$\text{TAC} = \text{Direct Annual Costs} + \text{Indirect Annual Costs}$$

Direct Annual Costs (DAC) =	\$3,060,908 in 2019 dollars
Indirect Annual Costs (IDAC) =	\$1,362,046 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC	\$4,422,954 in 2019 dollars

Direct Annual Costs (DAC)

$$\text{DAC} = (\text{Annual Maintenance Cost}) + (\text{Annual Reagent Cost}) + (\text{Annual Electricity Cost}) + (\text{Annual Water Cost}) + (\text{Annual Fuel Cost}) + (\text{Annual Ash Cost})$$

Annual Maintenance Cost =	0.015 x TCI =	\$201,785 in 2019 dollars
Annual Reagent Cost =	$q_{\text{sol}} \times \text{Cost}_{\text{reag}} \times t_{\text{op}} =$	\$2,805,691 in 2019 dollars
Annual Electricity Cost =	$P \times \text{Cost}_{\text{elect}} \times t_{\text{op}} =$	\$38,623 in 2019 dollars
Annual Water Cost =	$q_{\text{water}} \times \text{Cost}_{\text{water}} \times t_{\text{op}} =$	\$0 in 2019 dollars
Additional Fuel Cost =	$\Delta \text{Fuel} \times \text{Cost}_{\text{fuel}} \times t_{\text{op}} =$	\$13,644 in 2019 dollars
Additional Ash Cost =	$\Delta \text{Ash} \times \text{Cost}_{\text{ash}} \times t_{\text{op}} \times (1/2000) =$	\$1,165 in 2019 dollars
Direct Annual Cost =		\$3,060,908 in 2019 dollars

Indirect Annual Cost (IDAC)

$$\text{IDAC} = \text{Administrative Charges} + \text{Capital Recovery Costs}$$

Administrative Charges (AC) =	0.03 x Annual Maintenance Cost =	\$6,054 in 2019 dollars
Capital Recovery Costs (CR)=	$\text{CRF} \times \text{TCI} =$	\$1,355,992 in 2019 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$1,362,046 in 2019 dollars

Cost Effectiveness

$$\text{Cost Effectiveness} = \text{Total Annual Cost} / \text{NOx Removed/year}$$

Total Annual Cost (TAC) =	\$4,422,954 per year in 2019 dollars
NOx Removed =	754 tons/year
Cost Effectiveness =	\$5,863.19 per ton of NOx removed in 2019 dollars

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler? Utility

What type of fuel does the unit burn? Coal

Is the SNCR for a new boiler or retrofit of an existing boiler? Retrofit

Please enter a retrofit factor equal to or greater than 0.84 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty. 1

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)? 725.8 MW

What is the higher heating value (HHV) of the fuel? 8,827 Btu/lb

What is the estimated actual annual MWh output? 4,576,617 MWh

Is the boiler a fluid-bed boiler? No

Enter the net plant heat input rate (NPHR) 9.87 MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Provide the following information for coal-fired boilers:

Type of coal burned: Sub-Bituminous

Enter the sulfur content (%S) = 0.24 percent by weight
or
Select the appropriate SO₂ emission rate: Not Applicable

Ash content (%Ash): 5.84 percent by weight
*The ash content of 5.84% is a default value. See below for data source. Enter actual value, if known.

For units burning coal blends:

Note: The table below is pre-populated with default values for HHV, %S, %Ash and cost. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

	Fraction in Coal Blend	%S	%Ash	HHV (Btu/lb)	Fuel Cost (\$/MMBtu)
Bituminous	0	1.84	9.23	11,841	2.4
Sub-Bituminous	0	0.41	5.84	8,826	1.89
Lignite	0	0.82	13.6	6,626	1.74

Please click the calculate button to calculate weighted values based on the data in the table above.

Enter the following design parameters for the proposed SNCR:

Number of days the SNCR operates (t_{SNCR})	365 days	default 155	Plant Elevation	1089 Feet above sea level
Inlet NO_x Emissions ($NO_{x,in}$) to SNCR	0.223 lb/MMBtu			
Outlet NO_x Emissions ($NO_{x,out}$) from SNCR	0.1784 lb/MMBtu			
Estimated Normalized Stoichiometric Ratio (NSR)	1.22		*The NSR for a urea system may be calculated using equation 1.17 in Section 4, Chapter 1 of the Air Pollution Control Cost Manual (as updated March 2019).	
Concentration of reagent as stored (C_{stored})	50 Percent	Densities of typical SNCR reagents: 50% urea solution 71 lbs/ft ³ 29.4% aqueous NH ₃ 56 lbs/ft ³		
Density of reagent as stored (ρ_{stored})	71 lb/ft ³			
Concentration of reagent injected (C_{inj})	50 percent			
Number of days reagent is stored ($t_{storage}$)	14 days			
Estimated equipment life	20 Years			
Select the reagent used	Urea			

Enter the cost data for the proposed SNCR:

Desired dollar-year	2019			
CEPCI for 2019	607.5 Enter the CEPCI value for 2019	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	7.862 Percent			
Fuel ($Cost_{fuel}$)	1.89 \$/MMBtu*			
Reagent ($Cost_{reag}$)	1.66 \$/gallon for a 50 percent solution of urea*			
Water ($Cost_{water}$)	0.0042 \$/gallon*			
Electricity ($Cost_{elect}$)	0.0660 \$/kWh			
Ash Disposal (for coal-fired boilers only) ($Cost_{ash}$)	48.80 \$/ton*			

* The values marked are default values. See the table below for the default values used and their references. Enter actual values, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.015
Administrative Charges Factor (ACF) =	0.03

Data Sources for Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$1.66/gallon of 50% urea solution	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6, Using the Integrated Planning Model, Updates to the Cost and Performance for APC Technologies, SNCR Cost Development Methodology, Chapter 5, Attachment 5-4, January 2017. Available at: https://www.epa.gov/sites/production/files/2018-05/documents/attachment_5-4_sncr_cost_development_methodology.pdf .	
Water Cost (\$/gallon)	0.00417	Average water rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf .	
Electricity Cost (\$/kWh)	0.0361	U.S. Energy Information Administration. Electric Power Annual 2016. Table 8.4. Published December 2017. Available at: https://www.eia.gov/electricity/annual/pdf/epa.pdf .	2019 EIA data-0.0660 \$/kWh
Fuel Cost (\$/MMBtu)	1.89	U.S. Energy Information Administration. Electric Power Annual 2016. Table 7.4. Published December 2017. Available at: https://www.eia.gov/electricity/annual/pdf/epa.pdf .	
Ash Disposal Cost (\$/ton)	48.8	Waste Business Journal. The Cost to Landfill MSW Continues to Rise Despite Soft Demand. July 11, 2017. Available at: http://www.wastebusinessjournal.com/news/wbj20170711A.htm .	
Percent sulfur content for Coal (% weight)	0.41	Average sulfur content based on U.S. coal data for 2016 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	Site Specific Sulfur Content-0.24%
Percent ash content for Coal (% weight)	5.84	Average ash content based on U.S. coal data for 2016 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	
Higher Heating Value (HHV) (Btu/lb)	8,826	2016 coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	Site Specific Coal HH Value-8827 BTU/lb
Interest Rate (%)	5.5	Default bank prime rate	Firm Specific Rate-7.862%

SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate (Q_B) =	$B_{mw} \times NPHR =$	7,164	MMBtu/hour
Maximum Annual MWh Output =	$B_{mw} \times 8760 =$	6,358,008	MWh
Estimated Actual Annual MWh Output (Boutput) =		4,576,617	MWh
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.99	
Total System Capacity Factor (CF_{total}) =	$(Boutput/B_{mw}) \times (tsnrcr/365) =$	0.72	fraction
Total operating time for the SNCR (t_{op}) =	$CF_{total} \times 8760 =$	6306	hours
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	20.0	percent
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_B =$	319.50	lb/hour
Total NO _x removed per year =	$(NO_{x_{in}} \times EF \times Q_B \times t_{op})/2000 =$	1,007.32	tons/year
Coal Factor (Coal _f) =	1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05	
SO ₂ Emission rate =	$(\%S/100) \times (64/32) \times (1 \times 10^6)/HHV =$	< 3	lbs/MMBtu
Elevation Factor (ELEV _F) =	14.7 psia/P =	1.04	
Atmospheric pressure at 1089 feet above sea level (P) =	$2116 \times [(59 - (0.00356 \times h) + 459.7)/518.6]^{5.256} \times (1/144) * =$	14.1	psia
Retrofit Factor (RF) =	Retrofit to existing boiler	1.00	

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html>.

Reagent Data:

Type of reagent used

Urea

Molecular Weight of Reagent (MW) =

60.06 g/mole

Density =

71 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m_{reagent}) =	$(\text{NO}_{x,\text{in}} \times Q_{\text{B}} \times \text{NSR} \times \text{MW}_{\text{R}}) / (\text{MW}_{\text{NO}_x} \times \text{SR}) =$ (whre SR = 1 for NH_3 ; 2 for Urea)	1272	lb/hour
Reagent Usage Rate (m_{sol}) =	$m_{\text{reagent}} / C_{\text{sol}} =$	2,544	lb/hour
	$(m_{\text{sol}} \times 7.4805) / \text{Reagent Density} =$	268.0	gal/hour
Estimated tank volume for reagent storage =	$(m_{\text{sol}} \times 7.4805 \times t_{\text{storage}} \times 24 \text{ hours/day}) / \text{Reagent Density} =$	90,100	gallons (storage needed to store a 14 day reagent supply rounded up to the nearest 100 gallons)

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.1008

Parameter	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$(0.47 \times \text{NO}_{x,\text{in}} \times \text{NSR} \times Q_{\text{B}}) / \text{NPHR} =$	92.8	kW/hour
Water Usage:			
Water consumption (q_{w}) =	$(m_{\text{sol}} / \text{Density of water}) \times ((C_{\text{stored}} / C_{\text{inj}}) - 1) =$	0	gallons/hour
Fuel Data:			
Additional Fuel required to evaporate water in injected reagent (ΔFuel) =	$H_v \times m_{\text{reagent}} \times ((1/C_{\text{inj}}) - 1) =$	1.14	MMBtu/hour
Ash Disposal:			
Additional ash produced due to increased fuel consumption (Δash) =	$(\Delta\text{fuel} \times \% \text{Ash} \times 1 \times 10^6) / \text{HHV} =$	7.6	lb/hour

Cost Estimate

Total Capital Investment (TCI)

For Coal-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$$

For Fuel Oil and Natural Gas-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$$

Capital costs for the SNCR ($SNCR_{cost}$) =	\$4,259,953 in 2019 dollars
Air Pre-Heater Costs (APH_{cost})* =	\$0 in 2019 dollars
Balance of Plant Costs (BOP_{cost}) =	\$6,302,942 in 2019 dollars
Total Capital Investment (TCI) =	\$13,731,763 in 2019 dollars

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide.

SNCR Capital Costs ($SNCR_{cost}$)

For Coal-Fired Utility Boilers:

$$SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times \text{CoalF} \times \text{BTF} \times \text{ELEV} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times \text{ELEV} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times \text{CoalF} \times \text{BTF} \times \text{ELEV} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$SNCR_{cost} = 147,000 \times ((Q_B/NPHR) \times HRF)^{0.42} \times \text{ELEV} \times \text{RF}$$

SNCR Capital Costs ($SNCR_{cost}$) =	\$4,259,953 in 2019 dollars
--	-----------------------------

Air Pre-Heater Costs (APH_{cost})*

For Coal-Fired Utility Boilers:

$$APH_{cost} = 69,000 \times (B_{MW} \times HRF \times \text{CoalF})^{0.78} \times \text{AHF} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times \text{CoalF})^{0.78} \times \text{AHF} \times \text{RF}$$

Air Pre-Heater Costs (APH_{cost}) =	\$0 in 2019 dollars
---	---------------------

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

Balance of Plant Costs (BOP_{cost})

For Coal-Fired Utility Boilers:

$$BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{BTF} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$BOP_{cost} = 213,000 \times (B_{MW})^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{BTF} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$BOP_{cost} = 213,000 \times (Q_B/NPHR)^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{RF}$$

Balance of Plant Costs (BOP_{cost}) =	\$6,302,942 in 2019 dollars
---	-----------------------------

Annual Costs

Total Annual Cost (TAC)

$$\text{TAC} = \text{Direct Annual Costs} + \text{Indirect Annual Costs}$$

Direct Annual Costs (DAC) =	\$3,065,100 in 2019 dollars
Indirect Annual Costs (IDAC) =	\$1,390,341 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC	\$4,455,441 in 2019 dollars

Direct Annual Costs (DAC)

$$\text{DAC} = (\text{Annual Maintenance Cost}) + (\text{Annual Reagent Cost}) + (\text{Annual Electricity Cost}) + (\text{Annual Water Cost}) + (\text{Annual Fuel Cost}) + (\text{Annual Ash Cost})$$

Annual Maintenance Cost =	$0.015 \times \text{TCl} =$	\$205,976 in 2019 dollars
Annual Reagent Cost =	$q_{\text{sol}} \times \text{Cost}_{\text{reag}} \times t_{\text{op}} =$	\$2,805,691 in 2019 dollars
Annual Electricity Cost =	$P \times \text{Cost}_{\text{elect}} \times t_{\text{op}} =$	\$38,623 in 2019 dollars
Annual Water Cost =	$q_{\text{water}} \times \text{Cost}_{\text{water}} \times t_{\text{op}} =$	\$0 in 2019 dollars
Additional Fuel Cost =	$\Delta \text{Fuel} \times \text{Cost}_{\text{fuel}} \times t_{\text{op}} =$	\$13,644 in 2019 dollars
Additional Ash Cost =	$\Delta \text{Ash} \times \text{Cost}_{\text{ash}} \times t_{\text{op}} \times (1/2000) =$	\$1,165 in 2019 dollars
Direct Annual Cost =		\$3,065,100 in 2019 dollars

Indirect Annual Cost (IDAC)

$$\text{IDAC} = \text{Administrative Charges} + \text{Capital Recovery Costs}$$

Administrative Charges (AC) =	$0.03 \times \text{Annual Maintenance Cost} =$	\$6,179 in 2019 dollars
Capital Recovery Costs (CR)=	$\text{CRF} \times \text{TCl} =$	\$1,384,162 in 2019 dollars
Indirect Annual Cost (IDAC) =	$\text{AC} + \text{CR} =$	\$1,390,341 in 2019 dollars

Cost Effectiveness

$$\text{Cost Effectiveness} = \text{Total Annual Cost} / \text{NOx Removed/year}$$

Total Annual Cost (TAC) =	\$4,455,441 per year in 2019 dollars
NOx Removed =	1,007 tons/year
Cost Effectiveness =	\$4,423.07 per ton of NOx removed in 2019 dollars