

**Iowa Department of Natural Resources  
Title V Operating Permit**

**Name of Permitted Facility: Donaldson Company, Inc.**  
**Facility Location: 111 Donaldson Ct., Cresco, IA 52136**  
**Air Quality Operating Permit Number: 99-TV-043R3**  
**Expiration Date: September 5, 2023**  
**Permit Renewal Application Deadline: March 5, 2023**

**EIQ Number: 92-1417**  
**Facility File Number: 45-01-003**

---

**Responsible Official**

**Name: Ronald Bethany**  
**Title: Plant Manager**  
**Mailing Address: 111 Donaldson Ct., Cresco, IA 52136**  
**Phone #: 563-547-3030**

**Permit Contact Person for the Facility**

**Name: Eric Phillips**  
**Title: Manufacturing Engineering Manager**  
**Address: 111 Donaldson Ct., Cresco, IA 52136**  
**Phone #: 563-547-1431**

---

This permit is issued in accordance with 567 Iowa Administrative Code Chapter 22, and is issued subject to the terms and conditions contained in this permit. Two Title V Permits exist for one source (Industrial Energy Applications, Inc. and Donaldson Company). These two facilities constitute one stationary source. This permit is for Donaldson Company (Facility # 45-01-003)

**For the Director of the Department of Natural Resources**

---

Lori Hanson, Supervisor of Air Operating Permits Section

Date

# Table of Contents

<b>I. Facility Description and Equipment List .....</b>	<b>4</b>
<b>II. Plant - Wide Conditions.....</b>	<b>7</b>
<b>III. Emission Point Specific Conditions .....</b>	<b>10</b>
<b>IV. General Conditions.....</b>	<b>61</b>
G1. Duty to Comply	
G2. Permit Expiration	
G3. Certification Requirement for Title V Related Documents	
G4. Annual Compliance Certification	
G5. Semi-Annual Monitoring Report	
G6. Annual Fee	
G7. Inspection of Premises, Records, Equipment, Methods and Discharges	
G8. Duty to Provide Information	
G9. General Maintenance and Repair Duties	
G10. Recordkeeping Requirements for Compliance Monitoring	
G11. Evidence used in establishing that a violation has or is occurring.	
G12. Prevention of Accidental Release: Risk Management Plan Notification and Compliance Certification	
G13. Hazardous Release	
G14. Excess Emissions and Excess Emissions Reporting Requirements	
G15. Permit Deviation Reporting Requirements	
G16. Notification Requirements for Sources That Become Subject to NSPS and NESHAP Regulations	
G17. Requirements for Making Changes to Emission Sources That Do Not Require Title V Permit Modification	
G18. Duty to Modify a Title V Permit	
G19. Duty to Obtain Construction Permits	
G20. Asbestos	
G21. Open Burning	
G22. Acid Rain (Title IV) Emissions Allowances	
G23. Stratospheric Ozone and Climate Protection (Title VI) Requirements	
G24. Permit Reopenings	
G25. Permit Shield	
G26. Severability	
G27. Property Rights	
G28. Transferability	
G29. Disclaimer	
G30. Notification and Reporting Requirements for Stack Tests or Monitor Certification	
G31. Prevention of Air Pollution Emergency Episodes	
G32. Contacts List	
<b>V. Appendix: NESHAP Links.....</b>	<b>77</b>

## Abbreviations

acfm.....	actual cubic feet per minute
CFR.....	Code of Federal Regulation
CE .....	control equipment
CEM.....	continuous emission monitor
CFH.....	cubic feet per hour
°F .....	degrees Fahrenheit
EIQ.....	emissions inventory questionnaire
EP .....	emission point
EU .....	emission unit
gr./dscf .....	grains per dry standard cubic foot
IAC.....	Iowa Administrative Code
DNR .....	Iowa Department of Natural Resources
MVAC.....	motor vehicle air conditioner
NAICS.....	North American Industry Classification System
NSPS.....	new source performance standard
ppmv .....	parts per million by volume
lb./hr .....	pounds per hour
lb./MMBtu .....	pounds per million British thermal units
SCC.....	Source Classification Codes
scfm.....	standard cubic feet per minute
SIC .....	Standard Industrial Classification
TPY.....	tons per year
USEPA.....	United States Environmental Protection Agency

### Pollutants

PM.....	particulate matter
PM <sub>10</sub> .....	particulate matter ten microns or less in diameter
SO <sub>2</sub> .....	sulfur dioxide
NO <sub>x</sub> .....	nitrogen oxides
VOC .....	volatile organic compound
CO.....	carbon monoxide
HAP.....	hazardous air pollutant

# I. Facility Description and Equipment List

Facility Name: Donaldson Company, Inc.

Permit Number: 99-TV-043R3

Facility Description: Air Filter Manufacturer (SIC 3531)

---

## Equipment List

---

### A. Plastisol Cure Ovens

<b>Emission Point Number</b>	<b>Emission Unit Number</b>	<b>Emission Unit Description</b>	<b>DNR Construction Permit Number</b>
F4	F4	Plastisol Curing	04-A-933-S3

### B. Resistance Welding

<b>Emission Point Number</b>	<b>Emission Unit Number</b>	<b>Emission Unit Description</b>	<b>DNR Construction Permit Number</b>
33A	33A	Resistance Welding	94-A-490-S3
45	45	Resistance Welding	08-A-195

### C. Media Steamers

<b>Emission Point Number</b>	<b>Emission Unit Number</b>	<b>Emission Unit Description</b>	<b>DNR Construction Permit Number</b>
19	19	Media Steamer	95-A-196-S4
33B	33B	Media Steamer	00-A-936-S2

### D. Natural Gas Boilers

<b>Emission Point Number</b>	<b>Emission Unit Number</b>	<b>Emission Unit Description</b>	<b>DNR Construction Permit Number</b>
24	24	Natural Gas Boiler (South)	N/A
25	25	Natural Gas Boiler (North)	N/A

E. Power Core

<b>Emission Point Number</b>	<b>Emission Unit Number</b>	<b>Emission Unit Description</b>	<b>DNR Construction Permit Number</b>
F41	F41	Power Core (Adhesive Application)	02-A-655-S3
F42	F42	Power Core (Adhesive Application)	03-A-720-S2
F50	F50	Power Core (Adhesive Application)	12-A-037-S1

F. Curing Ovens

<b>Emission Point Number</b>	<b>Emission Unit Number</b>	<b>Emission Unit Description</b>	<b>DNR Construction Permit Number</b>
50	50	Curing Oven 1	12-A-361-S3
51	51	Curing Oven 2	12-A-362-S3
55	55	Curing Oven 3	18-A-104
56	56	Curing Oven 4	18-A-105

G. Ultra Web

<b>Emission Point Number</b>	<b>Emission Unit Number</b>	<b>Emission Unit Description</b>	<b>DNR Construction Permit Number</b>
48A	48	Ultra Web Line 1	12-A-366-S3
48B			12-A-365-S3
49A	49	Ultra Web Line 2	12-A-368-S3
49B			12-A-367-S3
53A	53	Ultra Web Line 3	18-A-100
53B			18-A-101
54A	54	Ultra Web Line 4	18-A-102
54B			18-A-103

I. Miscellaneous Sources

<b>Emission Point Number</b>	<b>Emission Unit Number</b>	<b>Emission Unit Description</b>	<b>DNR Construction Permit Number</b>
6	6	Ribbon Bonder	95-A-187-S1
29A	29A	Diesel Engine Fire Pump	N/A
40	40A	Thermoplastic Resin Injection Molding Machines	02-A-654-S3
	40B		
	40C		
	40D		
	40E		
	40F		
	40G		
	40H		
52	52A	Thermoplastic Resin Injection Molding Machines	18-A-099
	52B		
43	43	Hot Plate Welding	09-A-748-S4
F1	F1	Seam Seal	N/A
F5	F5	End Cap Printing	04-A-934-S1
F11	F11	Mold Release	06-A-445-S1
F20	F20	General Adhesive Application	04-A-935
F26	F26	Pleat Spacing Material	06-A-061-S1
	F28	Urethane Components	
F27	F27	Customer Required Sealant	06-A-062
47	47	Corrugator	12-A-360-S3
46A	46	Mix Room	12-A-364-S3
46B			12-A-363-S3

**Insignificant Activities Equipment List**

<b>Insignificant Emission Unit Number</b>	<b>Insignificant Emission Unit Description</b>
29B	Diesel Storage Tank (2,000 gal)
F2	Filter Media Scrap Dust
F7	Space heater (3 MMBtu/hr)
F8	Space heater (3 MMBtu/hr)
F9	Space heater (5.4 MMBtu/hr)
F13	Steel Shaping

## II. Plant-Wide Conditions

Facility Name: Donaldson Company, Inc.  
Permit Number: 99-TV-043R3

Permit conditions are established in accord with 567 Iowa Administrative Code rule 22.108

---

### Permit Duration

The term of this permit is: 5 Years  
Commencing on: 09/06/2018  
Ending on: 09/05/2023

Amendments, modifications and reopenings of the permit shall be obtained in accordance with 567 Iowa Administrative Code rules 22.110 - 22.114. Permits may be suspended, terminated, or revoked as specified in 567 Iowa Administrative Code Rules 22.115.

---

### Emission Limits

*Unless specified otherwise in the Source Specific Conditions, the following limitations and supporting regulations apply to all emission points at this plant:*

Opacity (visible emissions): 40% opacity  
Authority for Requirement: 567 IAC 23.3(2)"d"

Sulfur Dioxide (SO<sub>2</sub>): 500 parts per million by volume  
Authority for Requirement: 567 IAC 23.3(3)"e"

#### Particulate Matter:

No person shall cause or allow the emission of particulate matter from any source in excess of the emission standards specified in this chapter, except as provided in 567 – Chapter 24. For sources constructed, modified or reconstructed on or after July 21, 1999, the emission of particulate matter from any process shall not exceed an emission standard of 0.1 grain per dry standard cubic foot of exhaust gas, except as provided in 567 – 21.2(455B), 23.1(455B), 23.4(455B) and 567 – Chapter 24.

For sources constructed, modified or reconstructed prior to July 21, 1999, the emission of particulate matter from any process shall not exceed the amount determined from Table I, or amount specified in a permit if based on an emission standard of 0.1 grain per standard cubic foot of exhaust gas or established from standards provided in 23.1(455B) and 23.4(455B).  
Authority for Requirement: 567 IAC 23.3(2)"a"

Fugitive Dust: Attainment and Unclassified Areas - A person shall take reasonable precautions to prevent particulate matter from becoming airborne in quantities sufficient to cause a nuisance as defined in Iowa Code section 657.1 when the person allows, causes or permits any materials to be handled, transported or stored or a building, its appurtenances or a construction haul road to be used, constructed, altered, repaired or demolished, with the exception of farming operations or

dust generated by ordinary travel on unpaved roads. Ordinary travel includes routine traffic and road maintenance activities such as scarifying, compacting, transporting road maintenance surfacing material, and scraping of the unpaved public road surface. (the preceding sentence is State Only) All persons, with the above exceptions, shall take reasonable precautions to prevent the discharge of visible emissions of fugitive dusts beyond the lot line of the property on which the emissions originate. The public highway authority shall be responsible for taking corrective action in those cases where said authority has received complaints of or has actual knowledge of dust conditions which require abatement pursuant to this subrule. Reasonable precautions may include, but not be limited to, the following procedures.

1. Use, where practical, of water or chemicals for control of dusts in the demolition of existing buildings or structures, construction operations, the grading of roads or the clearing of land.
2. Application of suitable materials, such as but not limited to asphalt, oil, water or chemicals on unpaved roads, material stockpiles, race tracks and other surfaces which can give rise to airborne dusts.
3. Installation and use of containment or control equipment, to enclose or otherwise limit the emissions resulting from the handling and transfer of dusty materials, such as but not limited to grain, fertilizer or limestone.
4. Covering, at all times when in motion, open-bodied vehicles transporting materials likely to give rise to airborne dusts.
5. Prompt removal of earth or other material from paved streets or to which earth or other material has been transported by trucking or earth-moving equipment, erosion by water or other means.
6. Reducing the speed of vehicles traveling over on-property surfaces as necessary to minimize the generation of airborne dusts.

Authority for Requirement: 567 IAC 23.3(2)"c"

---

## **NESHAP**

Several sources at this facility are affected sources under 40 CFR 63 Subpart M – National Emission Standards for Hazardous Air Pollutants for Surface Coating of Miscellaneous Metal Parts and Products. The affected units are 6, F4, F5, F20, F26, F28 and F27 and the facility has decided to show compliance through the emission rate without add-on controls option.

Applicable subpart M requirements are incorporated into the Emission-Point Specific Conditions Section. The facility shall also comply with all applicable requirements from 40 CFR 63 subpart A (General Provisions).

Authority for Requirement: 40 CFR Part 63 Subpart M  
567 IAC 23.1(4)"cm"

Several sources at this facility are affected sources under 40 CFR 63 Subpart PPPP – National Emission Standards for Hazardous Air Pollutants for Surface Coating of Plastic Parts and Products). The affected units are F5, F26, F28, F41 and F42 and the facility has decided to show compliance through the emission rate without add-on controls option. Applicable subpart PPPP requirements are incorporated into the Emission-Point Specific Conditions Section. The facility shall also comply with all applicable requirements from 40 CFR 63 subpart A (General Provisions).

Authority for Requirement: 40 CFR 63 subpart PPPP  
567 IAC 23.1(4)"cp"

### III. Emission Point-Specific Conditions

Facility Name: Donaldson Company, Inc.  
Permit Number: **99-TV-043R3**

---

#### **Emission Point ID Number**

##### Associated Equipment

Associated Emission Unit ID Number: F4

---

Emission Unit vented through this Emission Point: F4  
Emission Unit Description: Plastisol Curing  
Raw Material/Fuel: Plastisol  
Rated Capacity: 83,333 lb/month (15.1 lb/hr)

#### **Applicable Requirements**

##### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from the emission point shall not exceed the levels specified below.*

There are no emission limits at this time.

##### **Operating Requirements with Associated Monitoring and Recordkeeping**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below. All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.*

##### Operating Limits:

- A. The maximum volatile organic compounds (VOC) content of the material used in this emission unit (EU F4) shall not exceed 5.0% (by weight).
- B. The maximum hazardous air pollutants (HAP) content of the material used in this emission unit (EU F4) shall not exceed 0.002% (by weight).
- C. The maximum amount of material used in this emission unit (EU F4) shall not exceed 1,000,000 pounds per twelve month rolling period.

Authority for Requirement: Iowa DNR Construction Permits 04-A-933-S3

- D. Demonstrate that, based on the coatings, thinners and/or other additives, and cleaning materials used in the coating operation(s), the organic HAP emission rate for the coating operation(s) is less than or equal to 0.31 kg/liter (2.6 lb/gal) coating solids, calculated as a rolling 12-month emission rate and determined on a monthly basis. All requirements of 40 CFR 63.3950, 3951, and 3952 must be met to demonstrate compliance.

Authority for Requirement: 40 CFR 63.3891(b)

Reporting & Record keeping:

- A. A list of materials used in this emission unit (EU F4).
- B. The volatile organic compounds (VOC) content (in weight %) of each material used in this emission unit (EU F4).
- C. The hazardous air pollutants (HAP) content (in weight %) of each material used in this emission unit (EU F4).
- D. A copy of the manufacturer or vendor provided information [i.e. Material Safety Data Sheet (MSDS), technical data sheets, etc.] for each material used in this emission unit (EU F4).
- E. The monthly amount of material used (in lbs/month) in this emission unit (EU F4).
- F. The 12-month rolling total of material used in this emission unit (EU F4).
- G. Any records required by 40 CFR §63.3930.

Authority for Requirement: Iowa DNR Construction Permits 04-A-933-S3

- H. Continuous compliance shall be demonstrated and reported and records maintained as specified in 40 CFR 63.3952.

Authority for Requirement: 40 CFR 63 Subpart M  
567 IAC 23.1(4)"cm"

NESHAP

Emission unit F4 is subject to Subpart A (General Provisions, 40 CFR §63.1 – 40 CFR §63.15) and Subpart M (National Emission Standards for Hazardous Air Pollutants for Surface Coating of Miscellaneous Metal Parts and Products, 40 CFR §63.3880 – 40 CFR §63.3981) of the National Emission Standards for Hazardous Air Pollutants (NESHAP).

Authority for Requirement: 40 CFR 63 Subpart M  
567 IAC 23.1(4)"cm"

**Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height, (ft, from the ground): Vents Inside

Stack Opening, (inches, dia.): Vents Inside

Exhaust Flow Rate (scfm): Vents Inside

Exhaust Temperature (°F): Vents Inside

Discharge Style: Vents Inside

Authority for Requirement: Iowa DNR Construction Permits 04-A-933-S3

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## Emission Point ID Numbers: 33A and 45

### Associated Equipment

Associated Emission Unit ID Numbers: See Table: Resistance Welding

Table: Resistance Welding

Emission Point Number	Associated Emission Unit Number	Emission Unit Description	Raw Material	Rated Capacity
33A	33A	Resistance Welding	Steel	0.00722 tons/hr
45	45	Resistance Welding	Steel	900 parts/hr

### Applicable Requirements

#### Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

*The emissions from each emission point shall not exceed the levels specified below.*

Table: Resistance Welding-Emission Limits

Emission Point Number	Associated Emission Unit Number	Opacity 567 IAC 23.3(2)"d"	PM 567 IAC 23.3(2)"a"	Authority for Requirement (Construction Permit Number)
33A	33A	40% <sup>(1)</sup>	0.1 gr./dscf	94-A-490-S3
45	45	40% <sup>(1)</sup>	0.1 gr./dscf	08-A-195

<sup>(1)</sup> An exceedance of the indicator opacity of (25%) will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

#### Operating Requirements with Associated Monitoring and Recordkeeping

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below. All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.*

None at this time.

**Emission Point Characteristics**

*These emission points shall conform to the specifications listed below.*

Table: Resistance Welding – Emission Point Characteristics

Emission Point Number	Authority for Requirement (Construction Permit No.)	Stack Characteristics				
		Height (ft from ground)	Diameter (inches)	Exhaust Flowrate	Exhaust Temp. (°F)	Discharge Style
33A	94-A-490-S3	26	12	1450 (acfm)	Ambient (70)	Vertical, Unobstructed
45	08-A-195	30	10	500 (scfm)	Ambient (70)	Vertical, Unobstructed

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## Emission Point ID Numbers: 19 and 33B

### Associated Equipment

Associated Emission Unit ID Numbers: See Table: Media Steamers

Table: Media Steamers

Emission Point Number	Associated Emission Unit Number	Emission Unit Description	Raw Material	Rated Capacity
19	19	Media Steamer	Filter Media/ Natural Gas	228 lb/hr/ 2 MMBtu
33B	33B	Media Steamer	Filter Media	1,200 lb/hr

### Applicable Requirements

#### Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

*The emissions from each emission point shall not exceed the levels specified below.*

Table: Media Steamers-Emission Limits

Emission Point Number	Associated Emission Unit Number	Opacity 567 IAC 23.3(2)"d"	PM (gr/dscf)	Authority for Requirement (Construction Permit Number)
19	19	40% <sup>(1)</sup>	0.1 <sup>(3)</sup>	95-A-196-S4
33B	33B	40% <sup>(2)</sup>	0.01 <sup>(4)</sup>	00-A-936-S2

<sup>(1)</sup> An exceedance of the indicator opacity of no visible emissions will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

<sup>(2)</sup> An exceedance of the indicator opacity of (10%) will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

<sup>(3)</sup> Additional Authority for Requirement: 567 IAC 23.3(2)"a"

<sup>(4)</sup> Additional Authority for Requirement: 567 IAC 23.4(13)

**Operating Requirements with Associated Monitoring and Recordkeeping**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below. All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.*

Process throughput:

- A. The maximum amount of "VOC-containing" filter media processed in these emission units, EU-19 and EU-33B, shall not exceed 2,000,000 pounds per twelve-month rolling period.
- B. The maximum VOC content of the filter media processed shall not exceed 0.5% by weight.
- C. The maximum total HAP content of the filter media processed shall not exceed 0.5% by weight.
- D. The owner or operator shall record on a monthly basis the amount of filter media processed in these emission units, EU-19 and EU-33B in pounds. The owner or operator of the facility shall calculate and record the monthly total and the 12-month rolling total.
- E. The owner or operator of the facility shall record the VOC and HAP content of any material used in these emission units, EU-19 and EU-33B in applicable units.
- F. The owner or operator shall maintain manufacturer/vendor provided information (i.e., Material Safety Data Sheets (MSDS), technical data sheets, etc.) of all materials used in these emission units, EU-19 and EU-33B.

Authority for Requirement: Iowa DNR Construction Permits 95-A-196-S4 and 00-A-936-S2

**Emission Point Characteristics**

*These emission points shall conform to the specifications listed below.*

Table: Media Steamers – Emission Point Characteristics

Emission Point Number	Authority for Requirement (Construction Permit No.)	Stack Characteristics				Discharge Style
		Height (feet)	Stack Opening (inches)	Exhaust Flowrate (scfm)	Exhaust Temp. (°F)	
19	95-A-196-S4	28	8	170	120	Vertical, Obstructed
33B	00-A-936-S2	25	30x30	7,276	120	Vertical, Obstructed

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## Emission Point ID Number: 24 and 25

### Associated Equipment

Associated Emission Unit ID Numbers: See Table: Natural Gas Boilers

Table: Natural Gas Boilers

Emission Point Number	Associated Emission Unit Number	Emission Unit Description	Raw Material	Rated Capacity (MMBtu/hr)
24	24	Natural Gas Boiler (South)	Natural Gas	14.5
25	25	Natural Gas Boiler (North)	Natural Gas	14.5

### Applicable Requirements

#### Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

*The emissions from these emission points shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit(s): 40%

Authority for Requirement: 567 IAC 23.3(2)"d"

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.8 lb./MMBtu

Authority for Requirement: 567 IAC 23.3(2)"b"

Pollutant: Sulfur Dioxide (SO<sub>2</sub>)

Emission Limit(s): 500 ppmv

Authority for Requirement: 567 IAC 23.3(3)

#### Operating Requirements with Associated Monitoring and Recordkeeping

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below. All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.*

#### NESHAP:

The boilers are subject to the National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters [40 CFR Part 63 Subpart DDDDD].

Authority for Requirement: 40 CFR Part 63 Subpart DDDDD

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## Emission Point ID Numbers: F41, F42, and F50

### Associated Equipment

Associated Emission Unit ID Numbers: See Table: Power Core

Table: Power Core

Emission Point Number	Associated Emission Unit Number	Emission Unit Description	Raw Material	Rated Capacity (lb/hr)	Construction Permit Number
F41	F41	Power Core (adhesive application)	Filter Media	500	02-A-655-S3
F42	F42	Power Core (adhesive application)	Filter Media	500	03-A-720-S2
F50	F50	Power Core (adhesive application)	Filter Media	500	12-A-037-S1

### Applicable Requirements

#### Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

*The emissions from each emission point shall not exceed the levels specified below.*

Emission Point Number	Opacity 567 IAC 23.3(2)"d"	PM (gr/dscf) 567 IAC 23.4(13)	Total HAP 567 IAC 23.1(4)"cp"	Authority for Requirement (Construction Permit Number)
F41	40% <sup>(1)</sup>	0.01	1.9 lb organic HAP/lb coating solid <sup>(2)</sup>	02-A-655-S3
F42	40% <sup>(1)</sup>	0.01	1.9 lb organic HAP/lb coating solid <sup>(2)</sup>	03-A-720-S2
F50	40% <sup>(1)</sup>	0.01	1.9 lb organic HAP/lb coating solid <sup>(2)</sup>	12-A-037-S1

<sup>(1)</sup> An exceedance of the indicator opacity of “no visible emissions” will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

<sup>(2)</sup> Per 40 CFR §63.4490(a)(1) the new general use coating affected source limit is for a 12-month rolling average basis.

#### Operating Requirements with Associated Monitoring and Recordkeeping

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below. All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.*

For emission units F41 and F42:

- A. The adhesive usage in emission units F41 and F42 shall not exceed 1,000,000 pounds per

twelve (12) month rolling period.

- B. The VOC content of all adhesive materials used in emission units F41 and F42 shall not exceed 2.0% by weight.
- C. The owner or operator shall record on a monthly basis the amount of adhesive material applied in emission units, F41 and F42, in pounds. The owner or operator shall calculate and record the monthly total and the 12-month rolling total.
- D. The owner or operator shall record the VOC content of any adhesive material applied in emission units, F41 and F42, in applicable units.
- E. The permit holder, owner and operator of the facility shall maintain an MSDS of all materials used in emission units F41 and F42.
- F. The owner or operator shall comply with all applicable requirements from 40 CFR Part 63, Subpart PPPP, National Emissions Standards for Hazardous Air Pollutants for Surface Coating of Plastic Parts and Products.
- G. As specified in §63.4500(b), the owner or operator shall always operate and maintain the affected sources, including air pollution control and monitoring equipment, according to the provisions in §63.6(e)(1)(i).
- H. The owner or operator shall follow one of the methods from §63.4491, Options for Meeting Standards, in order to demonstrate compliance with the organic HAP limits. The permittee shall maintain a record of the compliance option from Subpart PPPP is being used. At the time of permit issuance, the permittee is using §63.4491(b), Emission rate without add-on controls option. The necessary calculations must be completed within 30 days after the end of the month. The facility is allowed to change compliance options for Subpart PPPP; however, the permittee shall notify the Iowa DNR – Air Quality Bureau and DNR Field Office 1 in a compliance report if the compliance option has changed.
- I. The owner or operator shall submit all notifications required by §63.4510 of Subpart PPPP of Part 63.
- J. The owner or operator shall submit all reports required by §63.4520 of Subpart PPPP of Part 63.
- K. The owner or operator shall retain records in accordance with §63.4530. Records required by Subpart PPPP of Part 63 must be retained for a minimum of five years.

Authority for Requirement: Iowa DNR Construction Permits 02-A-655-S3 (F41) and 03-A-720-S2 (F42).

For emission unit 50

- A. The adhesive usage in this Power Core Adhesive Application operation (F50) shall not exceed 833,333 pounds per twelve (12) month period, rolled monthly.
- B. The VOC content of all adhesive materials used in this Power Core Adhesive Application operation (F50) shall not exceed 2.0% by weight.
- C. At the end of each month, record the amount (in pounds) of adhesive used in this Power Core Adhesive Application operation (F50) over the previous month.
- D. At the end of each month, record the amount (in pounds) of adhesive used in this Power Core Adhesive Application operation (F50) over the previous twelve (12) months.
- E. Maintain a copy of the MSDS or other vendor's documentation showing the VOC content of all adhesive materials used in this Power Core Adhesive Application operation (F50).
- F. The owner or operator shall comply with all applicable requirements from 40 CFR Part 63, Subpart PPPP, National Emissions Standards for Hazardous Air Pollutants for Surface Coating of Plastic Parts and Products.
- G. As specified in §63.4500(b), the owner or operator shall always operate and maintain the affected sources, including air pollution control and monitoring equipment, according to the provisions in §63.6(e)(1)(i).
- H. The owner or operator shall follow one of the methods from §63.4491, Options for Meeting Standards, in order to demonstrate compliance with the organic HAP limits. The permittee shall maintain a record of the compliance option from Subpart PPPP is being used. At the time of permit issuance, the permittee is using §63.4491(b), Emission rate without add-on controls option. The necessary calculations must be completed within 30 days after the end of the month. The facility is allowed to change compliance options for Subpart PPPP; however, the permittee shall notify the Iowa DNR – Air Quality Bureau and DNR Field Office 1 in a compliance report if the compliance option has changed.
- I. The owner or operator shall submit all notifications required by §63.4510 of Subpart PPPP of Part 63.
- J. The owner or operator shall submit all reports required by §63.4520 of Subpart PPPP of Part 63.
- K. The owner or operator shall retain records in accordance with §63.4530. Records required by Subpart PPPP of Part 63 must be retained for a minimum of five years.

Authority for Requirement: Iowa DNR Construction Permit 12-A-037-S1

**Emission Point Characteristics**

*These emission points shall conform to the specifications listed below.*

Table: Power Core -Emission Point Characteristics

Emission Point Number	Authority for Requirement (Construction Permit No.)	Stack Characteristics				
		Height (feet from ground)	Diameter (inches)	Exhaust Flowrate (scfm)	Exhaust Temp. (°F)	Discharge Style
F41	02-A-655-S3	Vents Inside	Vents Inside	Vents Inside	70	Vents Inside
F42	03-A-720-S2	Vents Inside	Vents Inside	Vents Inside	70	Vents Inside
F50	12-A-037-S1	31.5 <sup>(1)</sup>	14 <sup>(1)</sup>	1,500 <sup>(1)</sup>	250 <sup>(1)</sup>	Vertical Unobstructed <sup>(1)</sup>

<sup>(1)</sup>Construction Permit 12-A-037-S1 incorrectly lists the above stack characteristics. The stack actually vents internally.

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

**NESHAP**

These emission units (F41, F42, and F50) are subject to Subpart A (General Provisions, 40 CFR §63.1 – 40 CFR §63.15) and Subpart P (National Emission Standards for Hazardous Air Pollutants for Surface Coating of Plastic Parts and Products, 40 CFR §63.4480 – 40 CFR §63.4581) of the National Emission Standards for Hazardous Air Pollutants (NESHAP).

Authority for Requirement: Iowa DNR Construction Permits 02-A-655-S3, 03-A-720-S2 and 12-A-037-S1.

40 CFR Part 63 Subpart P  
567 IAC 23.1(4)“cp”

**Monitoring Requirements**

**Agency Approved Operation & Maintenance Plan Required?** Yes  No

**Facility Maintained Operation & Maintenance Plan Required?** Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?** Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## Emission Point ID Numbers: 50, 51, 55, and 56

### Associated Equipment

Associated Emission Unit ID Numbers: See Table: Curing Ovens

Table: Curing Ovens

Emission Point Number	Associated Emission Unit Number	Emission Unit Description	Raw Material	Rated Capacity
50	50	Curing Oven 1	Filter Media/ Natural Gas	450 lb/hr/ 2 MMBtu/hr
51	51	Curing Oven 2	Filter Media/ Natural Gas	450 lb/hr/ 2 MMBtu/hr
55	55	Curing Oven 3	Filter Media/ Natural Gas	450 lb/hr/ 2 MMBtu/hr
56	56	Curing Oven 4	Filter Media/ Natural Gas	450 lb/hr/ 2 MMBtu/hr

### Applicable Requirements

#### Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

*The emissions from these emission points shall not exceed the levels specified below.*

Table: Curing Ovens-Emission Limits

Emission Point Number	Opacity 567 IAC 23.3(2)" d"	PM (gr./dscf) 567 IAC 23.3(2)"a"	VOC (tpy)	Single HAP (tpy)	Total HAP (tpy)	SO <sub>2</sub> (ppmv) 567 IAC 23.3(3)"e "	Authority for Requirement (Construction Permit Number)
50	40% <sup>(1)</sup>	0.1	120 <sup>(2)</sup>	9.4 <sup>(2)</sup>	24.4 <sup>(2)</sup>	500	12-A-361-S3
51	40% <sup>(1)</sup>	0.1	120 <sup>(2)</sup>	9.4 <sup>(2)</sup>	24.4 <sup>(2)</sup>	500	12-A-362-S3
55	40% <sup>(1)</sup>	0.1	120 <sup>(2)</sup>	9.4 <sup>(2)</sup>	24.4 <sup>(2)</sup>	500	18-A-104
56	40% <sup>(1)</sup>	0.1	120 <sup>(2)</sup>	9.4 <sup>(2)</sup>	24.4 <sup>(2)</sup>	500	18-A-105

<sup>(1)</sup> An exceedance of the indicator opacity of “no visible emissions” will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

<sup>(2)</sup>The emission limit is for the combined emissions from emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.

### **Operating Requirements with Associated Monitoring and Recordkeeping**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below. All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.*

- A. The owner or operator shall not exceed 320,000 pounds per twelve (12) month rolling period of VOC containing resin polymer used in emission units EU-46, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- B. The owner or operator shall record on a monthly basis the amount of VOC containing resin polymer used in emission units EU-46, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56 in units of pounds.
- C. The owner or operator shall recover a minimum of 50 percent of the VOC containing resin polymer used in emission units EU-46, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- D. The owner or operator shall record on a monthly basis the amount of VOC containing resin polymer recovered (and disposed of offsite) from emission units EU-48, EU-49, EU-53, and EU-54 in units of pounds.
- E. The owner or operator shall not exceed 15,800,000 pounds per twelve (12) month rolling period of VOC containing substrate in emission units EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- F. The owner or operator shall record on a monthly basis the amount of VOC containing substrate used in emission units EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56, in pounds.
- G. The owner or operator shall not use VOC containing substrate with a VOC content in excess of 0.5% by weight, or be able to demonstrate that the weighted average VOC content of substrate processed is 0.5% or less in emission units EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56. The weighted average shall be calculated as the total weight of VOC in the processed substrate divided by the total weight of substrate processed in that calendar month.
- H. The owner or operator shall not exceed 3,740,000 pounds per twelve (12) month rolling period of HAP containing substrate in emission units EU-47, EU-48, EU-49, EU-50, and EU-51.
- I. The owner or operator shall record on a monthly basis the amount of HAP containing substrate used in emission units EU-47, EU-48, EU-49, EU-50, and EU-51, in pounds.
- J. The owner or operator shall not use HAP containing substrate with a total HAP content in excess of 0.5% by weight, or be able to demonstrate that the weighted average total HAP content of substrate processed is 0.5% or less in emission units EU-47, EU-48, EU-49,

EU-50, and EU-51. The weighted average shall be calculated as the total weight of total HAP in the processed substrate divided by the total weight of substrate processed in that calendar month.

- K. The owner or operator shall not exceed 320,000 pounds per twelve (12) month rolling period of HAP containing resin polymer in emission units EU-47, EU-48, EU-49, EU-50, and EU-51.
- L. The owner or operator shall record on a monthly basis the amount of HAP containing resin polymer used in emission units EU-47, EU-48, EU-49, EU-50, and EU-51, in pounds.
- M. The owner or operator shall not use HAP containing resin polymer with a total HAP content in excess of 6.0% by weight.
- N. The owner or operator shall not use HAP containing resin polymer with a SHAP content in excess of 5.4% by weight.
- O. The owner or operator shall not use formaldehyde (CAS number 50-00-0) containing resin polymer with a content in excess of 0.01% by weight.
- P. The owner or operator shall assume all HAPs of HAP containing resin polymer and substrate used in emission units EU-46, EU-47, EU-48, EU-49, EU-50, and EU-51 are emitted to the atmosphere. If the facility chooses to take credit for HAPs recovered in waste then the facility shall characterize the HAP content of recovered waste from emission units EU-48, EU-49, EU-50, and EU-51.
- Q. The owner or operator shall maintain an inventory of SDS for all resin polymer and substrate used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.

Authority for Requirements: DNR Construction Permits 12-A-361-S3, 12-A-362-S3, 18-A-104, 18-A-105

**Emission Point Characteristics**

*These emission points shall conform to the specifications listed below.*

Table: Curing Ovens-Emission Point Characteristics

Emission Point Number	Authority for Requirement (Construction Permit Number)	Stack Characteristics				
		Height (feet)	Diameter (inches)	Exhaust Flowrate (scfm)	Exhaust Temp. (°F)	Discharge Style
50	12-A-361-S3	31.5	14	1,500	250	Vertical, Unobstructed
51	12-A-362-S3	31.5	14	1,500	250	Vertical, Unobstructed
55	18-A-104	31.5	14	2,180	295	Vertical, Unobstructed
56	18-A-105	31.5	14	2,180	295	Vertical, Unobstructed

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

**Emission Point ID Numbers: 48A, 48B, 49A, 49B, 53A, 53B, 54A, and 54B**

Associated Equipment

Associated Emission Unit ID Numbers: See Table: Ultra Web Lines

Table: Ultra Web Lines

Emission Point Number	Associated Emission Unit Number	Emission Unit Description	Raw Material	Rated Capacity
48A	48	Ultra Web Line 1	Substrate/ Polymer	450 lb/hr/ 8.82 lb/hr
48B				
49A	49	Ultra Web Line 2	Substrate/ Polymer	450 lb/hr/ 8.82 lb/hr
49A				
53A	53	Ultra Web Line 3	Substrate/ Polymer	450 lb/hr/ 8.82 lb/hr
53B				
54A	54	Ultra Web Line 4	Substrate/ Polymer	450 lb/hr/ 8.82 lb/hr
54B				

**Applicable Requirements**

**Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from these emission points shall not exceed the levels specified below.*

Table: Ultra Web Lines-Emission Limits

Emission Point Number	Opacity 567 IAC 23.3(2)"d"	PM (gr./dscf) 567 IAC 23.4(13)	VOC (tpy)	Single HAP (tpy)	Total HAP (tpy)	Authority for Requirement (Construction Permit No)
48A	40% <sup>(1)</sup>	0.01	120 <sup>(2)</sup>	9.4 <sup>(2)</sup>	24.4 <sup>(2)</sup>	12-A-366-S3
48B	40% <sup>(1)</sup>	0.01	120 <sup>(2)</sup>	9.4 <sup>(2)</sup>	24.4 <sup>(2)</sup>	12-A-365-S3
49A	40% <sup>(1)</sup>	0.01	120 <sup>(2)</sup>	9.4 <sup>(2)</sup>	24.4 <sup>(2)</sup>	12-A-368-S3
49B	40% <sup>(1)</sup>	0.01	120 <sup>(2)</sup>	9.4 <sup>(2)</sup>	24.4 <sup>(2)</sup>	12-A-367-S3
53A	40% <sup>(1)</sup>	0.01	120 <sup>(2)(3)</sup>	9.4 <sup>(2)</sup>	24.4 <sup>(2)</sup>	18-A-100
53B	40% <sup>(1)</sup>	0.01	120 <sup>(2)</sup>	9.4 <sup>(2)</sup>	24.4 <sup>(2)</sup>	18-A-101
54A	40% <sup>(1)</sup>	0.01	120 <sup>(2)</sup>	9.4 <sup>(2)</sup>	24.4 <sup>(2)</sup>	18-A-102
54B	40% <sup>(1)</sup>	0.01	120 <sup>(2)</sup>	9.4 <sup>(2)</sup>	24.4 <sup>(2)</sup>	18-A-103

<sup>(1)</sup> An exceedance of the indicator opacity of “no visible emissions” will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

<sup>(2)</sup>The emission limit is for the combined emissions from emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.

<sup>(3)</sup> DNR Construction Permit 18-A-100 mistakenly specified VOC limit of 112.0 tpy.

### **Operating Requirements with Associated Monitoring and Recordkeeping**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below. All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

- A. The owner or operator shall not exceed 320,000 pounds per twelve (12) month rolling period of VOC containing resin polymer used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- B. The owner or operator shall record on a monthly basis the amount of VOC containing resin polymer used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56 in units of pounds.
- C. The owner or operator shall recover a minimum of 50 percent of the VOC containing resin polymer used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- D. The owner or operator shall record on a monthly basis the amount of VOC containing resin polymer recovered (and disposed of offsite) from emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- E. The owner or operator shall not exceed 15,800,000 pounds per twelve (12) month rolling period of VOC containing substrate in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- F. The owner or operator shall record on a monthly basis the amount of VOC containing substrate used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56 in pounds.
- G. The owner or operator shall not use VOC containing substrate with a VOC content in excess of 0.5% by weight, or be able to demonstrate that the weighted average VOC content of substrate processed is 0.5% or less in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56. The weighted average shall be calculated as the total weight of VOC in the processed substrate divided by the total weight of substrate processed in that calendar month.
- H. The owner or operator shall not exceed 3,740,000 pounds per twelve (12) month rolling period of HAP containing substrate in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- I. The owner or operator shall record on a monthly basis the amount of HAP containing substrate used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56, in pounds.
- J. The owner or operator shall not use HAP containing substrate with a total HAP content in

excess of 0.5% by weight, or be able to demonstrate that the weighted average total HAP content of substrate processed is 0.5% or less in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56. The weighted average shall be calculated as the total weight of total HAP in the processed substrate divided by the total weight of substrate processed in that calendar month.

- K. The owner or operator shall not exceed 320,000 pounds per twelve (12) month rolling period of HAP containing resin polymer in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- L. The owner or operator shall record on a monthly basis the amount of HAP containing resin polymer used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56., in pounds.
- M. The owner or operator shall not use HAP containing resin polymer with a total HAP content in excess of 6.0% by weight.
- N. The owner or operator shall not use HAP containing resin polymer with a SHAP content in excess of 5.4% by weight.
- O. The owner or operator shall not use formaldehyde (CAS number 50-00-0) containing resin polymer with a content in excess of 0.01% by weight.
- P. The owner or operator shall assume all HAPs of HAP containing resin polymer and substrate used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56 are emitted to the atmosphere. If the facility chooses to take credit for HAPs recovered in waste then the facility shall characterize the HAP content of recovered waste from emission units EU-48, EU-49, EU-50, and EU-51.
- Q. The owner or operator shall maintain an inventory of SDS for all resin polymer and substrate used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.

**Emission Point Characteristics**

*These emission points shall conform to the specifications listed below.*

Table: Ultra Web Lines – Emission Point Characteristics

Emission Point Number	Associated Emission Unit Number	Authority for Requirement (Construction Permit No.)	Stack Characteristics				Discharge Style
			Height (feet)	Opening (inches)	Exhaust Flowrate (scfm)	Exhaust Temp. (°F)	
48A	48	12-A-366-S3	31	9.5 x 12	1500	70	Downward
48B		12-A-365-S3	31	9.5 x 12	1500	70	Downward
49A	49	12-A-368-S3	31	9.5 x 12	1500	70	Downward
49B		12-A-367-S3	31	9.5 x 12	1500	70	Downward
53A	53	18-A-100	31	9.5 x 12	1500	70	Downward
53B		18-A-101	31	9.5 x 12	1500	70	Downward
54A	54	18-A-102	31	9.5 x 12	1500	70	Downward
54B		18-A-103	31	9.5 x 12	1500	70	Downward

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## **Emission Point ID Number: 6**

### Associated Equipment

Associated Emission Unit ID Numbers: 6

---

Emission Unit vented through this Emission Point: 6

Emission Unit Description: Ribbon Bonder

Raw Material/Fuel: Plastisol

Rated Capacity: 43.1 lb/hr

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit: 40% <sup>(1)</sup>

Authority for Requirement: Iowa DNR Construction Permit 95-A-187-S1

567 IAC 23.3(2)"d"

<sup>(1)</sup> An exceedance of the indicator opacity of (10%) will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit: 0.01 gr/scf

Authority for Requirement: Iowa DNR Construction Permit 95-A-187-S1

567 IAC 23.4(13)

#### **Operating Requirements with Associated Monitoring and Recordkeeping**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below. All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.*

Process throughput:

- A. The maximum amount of bonding material (plastisol) utilized in this emission unit, EU-6, shall not exceed 377,731 pounds per twelve-month rolling period.
- B. The maximum VOC content of bonding material utilized shall not exceed 2.0%, by weight.
- C. The maximum HAP content of the bonding material utilized shall not exceed 0.1% by weight.

Authority for Requirement: Iowa DNR Construction Permit 95-A-187-S1

- D. Demonstrate that, based on the coatings, thinners and/or other additives, and cleaning materials used in the coating operation(s), the organic HAP emission rate for the coating operation(s) is less than or equal to 0.31 kg/liter (2.6 lb/gal) coating solids, calculated as a rolling 12-month emission rate and determined on a monthly basis. All requirements of 40 CFR 63.3950, 3951, and 3952 must be met to demonstrate compliance.

Authority for Requirement: 40 CFR 63.3891(b)  
567 IAC 23.1(4)"cm"

Reporting & Record keeping:

- A. The permit holder, owner and operator of the facility shall record on a monthly basis the amount of bonding material utilized in the emission unit, EU-6, in pounds. The permit holder, owner and operator of the facility shall calculate and record the monthly total and the 12-month rolling total.
- B. The permit holder, owner and operator of the facility shall record the VOC and HAP content of any bonding material utilized in emission unit, EU-6, in applicable units.
- C. The permit holder, owner and operator of the facility shall maintain an MSDS of all materials used in this emission unit, EU-6.

Authority for Requirement: Iowa DNR Construction Permit 95-A-187-S1

- D. Continuous compliance shall be demonstrated and reported and records maintained as specified in 40 CFR 63.3952.

Authority for Requirement: 40 CFR 63 Subpart M  
567 IAC 23.1(4)"cm"

NESHAP

This emission unit is subject to Subpart A (General Provisions, 40 CFR §63.1 – 40 CFR §63.15) and Subpart M (National Emission Standards for Hazardous Air Pollutants for Surface Coating of Miscellaneous Metal Parts and Products, 40 CFR §63.3880 – 40 CFR §63.3981) of the National Emission Standards for Hazardous Air Pollutants (NESHAP).

Authority for Requirement: 40 CFR 63.3891(b)  
567 IAC 23.1(4)"cm"

**Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height, (ft, from the ground): 30

Stack Opening, (inches, dia.): 18

Exhaust Flow Rate (acfm): 1,413

Exhaust Temperature (°F): 425

Discharge Style: Vertical Obstructed

Authority for Requirement: Iowa DNR Construction Permit 95-A-187-S1

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**                      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**                      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**                      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## **Emission Point ID Number: 29A**

### Associated Equipment

Associated Emission Unit ID Numbers: 29A

---

Emission Unit vented through this Emission Point: 29A  
Emission Unit Description: Diesel Engine Fire Pump  
Raw Material/Fuel: Diesel fuel  
Rated Capacity: 170 hp

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity  
Emission Limit(s): 40%  
Authority for Requirement: 567 IAC 23.3(2)"d"

Pollutant: Particulate Matter (PM)  
Emission Limit(s): 0.1 gr./dscf  
Authority for Requirement: 567 IAC 23.3(1)"a"

Pollutant: Sulfur Dioxide (SO<sub>2</sub>)  
Emission Limit(s): 2.5 lb./MMBtu  
Authority for Requirement: 567 IAC 23.3(3)"b"

#### **Operating Requirements with Associated Monitoring and Recordkeeping**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below. All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.*

- A. No person shall allow, cause or permit the combustion of number 1 or number 2 fuel oil exceeding a sulfur content of 0.5 percent by weight.  
Authority for Requirement: 567 IAC 23.3(3)"b"(1)
  
- B. The facility shall monitor the percent of sulfur by weight in the fuel oil as delivered. The documentation may be vendor supplied or facility generated.  
Authority for Requirement: 567 IAC 22.108(3)

### NESHAP:

The emergency engine is subject to 40 CFR 63 Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE). According to 40 CFR 63.6590(a)(1)(ii) this compression ignition emergency engine, located at a major source, is an existing stationary RICE as it was constructed prior to June 12, 2006.

### Operation and Maintenance Requirements 40 CFR 63.6602, 63.6625, 63.6640 and Tables 2c and 6 to Subpart ZZZZ

1. Change oil and filter every 500 hours of operation or annually, whichever comes first. (See 63.6625(i) for the oil analysis option to extend time frame of requirements.)
2. Inspect air cleaner every 1000 hours of operation or annually, whichever comes first, and replace as necessary.
3. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.
4. Operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.
5. Install a non-resettable hour meter if one is not already installed.
6. Minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes.

### Operating Limits 40 CFR 63.6640(f)

1. Any operation other than emergency operation, maintenance and testing and operation in non-emergency situations (*up to*) 50 hours per year is prohibited.
2. There is no time limit on the use of emergency stationary RICE in emergency situations.
3. You may operate your emergency stationary RICE up to 100 combined hours per calendar year for maintenance checks and readiness testing. See 40 CFR 63.6640(f)(2) for additional information and restrictions.
4. You may operate your emergency stationary RICE up to 50 hours per calendar year for non-emergency situations, but those 50 hours are counted toward the 100 hours of maintenance and testing. The 50 hours per year for non-emergency situations cannot be used for peak shaving, or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

### Recordkeeping Requirements 40 CFR 63.6655

1. Keep records of the maintenance conducted on the stationary RICE.
2. Keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. Document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation. See 40 CFR 63.6655(f) for additional information.

### Notification and Reporting Requirements 40 CFR 63.6645, 63.6650 and Table 2c to Subpart ZZZZ

1. An initial notification is not required per 40 CFR 63.6645(a)(5).

2. A report may be required for failure to perform the work practice requirements on the schedule required in Table 2c. (See Footnote 1 of Table 2c for more information.)

Authority for Requirement: 40 CFR Part 63 Subpart ZZZZ  
567 IAC 23.1(4)"cz"

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## Emission Point ID Number: 40 and 52

### Associated Equipment

Associated Emission Unit ID Numbers: See Table: Thermoplastic Resin Injection Modeling Machines

Table: Thermoplastic Resin Injection Modeling Machines

<b>Emission Point Number</b>	<b>Associated Emission Unit Number</b>	<b>Emission Unit Description</b>	<b>Raw Material</b>	<b>Rated Capacity</b>	<b>Construction Permit Number (Authority for Requirement)</b>
40	40a	Thermoplastic Resin Injection Modeling Machine	Thermoplastic Resin	349 lb/hr	02-A-654-S3
	40b	Thermoplastic Resin Injection Modeling Machine	Thermoplastic Resin	318 lb/hr	
	40c	Thermoplastic Resin Injection Modeling Machine	Thermoplastic Resin	402 lb/hr	
	40d	Thermoplastic Resin Injection Modeling Machine	Thermoplastic Resin	683 lb/hr	
	40e	Thermoplastic Resin Injection Modeling Machine	Thermoplastic Resin	780 lb/hr	
	40f	Thermoplastic Resin Injection Modeling Machine	Thermoplastic Resin	349 lb/hr	
	40g	Thermoplastic Resin Injection Modeling Machine	Thermoplastic Resin	349 lb/hr	
	40h	Thermoplastic Resin Injection Modeling Machine	Thermoplastic Resin	402 lb/hr	
52	52A	Thermoplastic Resin Injection Modeling Machine	Thermoplastic Resin	353 lb/hr	18-A-099
	52B	Thermoplastic Resin Injection Modeling Machine	Thermoplastic Resin	564 lb/hr	

## Applicable Requirements

### Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from these emission points shall not exceed the levels specified below.

<b>Emission Point Number</b>	<b>Opacity</b> 567 IAC 23.3(2)"d"	<b>PM</b> (gr./dscf) 567 IAC 23.2(2)"a"	<b>PM</b> (lb/hr)	<b>PM<sub>10</sub></b> (lb/hr)	<b>Authority for Requirement</b> (Construction Permit No)
40	40% <sup>(1)</sup>	0.1	0.25	0.25	02-A-654-S3
52	40% <sup>(1)</sup>	0.1			18-A-099

<sup>(1)</sup>An exceedance of the indicator opacity of no visible emissions will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

### Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Table: Thermoplastic Resin Injection Modeling Machines – Emission Point Characteristics

<b>Emission Point Number</b>	<b>Authority for Requirement</b> (Construction Permit No.)	<b>Stack Characteristics</b>				<b>Discharge Style</b>
		<b>Height</b> (feet from the ground)	<b>Opening</b> (inches)	<b>Exhaust Flowrate</b> (scfm)	<b>Exhaust Temp.</b> (°F)	
40	02-A-654-S3	36	18	7500	80	Vertical Unobstructed
52	18-A-099	36	28	6300	80	Vertical Unobstructed

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

### Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## **Emission Point ID Number: 43**

### Associated Equipment

Associated Emission Unit ID Numbers: 43

---

Emission Unit vented through this Emission Point: 43  
Emission Unit Description: Hot Plate Welding  
Raw Material/Fuel: Plastic Parts  
Rated Capacity: 60 pieces/hr

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit: 40% <sup>(1)</sup>

Authority for Requirement: Iowa DNR Construction Permit 09-A-748-S4  
567 IAC 23.3(2)"d"

<sup>(1)</sup> An exceedance of the indicator opacity of 10% will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter

Emission Limit: 0.1 gr/scf

Authority for Requirement: Iowa DNR Construction Permit 09-A-748-S4  
567 IAC 23.2(2)"a"

Pollutant: Particulate Matter

Emission Limit: 0.25 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 09-A-748-S4

Pollutant: PM<sub>10</sub>

Emission Limit: 0.25 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 09-A-748-S4

**Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height, (ft, from the ground): 33

Stack Opening, (inches, dia.): 22

Exhaust Flow Rate (scfm): 3,200

Exhaust Temperature (°F): 80

Discharge Style: Vertical Unobstructed

Authority for Requirement: Iowa DNR Construction Permit 09-A-748-S4

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**                      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**                      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**                      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

**Emission Point ID Number: F1**

Associated Equipment

Associated Emission Unit ID Numbers: F1

Emission Unit vented through this Emission Point: F1

Emission Unit Description: Seam Seal

Raw Material/Fuel: Adhesives

Rated Capacity: 12.2 lb./hr

Adhesive application and molding

**Applicable Requirements**

**Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

There are no emission limits at this time.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## **Emission Point ID Number: F5**

### Associated Equipment

Associated Emission Unit ID Numbers: F5

---

Emission Unit vented through this Emission Point: F5

Emission Unit Description: End Cap Printing

Raw Material/Fuel: Ink and Solvents

Rated Capacity: 0.103 gal./hr

### **Applicable Requirements**

#### **Operating Requirements with Associated Monitoring and Recordkeeping**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below. All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.*

Process throughput:

1. The maximum amount of material used in this emission unit, F-5, shall not exceed 900 gallons per twelve-month rolling period.

Authority for Requirement: Iowa DNR Construction Permit 04-A-934-S1

2. Demonstrate that, based on the coatings, thinners and/or other additives, and cleaning materials used in the coating operation(s), the organic HAP emission rate for the coating operation(s) is less than or equal to 0.16 kg/kg (0.16 lb/lb) coating solids for the coating of plastics and 0.31 kg/liter (2.6 lb/gal) coating solids for the coating of metals, calculated as a rolling 12-month emission rate and determined on a monthly basis. All requirements of 40 CFR 63.4550, 4551, and 4552 must be met to demonstrate compliance for the coating of plastics and all requirements of 40 CFR 63.3950, 3951, and 3952 must be met to demonstrate compliance for the coating of metals.

Authority for Requirement: 40 CFR 63.4491(b) and 40 CFR 63.3891(b)  
567 IAC 23.1(4)"cm" and 567 IAC 23.1(4)"cp"

Reporting & Record keeping:

1. The permit holder, owner and operator of the facility shall record on a monthly basis the amount of material used in this emission unit, F-5, in gallons. The permit holder, owner and operator of the facility shall calculate and record the monthly total and the 12-month rolling total.
2. The permit holder, owner and operator of the facility shall record the VOC and HAP content of any material used in this emission unit, F-5.
3. The permit holder, owner and operator of the facility shall maintain an MSDS of all materials used in this emission unit, F-5.

Authority for Requirement: Iowa DNR Construction Permit 04-A-934-S1

4. Continuous compliance shall be demonstrated and reported and records maintained as specified in 40 CFR 63.4552 and 40 CFR 63.3952.

Authority for Requirement: 40 CFR 63 Subpart PPPP and 40 CFR 63 Subpart MMMM

**NESHAP**

This emission unit is subject to Subpart A (General Provisions, 40 CFR §63.1 – 40 CFR §63.15), Subpart MMMM (National Emission Standards for Hazardous Air Pollutants for Surface Coating of Miscellaneous Metal Parts and Products, 40 CFR §63.3880 – 40 CFR §63.3981) and Subpart PPPP (National Emission Standards for Hazardous Air Pollutants for Surface Coating of Plastic Parts and Products, 40 CFR §63.4480 – 40 CFR §63.4581) of the National Emission Standards for Hazardous Air Pollutants (NESHAP).

Authority for Requirement: 40 CFR Part 63 Subpart MMMM and 40 CFR Part 63 Subpart PPPP 567 IAC 23.1(4)“cm” and 567 IAC 23.1(4)“cp”

**Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height, (ft, from the ground): Indoor Venting

Stack Opening, (inches, dia.): Indoor Venting

Exhaust Flow Rate (scfm): Indoor Venting

Exhaust Temperature (°F): Ambient

Discharge Style: Indoor Venting

Authority for Requirement: Iowa DNR Construction Permit 04-A-934-S1

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?** Yes  No

**Facility Maintained Operation & Maintenance Plan Required?** Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?** Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## **Emission Point ID Number: F11**

### Associated Equipment

Associated Emission Unit ID Numbers: F11

---

Emission Unit vented through this Emission Point: F11

Emission Unit Description: Mold Release (fugitive)

Raw Material/Fuel: Mold Release

Rated Capacity: 0.799 lb./hr

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

There are no emission limits at this time.

#### **Operating Requirements with Associated Monitoring and Recordkeeping**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below. All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.*

Process throughput:

1. The maximum amount of material used in this operation (EP F11) shall not exceed 3,500 pounds per twelve-month rolling period.

Reporting & Record keeping:

1. The owner or operator shall record on a monthly basis the amount of material used in this emission point (EP F11) in pounds. The owner and operator shall calculate and record the monthly total and the 12-month rolling total.
2. The owner or operator shall record the VOC and HAP content of any material used in this emission point (EP F11) in applicable units.
3. The owner or operator shall maintain manufacturer/vendor provided information (i.e., Material Safety Data Sheets (MSDS), technical data sheets, etc.) of all materials used in this emission point (EP F11).

Authority for Requirement: Iowa DNR Construction Permit 06-A-445-S1

**Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height, (ft, from the ground): Vents inside

Stack Opening, (inches, dia.): Vents inside

Exhaust Flow Rate (scfm): Vents inside

Exhaust Temperature (°F): Vents inside

Discharge Style: Vents inside

Authority for Requirement: Iowa DNR Construction Permit 06-A-445-S1

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**                      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**                      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**                      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## **Emission Point ID Number: F20**

### Associated Equipment

Associated Emission Unit ID Numbers: F20

---

Emission Unit vented through this Emission Point: F20  
Emission Unit Description: General Adhesive Application  
Raw Material/Fuel: Adhesive  
Rated Capacity: 18.50 lb/hr

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit(s): 40%

Authority for Requirement: Iowa DNR Construction Permit 04-A-935  
567 IAC 23.3(2)"d"

#### **Operating Requirements with Associated Monitoring and Recordkeeping**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below. All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.*

Process throughput:

1. Materials used in this operation shall be limited to a maximum of 41,650 pounds per twelve- month rolling period.
2. Each material used in this operation shall have a maximum VOC content of 48%, by weight.

Authority for Requirement: Iowa DNR Construction Permit 04-A-935

3. Demonstrate that, based on the coatings, thinners and/or other additives, and cleaning materials used in the coating operation(s), the organic HAP emission rate for the coating operation(s) is less than or equal to 0.31 kg/liter (2.6 lb/gal) coating solids, calculated as a rolling 12-month emission rate and determined on a monthly basis. All requirements of 40 CFR 63.3950, 3951, and 3952 must be met to demonstrate compliance.

Authority for Requirement: 40 CFR 63.3891(b)  
567 IAC 23.1(4)"cm"

Reporting & Record keeping:

1. The owner or operator shall maintain a Material Safety Data Sheet (MSDS) that shows the VOC content of all materials used in this operation.

2. The owner or operator shall maintain a record of the amount of materials used in this operation each month. Each month the owner or operator shall calculate a twelve-month rolling total of materials used in this operation.

Authority for Requirement: Iowa DNR Construction Permit 04-A-935

3. Continuous compliance shall be demonstrated and reported and records maintained as specified in 40 CFR 63.3952.

Authority for Requirement: 40 CFR 63 Subpart M  
567 IAC 23.1(4) "cm"

NESHAP

This emission unit is subject to Subpart A (General Provisions, 40 CFR §63.1 – 40 CFR §63.15) and Subpart M (National Emission Standards for Hazardous Air Pollutants for Surface Coating of Miscellaneous Metal Parts and Products, 40 CFR §63.3880 – 40 CFR §63.3981) of the National Emission Standards for Hazardous Air Pollutants (NESHAP).

Authority for Requirement: 40 CFR 63 Subpart M  
567 IAC 23.1(4) "cm"

**Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height, (ft, from the ground): Indoor Venting

Stack Opening, (inches, dia.): Indoor Venting

Exhaust Flow Rate (scfm): Indoor Venting

Exhaust Temperature (°F): Ambient (70)

Discharge Style: Indoor Venting

Authority for Requirement: Iowa DNR Construction Permit 04-A-935

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## **Emission Point ID Number: F26**

### Associated Equipment

Associated Emission Unit ID Numbers: F26, F28

---

Emission Unit vented through this Emission Point: F26  
Emission Unit Description: Adhesive Application  
Raw Material/Fuel: Adhesive (Pleat Spacing Material)  
Rated Capacity: 119.18 lb/hr

Emission Unit vented through this Emission Point: F28  
Emission Unit Description: Molding  
Raw Material/Fuel: Urethane Components  
Rated Capacity: 333 lb./hr

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Volatile Organic Compounds (VOC)  
Emission Limit(s): 26.1 tons/yr  
Authority for Requirement: Iowa DNR Construction Permit 06-A-061-S1

#### **Operating Requirements with Associated Monitoring and Recordkeeping**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below. All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.*

#### Process throughput:

1. The maximum VOC content of any material used in these emission sources (EU F-26 and EU F-28) shall not exceed 5.0% by weight.
2. The amount of VOC containing material used in these emission sources (EU F-26 and EU F-28) shall not exceed 522 tons per twelve month rolling period.
3. The owner or operator shall follow the requirements of Subpart MMMM, 40 CFR 63.3880 through 63.3981 or Subpart PPPP, 40 CFR 63.4480 through 63.4581 as applicable.

#### Reporting & Record keeping:

1. The owner or operator shall keep Material Safety Data Sheets (MSDS) of each VOC containing material used in these emission sources (EU F-26 and EU F-28). For materials where the effective VOC emission rate is less than 1% due to the vapor

pressure and conditions in which it is used, include a copy of the letter from the manufacturer stating the reasoning along with the MSDS.

2. The owner or operator shall keep records of the amount of VOC containing material used in EU F-26 and EU F-28, and update the twelve-month rolling total on a monthly basis.
3. The owner or operator shall follow the requirements of Subpart MMMM, 40 CFR 63.3880 through 63.3981 or Subpart PPPP, 40 CFR 63.4480 through 63.4581, as applicable.

Authority for Requirement: Iowa DNR Construction Permit 06-A-061-S1

### NESHAP

Emission units F 26 and F28 are subject to Subpart A (General Provisions, 40 CFR §63.1 – 40 CFR §63.15), Subpart MMMM (National Emission Standards for Hazardous Air Pollutants for Surface Coating of Miscellaneous Metal Parts and Products, 40 CFR §63.3880 – 40 CFR §63.3981) and Subpart PPPP (National Emission Standards for Hazardous Air Pollutants for Surface Coating of Plastic Parts and Products, 40 CFR §63.4480 – 40 CFR §63.4581) of the National Emission Standards for Hazardous Air Pollutants (NESHAP).

Authority for Requirement: 40 CFR Part 63 Subpart MMMM and 40 CFR Part 63 Subpart PPPP 567 IAC 23.1(4)“cm” and 567 IAC 23.1(4)“cp”

### Emission Point Characteristics

*The emission point shall conform to the specifications listed below.*

Stack Height, (ft, from the ground): N/A

Stack Opening, (inches, dia.): N/A

Exhaust Flow Rate (scfm): N/A - fugitive

Exhaust Temperature (°F): N/A

Discharge Style: N/A

Authority for Requirement: Iowa DNR Construction Permit 06-A-061-S1

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

### Monitoring Requirements

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?** Yes  No

**Facility Maintained Operation & Maintenance Plan Required?** Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?** Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## **Emission Point ID Number: F27**

### Associated Equipment

Associated Emission Unit ID Numbers: F27

---

Emission Unit vented through this Emission Point: F27  
Emission Unit Description: Customer-required Sealant  
Raw Material/Fuel: Sealant  
Rated Capacity: 18.51 lb/hr

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Volatile Organic Compounds (VOC)  
Emission Limit(s): 9.46 tons/yr  
Authority for Requirement: Iowa DNR Construction Permit 06-A-062

#### **Operating Requirements with Associated Monitoring and Recordkeeping**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below. All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.*

Process throughput:

1. The maximum VOC content of any material used in this emission source (EU F-27) shall not exceed 54% by weight.
2. The amount of VOC containing material used in this emission source (EU F-27) shall not exceed 35,040 pounds per twelve month rolling period.

Authority for Requirement: Iowa DNR Construction Permit 06-A-062

3. Demonstrate that, based on the coatings, thinners and/or other additives, and cleaning materials used in the coating operation(s), the organic HAP emission rate for the coating operation(s) is less than or equal to 0.31 kg/liter (2.6 lb/gal) coating solids, calculated as a rolling 12-month emission rate and determined on a monthly basis. All requirements of 40 CFR 63.3950, 3951, and 3952 must be met to demonstrate compliance.

Authority for Requirement: 40 CFR 63.3891(b)  
567 IAC 23.1(4)“cp”

Reporting & Record keeping:

1. The owner or operator shall keep Material Safety Data Sheets (MSDS) of each VOC containing material used in this emission source (EU F-27).
2. The owner or operator shall keep records of the amount of VOC containing material used in EU F-27, and update the twelve-month rolling total on a monthly basis.

Authority for Requirement: Iowa DNR Construction Permit 06-A-062

3. Continuous compliance shall be demonstrated and reported and records maintained as specified in 40 CFR 63.3952.

Authority for Requirement: 40 CFR 63 Subpart Mmmm

NESHAP

This emission unit is subject to Subpart A (General Provisions, 40 CFR §63.1 – 40 CFR §63.15) and Subpart Mmmm (National Emission Standards for Hazardous Air Pollutants for Surface Coating of Miscellaneous Metal Parts and Products, 40 CFR §63.3880 – 40 CFR §63.3981) of the National Emission Standards for Hazardous Air Pollutants (NESHAP).

Emission Point Characteristics

*The emission point shall conform to the specifications listed below.*

Stack Height, (ft, from the ground): N/A

Stack Opening, (inches, dia.): N/A

Exhaust Flow Rate (scfm): N/A-Fugitive

Exhaust Temperature (°F): N/A

Discharge Style: N/A

Authority for Requirement: Iowa DNR Construction Permit 06-A-062

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

Monitoring Requirements

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## **Emission Point ID Number: 47**

### Associated Equipment

Associated Emission Unit ID Numbers: 47

---

Emission Unit vented through this Emission Point: 47  
Emission Unit Description: Corrugator  
Raw Material/Fuel: Filter Substrate  
Rated Capacity: 300 lb/hr

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit: 40% <sup>(1)</sup>

Authority for Requirement: Iowa DNR Construction Permit 12-A-360-S3  
567 IAC 23.3(2)"d"

Pollutant: Particulate Matter (PM)

Emission Limit: 0.1 gr/scf

Authority for Requirement: Iowa DNR Construction Permit 12-A-360-S3  
567 IAC 23.2(2)"a"

Pollutant: Volatile Organic Compounds (VOC)

Emission Limit: 120.0 TPY<sup>(2)</sup>

Authority for Requirement: Iowa DNR Construction Permit 12-A-360-S3

Pollutant: Single HAP (SHAP)

Emission Limit: 9.4 TPY<sup>(2)</sup>

Authority for Requirement: Iowa DNR Construction Permit 12-A-360-S3

Pollutant: Total HAP (THAP)

Emission Limit: 24.4 TPY<sup>(2)</sup>

Authority for Requirement: Iowa DNR Construction Permit 12-A-360-S3

<sup>(1)</sup>An exceedance of the indicator opacity of 25% will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

<sup>(2)</sup>The emission limit is for the combined emissions from emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.

### **Operating Requirements with Associated Monitoring and Recordkeeping**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below. All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.*

- A. The owner or operator shall not exceed 320,000 pounds per twelve (12) month rolling period of VOC containing resin polymer used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- B. The owner or operator shall record on a monthly basis the amount of VOC containing resin polymer used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56 in units of pounds.
- C. The owner or operator shall recover a minimum of 50 percent of the VOC containing resin polymer used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- D. The owner or operator shall record on a monthly basis the amount of VOC containing resin polymer recovered (and disposed of offsite) from emission units EU-48, EU-49, EU-53, and EU-54 in units of pounds.
- E. The owner or operator shall not exceed 15,800,000 pounds per twelve (12) month rolling period of VOC containing substrate in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- F. The owner or operator shall record on a monthly basis the amount of VOC containing substrate used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56, in pounds.
- G. The owner or operator shall not use VOC containing substrate with a VOC content in excess of 0.5% by weight, or be able to demonstrate that the weighted average VOC content of substrate processed is 0.5% or less in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56. The weighted average shall be calculated as the total weight of VOC in the processed substrate divided by the total weight of substrate processed in that calendar month.
- H. The owner or operator shall not exceed 3,740,000 pounds per twelve (12) month rolling period of HAP containing substrate in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- I. The owner or operator shall record on a monthly basis the amount of HAP containing substrate used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56, in pounds.
- J. The owner or operator shall not use HAP containing substrate with a total HAP content in

excess of 0.5% by weight, or be able to demonstrate that the weighted average total HAP content of substrate processed is 0.5% or less in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56. The weighted average shall be calculated as the total weight of total HAP in the processed substrate divided by the total weight of substrate processed in that calendar month.

- K. The owner or operator shall not exceed 320,000 pounds per twelve (12) month rolling period of HAP containing resin polymer in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- L. The owner or operator shall record on a monthly basis the amount of HAP containing resin polymer used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56 in pounds.
- M. The owner or operator shall not use HAP containing resin polymer with a total HAP content in excess of 6.0% by weight.
- N. The owner or operator shall not use HAP containing resin polymer with a SHAP content in excess of 5.4% by weight.
- O. The owner or operator shall not use formaldehyde (CAS number 50-00-0) containing resin polymer with a content in excess of 0.01% by weight.
- P. The owner or operator shall assume all HAPs of HAP containing resin polymer and substrate used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56 are emitted to the atmosphere. If the facility chooses to take credit for HAPs recovered in waste then the facility shall characterize the HAP content of recovered waste from emission units EU-48, EU-49, EU-50, and EU-51.
- Q. The owner or operator shall maintain an inventory of SDS for all resin polymer and substrate used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.

Authority for Requirement: Iowa DNR Construction Permit 12-A-360-S3

**Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height, (ft, from the ground): 31

Stack Opening, (inches): 13 x 17

Exhaust Flow Rate (scfm): 1,500

Exhaust Temperature (°F): 250

Discharge Style: Downward

Authority for Requirement: Iowa DNR Construction Permit 12-A-360-S3

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the

emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**                      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**                      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**                      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

## Emission Point ID Numbers: 46A and 46B

### Associated Equipment

Associated Emission Unit ID Numbers: See Table: Mix Room

Table: Mix Room

Emission Point Number	Associated Emission Unit Number	Emission Unit Description	Raw Material	Rated Capacity
46A	46	Mix Room	Polymer	45 lb/hr
46B				

### Applicable Requirements

#### Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

*The emissions from these emission points shall not exceed the levels specified below.*

Table: Ultra Web Lines-Emission Limits

Emission Point Number	Opacity 567 IAC 23.3(2)"d"	PM 567 IAC 23.3(2)"a"	VOC (TPY)	Single HAP (TPY)	Total HAP (TPY)	Authority for Requirement (Construction Permit Number)
46A	40% <sup>(1)</sup>	0.1 gr/dscf	120 <sup>(2)</sup>	9.4 <sup>(2)</sup>	24.4 <sup>(2)</sup>	12-A-364-S3
46B	40% <sup>(1)</sup>	0.1 gr/dscf	120 <sup>(2)</sup>	9.4 <sup>(2)</sup>	24.4 <sup>(2)</sup>	12-A-363-S3

<sup>(1)</sup>An exceedance of the indicator opacity of “no visible emissions” will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

<sup>(2)</sup>The emission limit is for the combined emissions from emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.

### **Operating Requirements with Associated Monitoring and Recordkeeping**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below. All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping for this permit shall be:*

- A. The owner or operator shall not exceed 320,000 pounds per twelve (12) month rolling period of VOC containing resin polymer used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- B. The owner or operator shall record on a monthly basis the amount of VOC containing resin polymer used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56 in units of pounds.
- C. The owner or operator shall recover a minimum of 50 percent of the VOC containing resin polymer used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- D. The owner or operator shall record on a monthly basis the amount of VOC containing resin polymer recovered (and disposed of offsite) from emission units EU-48, EU-49, EU-53, and EU-54 in units of pounds.
- E. The owner or operator shall not exceed 15,800,000 pounds per twelve (12) month rolling period of VOC containing substrate in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- F. The owner or operator shall record on a monthly basis the amount of VOC containing substrate used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56, in pounds.
- G. The owner or operator shall not use VOC containing substrate with a VOC content in excess of 0.5% by weight, or be able to demonstrate that the weighted average VOC content of substrate processed is 0.5% or less in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56. The weighted average shall be calculated as the total weight of VOC in the processed substrate divided by the total weight of substrate processed in that calendar month.
- H. The owner or operator shall not exceed 3,740,000 pounds per twelve (12) month rolling period of HAP containing substrate in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- I. The owner or operator shall record on a monthly basis the amount of HAP containing substrate used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56, in pounds.
- J. The owner or operator shall not use HAP containing substrate with a total HAP content in

excess of 0.5% by weight, or be able to demonstrate that the weighted average total HAP content of substrate processed is 0.5% or less in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56. The weighted average shall be calculated as the total weight of total HAP in the processed substrate divided by the total weight of substrate processed in that calendar month.

- K. The owner or operator shall not exceed 320,000 pounds per twelve (12) month rolling period of HAP containing resin polymer in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.
- L. The owner or operator shall record on a monthly basis the amount of HAP containing resin polymer used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56 in pounds.
- M. The owner or operator shall not use HAP containing resin polymer with a total HAP content in excess of 6.0% by weight.
- N. The owner or operator shall not use HAP containing resin polymer with a SHAP content in excess of 5.4% by weight.
- O. The owner or operator shall not use formaldehyde (CAS number 50-00-0) containing resin polymer with a content in excess of 0.01% by weight.
- P. The owner or operator shall assume all HAPs of HAP containing resin polymer and substrate used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56 are emitted to the atmosphere. If the facility chooses to take credit for HAPs recovered in waste then the facility shall characterize the HAP content of recovered waste from emission units EU-48, EU-49, EU-50, and EU-51.
- Q. The owner or operator shall maintain an inventory of SDS for all resin polymer and substrate used in emission units EU-46, EU-47, EU-48, EU-49, EU-53, EU-54, EU-50, EU-51, EU-55, and EU-56.

Authority for Requirement: Iowa DNR Construction Permit 12-A-363-S3 and 12-A-364-S3

**Emission Point Characteristics**

*These emission points shall conform to the specifications listed below.*

Table: Mix Room – Emission Point Characteristics

Emission Point Number	Associated Emission Unit Number	Authority for Requirement (Construction Permit No.)	Stack Characteristics				Discharge Style
			Height (feet from the ground)	Opening (inches)	Exhaust Flowrate (scfm)	Exhaust Temp. (°F)	
46A	46	12-A-364-S3	31	16 x 20.5	1,000	70	Downward
46B		12-A-363-S3	31	13 x 17	1,000	70	Downward

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may

vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**                      Yes  No

**Facility Maintained Operation & Maintenance Plan Required?**                      Yes  No

**Compliance Assurance Monitoring (CAM) Plan Required?**                      Yes  No

Authority for Requirement: 567 IAC 22.108(3)

#### **IV. General Conditions**

This permit is issued under the authority of the Iowa Code subsection 455B.133(8) and in accordance with 567 Iowa Administrative Code chapter 22.

##### **G1. Duty to Comply**

1. The permittee must comply with all conditions of the Title V permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action; for a permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. *567 IAC 22.108(9)"a"*
2. Any compliance schedule shall be supplemental to, and shall not sanction noncompliance with, the applicable requirements on which it is based. *567 IAC 22.105 (2)"h"(3)*
3. Where an applicable requirement of the Act is more stringent than an applicable requirement of regulations promulgated under Title IV of the Act, both provisions shall be enforceable by the administrator and are incorporated into this permit. *567 IAC 22.108 (1)"b"*
4. Unless specified as either "state enforceable only" or "local program enforceable only", all terms and conditions in the permit, including provisions to limit a source's potential to emit, are enforceable by the administrator and citizens under the Act. *567 IAC 22.108 (14)*
5. It shall not be a defense for a permittee, in an enforcement action, that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. *567 IAC 22.108 (9)"b"*
6. For applicable requirements with which the permittee is in compliance, the permittee shall continue to comply with such requirements. For applicable requirements that will become effective during the permit term, the permittee shall meet such requirements on a timely basis. *567 IAC 22.108(15)"c"*

##### **G2. Permit Expiration**

1. Except as provided in rule 567—22.104(455B), permit expiration terminates a source's right to operate unless a timely and complete application for renewal has been submitted in accordance with rule 567—22.105(455B). *567 IAC 22.116(2)*
2. To be considered timely, the owner, operator, or designated representative (where applicable) of each source required to obtain a Title V permit shall submit on forms or electronic format specified by the Department to the Air Quality Bureau, Iowa Department of Natural Resources, Air Quality Bureau, Wallace State Office Building, 502 E 9th St., Des Moines, IA 50319-0034, two copies (three if your facility is located in Linn or Polk county) of a complete permit application, at least 6 months but not more than 18 months prior to the date of permit expiration. An additional copy must also be sent to U.S. EPA Region VII, Attention: Chief of Air Permits, 11201 Renner Blvd., Lenexa, KS 66219. Additional copies to local programs or EPA are not required for application materials submitted through the electronic format specified by the Department. The application must include all emission points, emission units, air pollution control equipment, and monitoring devices at the facility. All emissions generating activities, including fugitive emissions, must be included. The definition of a complete application is as indicated in *567 IAC 22.105(2)*. *567 IAC 22.105*

##### **G3. Certification Requirement for Title V Related Documents**

Any application, report, compliance certification or other document submitted pursuant to this permit shall contain certification by a responsible official of truth, accuracy, and completeness. All certifications shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. *567 IAC 22.107 (4)*

##### **G4. Annual Compliance Certification**

By March 31 of each year, the permittee shall submit compliance certifications for the previous calendar year. The certifications shall include descriptions of means to monitor the compliance status of all emissions sources including emissions limitations, standards, and work practices in accordance with applicable requirements. The certification for a source shall include the identification of each term or condition of the permit that is the basis of the certification; the compliance status; whether compliance was continuous or intermittent; the method(s) used for determining the compliance status of the source, currently and over the reporting period consistent with all applicable department rules. For sources determined not to be in compliance at the time of compliance certification, a compliance schedule shall be submitted which provides for periodic progress reports, dates for achieving activities, milestones, and an explanation of why any dates were missed and preventive or corrective measures. The compliance certification shall be submitted to the administrator, director, and the appropriate DNR Field office. *567 IAC 22.108 (15)"e"*

#### **G5. Semi-Annual Monitoring Report**

By March 31 and September 30 of each year, the permittee shall submit a report of any monitoring required under this permit for the 6 month periods of July 1 to December 31 and January 1 to June 30, respectively. All instances of deviations from permit requirements must be clearly identified in these reports, and the report must be signed by a responsible official, consistent with 567 IAC 22.107(4). The semi-annual monitoring report shall be submitted to the director and the appropriate DNR Field office. *567 IAC 22.108 (5)*

#### **G6. Annual Fee**

1. The permittee is required under subrule 567 IAC 22.106 to pay an annual fee based on the total tons of actual emissions of each regulated air pollutant. Beginning July 1, 1996, Title V operating permit fees will be paid on July 1 of each year. The fee shall be based on emissions for the previous calendar year.
2. The fee amount shall be calculated based on the first 4,000 tons of each regulated air pollutant emitted each year. The fee to be charged per ton of pollutant will be available from the department by June 1 of each year. The Responsible Official will be advised of any change in the annual fee per ton of pollutant.
3. The emissions inventory shall be submitted annually by March 31 with forms specified by the department documenting actual emissions for the previous calendar year.
4. The fee shall be submitted annually by July 1 with forms specified by the department.
5. If there are any changes to the emission calculation form, the department shall make revised forms available to the public by January 1. If revised forms are not available by January 1, forms from the previous year may be used and the year of emissions documented changed. The department shall calculate the total statewide Title V emissions for the prior calendar year and make this information available to the public no later than April 30 of each year.
6. Phase I acid rain affected units under section 404 of the Act shall not be required to pay a fee for emissions which occur during the years 1993 through 1999 inclusive.
7. The fee for a portable emissions unit or stationary source which operates both in Iowa and out of state shall be calculated only for emissions from the source while operating in Iowa.
8. Failure to pay the appropriate Title V fee represents cause for revocation of the Title V permit as indicated in 567 IAC 22.115(1)"d".

#### **G7. Inspection of Premises, Records, Equipment, Methods and Discharges**

Upon presentation of proper credentials and any other documents as may be required by law, the permittee shall allow the director or the director's authorized representative to:

1. Enter upon the permittee's premises where a Title V source is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
3. Inspect, at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
4. Sample or monitor, at reasonable times, substances or parameters for the purpose of ensuring compliance with the permit or other applicable requirements. *567 IAC 22.108 (15)"b"*

**G8. Duty to Provide Information**

The permittee shall furnish to the director, within a reasonable time, any information that the director may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee also shall furnish to the director copies of records required to be kept by the permit, or for information claimed to be confidential, the permittee shall furnish such records directly to the administrator of EPA along with a claim of confidentiality. *567 IAC 22.108 (9)"e"*

**G9. General Maintenance and Repair Duties**

The owner or operator of any air emission source or control equipment shall:

1. Maintain and operate the equipment or control equipment at all times in a manner consistent with good practice for minimizing emissions.
2. Remedy any cause of excess emissions in an expeditious manner.
3. Minimize the amount and duration of any excess emission to the maximum extent possible during periods of such emissions. These measures may include but not be limited to the use of clean fuels, production cutbacks, or the use of alternate process units or, in the case of utilities, purchase of electrical power until repairs are completed.
4. Schedule, at a minimum, routine maintenance of equipment or control equipment during periods of process shutdowns to the maximum extent possible. *567 IAC 24.2(1)*

**G10. Recordkeeping Requirements for Compliance Monitoring**

1. In addition to any source specific recordkeeping requirements contained in this permit, the permittee shall maintain the following compliance monitoring records, where applicable:
  - a. The date, place and time of sampling or measurements
  - b. The date the analyses were performed.
  - c. The company or entity that performed the analyses.
  - d. The analytical techniques or methods used.
  - e. The results of such analyses; and
  - f. The operating conditions as existing at the time of sampling or measurement.
  - g. The records of quality assurance for continuous compliance monitoring systems (including but not limited to quality control activities, audits and calibration drifts.)
2. The permittee shall retain records of all required compliance monitoring data and support information for a period of at least 5 years from the date of compliance monitoring sample, measurement report or application. Support information includes all calibration and maintenance records and all original strip chart recordings for continuous compliance monitoring, and copies of all reports required by the permit.
3. For any source which in its application identified reasonably anticipated alternative operating scenarios, the permittee shall:
  - a. Comply with all terms and conditions of this permit specific to each alternative scenario.
  - b. Maintain a log at the permitted facility of the scenario under which it is operating.

- c. Consider the permit shield, if provided in this permit, to extend to all terms and conditions under each operating scenario. *567 IAC 22.108(4), 567 IAC 22.108(12)*

**G11. Evidence used in establishing that a violation has or is occurring.**

Notwithstanding any other provisions of these rules, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions herein.

1. Information from the use of the following methods is presumptively credible evidence of whether a violation has occurred at a source:
  - a. A monitoring method approved for the source and incorporated in an operating permit pursuant to 567 Chapter 22;
  - b. Compliance test methods specified in 567 Chapter 25; or
  - c. Testing or monitoring methods approved for the source in a construction permit issued pursuant to 567 Chapter 22.
2. The following testing, monitoring or information gathering methods are presumptively credible testing, monitoring, or information gathering methods:
  - a. Any monitoring or testing methods provided in these rules; or
  - b. Other testing, monitoring, or information gathering methods that produce information comparable to that produced by any method in subrule 21.5(1) or this subrule. *567 IAC 21.5(1)-567 IAC 21.5(2)*

**G12. Prevention of Accidental Release: Risk Management Plan Notification and Compliance Certification**

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Act, the permittee shall notify the department of this requirement. The plan shall be filed with all appropriate authorities by the deadline specified by EPA. A certification that this risk management plan is being properly implemented shall be included in the annual compliance certification of this permit. *567 IAC 22.108(6)*

**G13. Hazardous Release**

The permittee must report any situation involving the actual, imminent, or probable release of a hazardous substance into the atmosphere which, because of the quantity, strength and toxicity of the substance, creates an immediate or potential danger to the public health, safety or to the environment. A verbal report shall be made to the department at (515) 725-8694 and to the local police department or the office of the sheriff of the affected county as soon as possible but not later than six hours after the discovery or onset of the condition. This verbal report must be followed up with a written report as indicated in 567 IAC 131.2(2). *567 IAC Chapter 131-State Only*

**G14. Excess Emissions and Excess Emissions Reporting Requirements**

1. Excess Emissions. Excess emission during a period of startup, shutdown, or cleaning of control equipment is not a violation of the emission standard if the startup, shutdown or cleaning is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions. Cleaning of control equipment which does not require the shutdown of the process equipment shall be limited to one six-minute period per one-hour period. An incident of excess emission (other than an incident during startup, shutdown or cleaning of control equipment) is a violation. If the owner or operator of a source maintains that the incident of excess emission was due to a malfunction, the owner or operator must show that the conditions which caused the incident of excess emission were not preventable by reasonable maintenance and control measures. Determination of any subsequent enforcement action will be made following review of this report. If excess emissions are occurring, either the control equipment causing the excess emission shall be repaired in an expeditious manner or the process generating the emissions shall

be shutdown within a reasonable period of time. An expeditious manner is the time necessary to determine the cause of the excess emissions and to correct it within a reasonable period of time. A reasonable period of time is eight hours plus the period of time required to shut down the process without damaging the process equipment or control equipment. A variance from this subrule may be available as provided for in Iowa Code section 455B.143. In the case of an electric utility, a reasonable period of time is eight hours plus the period of time until comparable generating capacity is available to meet consumer demand with the affected unit out of service, unless, the director shall, upon investigation, reasonably determine that continued operation constitutes an unjustifiable environmental hazard and issue an order that such operation is not in the public interest and require a process shutdown to commence immediately.

## 2. Excess Emissions Reporting

a. Initial Reporting of Excess Emissions. An incident of excess emission (other than an incident of excess emission during a period of startup, shutdown, or cleaning) shall be reported to the appropriate field office of the department within eight hours of, or at the start of the first working day following the onset of the incident. The reporting exemption for an incident of excess emission during startup, shutdown or cleaning does not relieve the owner or operator of a source with continuous monitoring equipment of the obligation of submitting reports required in 567-subrule 25.1(6). An initial report of excess emission is not required for a source with operational continuous monitoring equipment (as specified in 567-subrule 25.1(1) ) if the incident of excess emission continues for less than 30 minutes and does not exceed the applicable emission standard by more than 10 percent or the applicable visible emission standard by more than 10 percent opacity. The initial report may be made by electronic mail (E-mail), in person, or by telephone and shall include as a minimum the following:

- i. The identity of the equipment or source operation from which the excess emission originated and the associated stack or emission point.
- ii. The estimated quantity of the excess emission.
- iii. The time and expected duration of the excess emission.
- iv. The cause of the excess emission.
- v. The steps being taken to remedy the excess emission.
- vi. The steps being taken to limit the excess emission in the interim period.

b. Written Reporting of Excess Emissions. A written report of an incident of excess emission shall be submitted as a follow-up to all required initial reports to the department within seven days of the onset of the upset condition, and shall include as a minimum the following:

- i. The identity of the equipment or source operation point from which the excess emission originated and the associated stack or emission point.
- ii. The estimated quantity of the excess emission.
- iii. The time and duration of the excess emission.
- iv. The cause of the excess emission.
- v. The steps that were taken to remedy and to prevent the recurrence of the incident of excess emission.
- vi. The steps that were taken to limit the excess emission.
- vii. If the owner claims that the excess emission was due to malfunction, documentation to support this claim. *567 IAC 24.1(1)-567 IAC 24.1(4)*

3. Emergency Defense for Excess Emissions. For the purposes of this permit, an “emergency” means any situation arising from sudden and reasonably unforeseeable events beyond the control

of the source, including acts of God, which situation requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission limitation under the permit due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include non-compliance, to the extent caused by improperly designed equipment, lack of preventive maintenance, careless or improper operation or operator error. An emergency constitutes an affirmative defense to an action brought for non-compliance with technology based limitations if it can be demonstrated through properly signed contemporaneous operating logs or other relevant evidence that:

- a. An emergency occurred and that the permittee can identify the cause(s) of the emergency;
- b. The facility at the time was being properly operated;
- c. During the period of the emergency, the permittee took all reasonable steps to minimize levels of emissions that exceeded the emissions standards or other requirements of the permit; and
- d. The permittee submitted notice of the emergency to the director by certified mail within two working days of the time when the emissions limitations were exceeded due to the emergency. This notice fulfills the requirement of paragraph 22.108(5)"b." – See G15. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

In any enforcement proceeding, the permittee seeking to establish the occurrence of an emergency has the burden of proof. This provision is in addition to any emergency or upset provision contained in any applicable requirement. *567 IAC 22.108(16)*

#### **G15. Permit Deviation Reporting Requirements**

A deviation is any failure to meet a term, condition or applicable requirement in the permit. Reporting requirements for deviations that result in a hazardous release or excess emissions have been indicated above (see G13 and G14). Unless more frequent deviation reporting is specified in the permit, any other deviation shall be documented in the semi-annual monitoring report and the annual compliance certification (see G4 and G5). *567 IAC 22.108(5)"b"*

#### **G16. Notification Requirements for Sources That Become Subject to NSPS and NESHAP Regulations**

During the term of this permit, the permittee must notify the department of any source that becomes subject to a standard or other requirement under 567-subrule 23.1(2) (standards of performance of new stationary sources) or section 111 of the Act; or 567-subrule 23.1(3) (emissions standards for hazardous air pollutants), 567-subrule 23.1(4) (emission standards for hazardous air pollutants for source categories) or section 112 of the Act. This notification shall be submitted in writing to the department pursuant to the notification requirements in 40 CFR Section 60.7, 40 CFR Section 61.07, and/or 40 CFR Section 63.9. *567 IAC 23.1(2), 567 IAC 23.1(3), 567 IAC 23.1(4)*

#### **G17. Requirements for Making Changes to Emission Sources That Do Not Require Title V Permit Modification**

1. Off Permit Changes to a Source. Pursuant to section 502(b)(10) of the CAAA, the permittee may make changes to this installation/facility without revising this permit if:
  - a. The changes are not major modifications under any provision of any program required by section 110 of the Act, modifications under section 111 of the act, modifications under section 112 of the act, or major modifications as defined in 567 IAC Chapter 22.
  - b. The changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions);

- c. The changes are not modifications under any provisions of Title I of the Act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or as total emissions);
- d. The changes are not subject to any requirement under Title IV of the Act (revisions affecting Title IV permitting are addressed in rules 567—22.140(455B) through 567 - 22.144(455B));
- e. The changes comply with all applicable requirements.
- f. For each such change, the permitted source provides to the department and the administrator by certified mail, at least 30 days in advance of the proposed change, a written notification, including the following, which must be attached to the permit by the source, the department and the administrator:
  - i. A brief description of the change within the permitted facility,
  - ii. The date on which the change will occur,
  - iii. Any change in emission as a result of that change,
  - iv. The pollutants emitted subject to the emissions trade
  - v. If the emissions trading provisions of the state implementation plan are invoked, then Title V permit requirements with which the source shall comply; a description of how the emissions increases and decreases will comply with the terms and conditions of the Title V permit.
  - vi. A description of the trading of emissions increases and decreases for the purpose of complying with a federally enforceable emissions cap as specified in and in compliance with the Title V permit; and
  - vii. Any permit term or condition no longer applicable as a result of the change.

2. Such changes do not include changes that would violate applicable requirements or contravene federally enforceable permit terms and conditions that are monitoring (including test methods), record keeping, reporting, or compliance certification requirements. *567 IAC 22.110(2)*

3. Notwithstanding any other part of this rule, the director may, upon review of a notice, require a stationary source to apply for a Title V permit if the change does not meet the requirements of subrule 22.110(1). *567 IAC 22.110(3)*

4. The permit shield provided in subrule 22.108(18) shall not apply to any change made pursuant to this rule. Compliance with the permit requirements that the source will meet using the emissions trade shall be determined according to requirements of the state implementation plan authorizing the emissions trade. *567 IAC 22.110(4)*

5. No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes, for changes that are provided for in this permit. *567 IAC 22.108(11)*

### **G18. Duty to Modify a Title V Permit**

#### **1. Administrative Amendment.**

- a. An administrative permit amendment is a permit revision that does any of the following:
  - i. Correct typographical errors
  - ii. Identify a change in the name, address, or telephone number of any person identified in the permit, or provides a similar minor administrative change at the source;
  - iii. Require more frequent monitoring or reporting by the permittee; or

iv. Allow for a change in ownership or operational control of a source where the director determines that no other change in the permit is necessary, provided that a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new permittee has been submitted to the director.

b. The permittee may implement the changes addressed in the request for an administrative amendment immediately upon submittal of the request. The request shall be submitted to the director.

c. Administrative amendments to portions of permits containing provisions pursuant to Title IV of the Act shall be governed by regulations promulgated by the administrator under Title IV of the Act.

## 2. Minor Title V Permit Modification.

a. Minor Title V permit modification procedures may be used only for those permit modifications that satisfy all of the following:

- i. Do not violate any applicable requirement;
- ii. Do not involve significant changes to existing monitoring, reporting or recordkeeping requirements in the Title V permit;
- iii. Do not require or change a case by case determination of an emission limitation or other standard, or an increment analysis;
- iv. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed in order to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include any federally enforceable emissions caps which the source would assume to avoid classification as a modification under any provision under Title I of the Act; and an alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Act;
- v. Are not modifications under any provision of Title I of the Act; and
- vi. Are not required to be processed as significant modification under rule 567 - 22.113(455B).

b. An application for minor permit revision shall be on the minor Title V modification application form and shall include at least the following:

- i. A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
- ii. The permittee's suggested draft permit;
- iii. Certification by a responsible official, pursuant to 567 IAC 22.107(4), that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used; and
- iv. Completed forms to enable the department to notify the administrator and the affected states as required by 567 IAC 22.107(7).

c. The permittee may make the change proposed in its minor permit modification application immediately after it files the application. After the permittee makes this change and until the director takes any of the actions specified in 567 IAC 22.112(4) "a" to "c", the permittee must comply with both the applicable requirements governing the change and the proposed permit terms and conditions. During this time, the permittee need not comply with the existing permit terms and conditions it seeks to modify. However, if the permittee fails to comply with its proposed permit terms and conditions

during this time period, the existing permit terms and conditions it seeks to modify may be enforced against the facility.

### 3. Significant Title V Permit Modification.

Significant Title V modification procedures shall be used for applications requesting Title V permit modifications that do not qualify as minor Title V modifications or as administrative amendments. These include but are not limited to all significant changes in monitoring permit terms, every relaxation of reporting or recordkeeping permit terms, and any change in the method of measuring compliance with existing requirements. Significant Title V modifications shall meet all requirements of 567 IAC Chapter 22, including those for applications, public participation, review by affected states, and review by the administrator, as those requirements that apply to Title V issuance and renewal.

The permittee shall submit an application for a significant permit modification not later than three months after commencing operation of the changed source unless the existing Title V permit would prohibit such construction or change in operation, in which event the operation of the changed source may not commence until the department revises the permit. *567 IAC 22.111-567 IAC 22.113*

### **G19. Duty to Obtain Construction Permits**

Unless exempted in 567 IAC 22.1(2) or to meet the parameters established in 567 IAC 22.1(1)"c", the permittee shall not construct, install, reconstruct or alter any equipment, control equipment or anaerobic lagoon without first obtaining a construction permit, or conditional permit, or permit pursuant to rule 567 IAC 22.8, or permits required pursuant to rules 567 IAC 22.4, 567 IAC 22.5, 567 IAC 31.3, and 567 IAC 33.3 as required in 567 IAC 22.1(1). A permit shall be obtained prior to the initiation of construction, installation or alteration of any portion of the stationary source or anaerobic lagoon. 567 IAC 22.1(1)

### **G20. Asbestos**

The permittee shall comply with 567 IAC 23.1(3)"a", and 567 IAC 23.2(3)"g" when activities involve asbestos mills, surfacing of roadways, manufacturing operations, fabricating, insulating, waste disposal, spraying applications, demolition and renovation operations (567 IAC 23.1(3)"a"); training fires and controlled burning of a demolished building (567 IAC 23.2).

### **G21. Open Burning**

The permittee is prohibited from conducting open burning, except as provided in 567 IAC 23.2. 567 IAC 23.2 *except* 23.2(3)"j"; 567 IAC 23.2(3)"j" - State Only

### **G22. Acid Rain (Title IV) Emissions Allowances**

The permittee shall not exceed any allowances that it holds under Title IV of the Act or the regulations promulgated there under. Annual emissions of sulfur dioxide in excess of the number of allowances to emit sulfur dioxide held by the owners and operators of the unit or the designated representative of the owners and operators is prohibited. Exceedences of applicable emission rates are prohibited. "Held" in this context refers to both those allowances assigned to the owners and operators by USEPA, and those allowances supplementally acquired by the owners and operators. The use of any allowance prior to the year for which it was allocated is prohibited. Contravention of any other provision of the permit is prohibited. 567 IAC 22.108(7)

### **G23. Stratospheric Ozone and Climate Protection (Title VI) Requirements**

1. The permittee shall comply with the standards for labeling of products using ozone-depleting substances pursuant to 40 CFR Part 82, Subpart E:
  - a. All containers in which a class I or class II substance is stored or transported, all products containing a class I substance, and all products directly manufactured with a class I substance must bear the required warning statement if it is being introduced into interstate commerce pursuant to § 82.106.
  - b. The placement of the required warning statement must comply with the requirements pursuant to § 82.108.
  - c. The form of the label bearing the required warning statement must comply with the requirements pursuant to § 82.110.
  - d. No person may modify, remove, or interfere with the required warning statement except as described in § 82.112.
2. The permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 CFR Part 82, Subpart F, except as provided for MVACs in Subpart B:
  - a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to § 82.156.
  - b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to § 82.158.
  - c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to § 82.161.
  - d. Persons disposing of small appliances, MVACs, and MVAC-like appliances must

comply with reporting and recordkeeping requirements pursuant to § 82.166. ("MVAC-like appliance" as defined at § 82.152)

e. Persons owning commercial or industrial process refrigeration equipment must comply with the leak repair requirements pursuant to § 82.156.

f. Owners/operators of appliances normally containing 50 or more pounds of refrigerant must keep records of refrigerant purchased and added to such appliances pursuant to § 82.166.

3. If the permittee manufactures, transforms, imports, or exports a class I or class II substance, the permittee is subject to all the requirements as specified in 40 CFR part 82, Subpart A, Production and Consumption Controls.

4. If the permittee performs a service on motor (fleet) vehicles when this service involves ozone-depleting substance refrigerant (or regulated substitute substance) in the motor vehicle air conditioner (MVAC), the permittee is subject to all the applicable requirements as specified in 40 CFR part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners. The term "motor vehicle" as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed. The term "MVAC" as used in Subpart B does not include the air-tight sealed refrigeration system used as refrigerated cargo, or system used on passenger buses using HCFC-22 refrigerant,

5. The permittee shall be allowed to switch from any ozone-depleting or greenhouse gas generating substances to any alternative that is listed in the Significant New Alternatives Program (SNAP) promulgated pursuant to 40 CFR part 82, Subpart G, Significant New Alternatives Policy Program. *40 CFR part 82*

#### **G24. Permit Reopenings**

1. This permit may be modified, revoked, reopened, and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition. *567 IAC 22.108(9)"c"*

2. Additional applicable requirements under the Act become applicable to a major part 70 source with a remaining permit term of 3 or more years. Revisions shall be made as expeditiously as practicable, but not later than 18 months after the promulgation of such standards and regulations.

a. Reopening and revision on this ground is not required if the permit has a remaining term of less than three years;

b. Reopening and revision on this ground is not required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions have been extended pursuant to 40 CFR 70.4(b)(10)(i) or (ii) as amended to May 15, 2001.

c. Reopening and revision on this ground is not required if the additional applicable requirements are implemented in a general permit that is applicable to the source and the source receives approval for coverage under that general permit. *567 IAC 22.108(17)"a"*, *567 IAC 22.108(17)"b"*

3. A permit shall be reopened and revised under any of the following circumstances:

a. The department receives notice that the administrator has granted a petition for disapproval of a permit pursuant to 40 CFR 70.8(d) as amended to July 21, 1992, provided that the reopening may be stayed pending judicial review of that determination;

b. The department or the administrator determines that the Title V permit contains a material mistake or that inaccurate statements were made in establishing the emissions

standards or other terms or conditions of the Title V permit;

c. Additional applicable requirements under the Act become applicable to a Title V source, provided that the reopening on this ground is not required if the permit has a remaining term of less than three years, the effective date of the requirement is later than the date on which the permit is due to expire, or the additional applicable requirements are implemented in a general permit that is applicable to the source and the source receives approval for coverage under that general permit. Such a reopening shall be complete not later than 18 months after promulgation of the applicable requirement.

d. Additional requirements, including excess emissions requirements, become applicable to a Title IV affected source under the acid rain program. Upon approval by the administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

e. The department or the administrator determines that the permit must be revised or revoked to ensure compliance by the source with the applicable requirements. *567 IAC 22.114(1)*

4. Proceedings to reopen and reissue a Title V permit shall follow the procedures applicable to initial permit issuance and shall effect only those parts of the permit for which cause to reopen exists. *567 IAC 22.114(2)*

5. A notice of intent shall be provided to the Title V source at least 30 days in advance of the date the permit is to be reopened, except that the director may provide a shorter time period in the case of an emergency. *567 IAC 22.114(3)*

#### **G25. Permit Shield**

1. The director may expressly include in a Title V permit a provision stating that compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that:

a. Such applicable requirements are included and are specifically identified in the permit;  
or

b. The director, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the source, and the permit includes the determination or a concise summary thereof.

2. A Title V permit that does not expressly state that a permit shield exists shall be presumed not to provide such a shield.

3. A permit shield shall not alter or affect the following:

a. The provisions of Section 303 of the Act (emergency orders), including the authority of the administrator under that section;

b. The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance;

c. The applicable requirements of the acid rain program, consistent with Section 408(a) of the Act;

d. The ability of the department or the administrator to obtain information from the facility pursuant to Section 114 of the Act. *567 IAC 22.108 (18)*

#### **G26. Severability**

The provisions of this permit are severable and if any provision or application of any provision is found to be invalid by this department or a court of law, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected by such finding. *567 IAC 22.108 (8)*

#### **G27. Property Rights**

The permit does not convey any property rights of any sort, or any exclusive privilege. *567 IAC 22.108 (9)"d"*

**G28. Transferability**

This permit is not transferable from one source to another. If title to the facility or any part of it is transferred, an administrative amendment to the permit must be sought consistent with the requirements of *567 IAC 22.111(1)*. *567 IAC 22.111 (1)"d"*

**G29. Disclaimer**

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions.  
*567 IAC 22.3(3)"c"*

**G30. Notification and Reporting Requirements for Stack Tests or Monitor Certification**

The permittee shall notify the department's stack test contact in writing not less than 30 days before a required test or performance evaluation of a continuous emission monitor is performed to determine compliance with applicable requirements of 567 – Chapter 23 or a permit condition. Such notice shall include the time, the place, the name of the person who will conduct the test and other information as required by the department. If the owner or operator does not provide timely notice to the department, the department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with applicable rules or permit conditions. Upon written request, the department may allow a notification period of less than 30 days. At the department's request, a pretest meeting shall be held not later than 15 days prior to conducting the compliance demonstration. A testing protocol shall be submitted to the department no later than 15 days before the owner or operator conducts the compliance demonstration. A representative of the department shall be permitted to witness the tests. Results of the tests shall be submitted in writing to the department's stack test contact in the form of a comprehensive report within six weeks of the completion of the testing. Compliance tests conducted pursuant to this permit shall be conducted with the source operating in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which the source shall be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the equipment manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the department that the source has been physically altered so that capacity cannot be exceeded, or the department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the department to determine whether such source is in compliance.

Stack test notifications, reports and correspondence shall be sent to:

Stack Test Review Coordinator  
Iowa DNR, Air Quality Bureau  
Wallace State Office Building  
502 E 9<sup>th</sup> St.  
Des Moines, IA 50319-0034  
(515) 725-9545

Within Polk and Linn Counties, stack test notifications, reports and correspondence shall also be directed to the supervisor of the respective county air pollution program.

*567 IAC 25.1(7)"a", 567 IAC 25.1(9)*

**G31. Prevention of Air Pollution Emergency Episodes**

The permittee shall comply with the provisions of 567 IAC Chapter 26 in the prevention of excessive build-up of air contaminants during air pollution episodes, thereby preventing the occurrence of an emergency due to the effects of these contaminants on the health of persons.  
*567 IAC 26.1(1)*

### **G32. Contacts List**

The current address and phone number for reports and notifications to the EPA administrator is:

Chief of Air Permits  
U.S. EPA Region 7  
Air Permits and Compliance Branch  
11201 Renner Blvd.  
Lenexa, KS 66219  
(913) 551-7020

The current address and phone number for reports and notifications to the department or the Director is:

Chief, Air Quality Bureau  
Iowa Department of Natural Resources  
Wallace State Office Building  
502 E 9<sup>th</sup> St.  
Des Moines, IA 50319-0034  
(515) 725-8200

Reports or notifications to the DNR Field Offices or local programs shall be directed to the supervisor at the appropriate field office or local program. Current addresses and phone numbers are:

#### **Field Office 1**

909 West Main – Suite 4  
Manchester, IA 52057  
(563) 927-2640

#### **Field Office 2**

2300-15th St., SW  
Mason City, IA 50401  
(641) 424-4073

#### **Field Office 3**

1900 N. Grand Ave.  
Spencer, IA 51301  
(712) 262-4177

#### **Field Office 4**

1401 Sunnyside Lane  
Atlantic, IA 50022  
(712) 243-1934

#### **Field Office 5**

7900 Hickman Road, Suite #200  
Windsor Heights, IA 50324  
(515) 725-0268

#### **Field Office 6**

1023 West Madison Street  
Washington, IA 52353-1623  
(319) 653-2135

#### **Polk County Public Works Dept.**

Air Quality Division  
5885 NE 14th St.  
Des Moines, IA 50313  
(515) 286-3351

#### **Linn County Public Health**

Air Quality Branch  
501 13th St., NW  
Cedar Rapids, IA 52405  
(319) 892-6000



## **VI. Appendix: NESHAP Links**

1. 40 CFR 63 40 CFR 63 Subpart ZZZZ – National Emission Standard for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines  
<https://www.ecfr.gov/cgi-bin/text-idx?node=sp40.13.63.zzzz>
2. 40 CFR 63Subpart PPPP—National Emission Standards for Hazardous Air Pollutants for Surface Coating of Plastic Parts and Products  
<https://www.ecfr.gov/cgi-bin/text-idx?node=sp40.13.63.pppp>
3. 40 CFR Part 63 Subpart MMMM- National Emission Standards for Hazardous Air Pollutants for Surface Coating of Miscellaneous Metal Parts and Products  
<https://www.ecfr.gov/cgi-bin/text-idx?node=sp40.13.63.mmmm>