

Component	UST System Installation, Repair and Upgrade Requirements	Notification	148 Form	Inspection Checklist	No. of Inspections
Tanks	Installation	✓	✓	✓	3
	Removal	✓		✓	
	Inspection/repair of tank lining		✓		
	Cathodic protection repair/replacement		✓		
Sumps	Installation or replacement		✓	✓	1
	Modification or repair			✓	1
	Installation of penetration boot			✓	1
	Installation of test boot				1
	Tightening of band clamp				
	Repair/replacement of top hats or sump lids				
Piping	Installation or replacement	✓	✓	✓	2
	Removal	✓			
	Modification or repair		✓	✓	2
	Installation of penetration boot		✓	✓	1
	Installation of test boot				
	Tightening of band clamps				
	Replacement of flex hoses with secondary cont.				
	Replacement of flex hoses without secondary cont.)		✓	✓	1
	Replacement of STP with secondary cont.				
	Replacement of STP without secondary cont.		✓	✓	1
	Cathodic protection repair/replacement		✓		
Under Dispenser Containment (UDC)	Installation or replacement		✓	✓	1
	Modification or repair		✓	✓	1
	Installation of penetration boot			✓	1
	Installation of test boot				
	Repair/replacement of float chain mechanism				
	Installation/replacement of dispenser				
Monitoring	New monitoring system				1
	New ATG system where one had not existed before		✓	✓	
	New software that affects monitoring				
	New software that requires cold start				
	Minor software upgrade or reprogramming				
	Sensor replacement—same model				
	Sensor replacement—different model		✓	✓	1
	Leak detector replacement—same model				
	Leak detector replacement—different model		✓	✓	1
	Installation of overfill or high-level alarm		✓	✓	
	Installation of ATG probe—same type				
	Installation of ATG probe—different type		✓	✓	1
	Repair/replacement of spill buckets in fill sump				
	Repair/replacement of direct bury spill buckets		✓	✓	1